

AQ-SPEC

Air Quality Sensor Performance Evaluation Center

Evaluation Summary

Sensor Description

Manufacturer/Model:
PM Monitor/Ecomasure
EcomSmart

Pollutants:
PM_{1.0}, PM_{2.5}

Time Resolution:
1-min

Type: Optical



Additional Information

Field evaluation report:

<http://www.aqmd.gov/aq-spec/evaluations/field>

Lab evaluation report:

<http://www.aqmd.gov/aq-spec/evaluations/laboratory>

AQ-SPEC website:

<http://www.aqmd.gov/aq-spec>

- The accuracy of the Ecomasure EcomSmart sensors for PM_{1.0} was 81.2% to 97.6%; for PM_{2.5} was 80.3% to 99.9% in the lab. Overall, the Ecomasure EcomSmart sensors overestimated PM_{2.5} measurements compared to the T640x in the lab. The sensors underestimated low and high PM_{1.0} measurements.
- The Ecomasure EcomSmart sensors exhibited high precision for all conc., T/RH combinations for PM_{1.0} and PM_{2.5}.
- The Ecomasure EcomSmart sensors showed low intra-model variability for PM_{1.0} and PM_{2.5} in the lab, respectively.
- Data recovery was ~95% to 100% from all units tested in the field and laboratory evaluations, respectively. Unit 0531 did not transmit data during the lab tests.
- Ecomasure EcomSmart sensors showed moderate to strong correlations for PM_{1.0} and PM_{2.5} ($R^2 \sim 0.53$ to 0.75) and no to very weak correlations for PM₁₀ ($R^2 \sim 0.07$ to 0.26) with GRIMM and T640 from the field; and very strong correlations with the T640x in the laboratory studies ($R^2 \sim 0.92$ for PM_{1.0} and PM_{2.5}).
- The same Ecomasure EcomSmart units were tested both in the field (1st stage of testing) and in the laboratory (2nd stage of testing) against reference PM instruments.



Field Evaluation Highlights

- Deployment period 03/10/2022 - 05/10/2022: the Ecomasure EcomSmart sensors showed moderate to strong correlations for PM_{1.0} and PM_{2.5} measurements, and no to very weak correlations with the PM₁₀ mass concentration as recorded by GRIMM and T640, respectively.
- Data recovery from the units was ~96%.

1-hr mean, all ref. inst.

PM_{1.0}: $0.65 < R^2 < 0.80$

PM_{2.5}: $0.56 < R^2 < 0.79$



Coefficient of Determination (R^2) quantifies how the two sensors followed the PM_{1.0}, PM_{2.5}, or PM₁₀ concentration change by the reference instruments.

An R^2 approaching the value of 1 reflects a near perfect agreement, whereas a value of 0 indicates a complete lack of correlation.

Laboratory Evaluation Highlights

Accuracy (PM_{2.5})

$$A (\%) = 100 - \frac{|\bar{X} - \bar{R}|}{\bar{R}} * 100$$


Steady State #	Sensor Mean (µg/m ³)	FEM T640x (µg/m ³)	Accuracy (%)
1	8.4	9.3	90.1
2	14.4	14.3	99.9
3	60.9	52.6	84.1
4	184.5	154.1	80.3
5	355.6	327.1	91.3

Accuracy was evaluated by a concentration ramping experiment at 20 °C and 40% RH. The sensor's readings at each ramping steady state are compared to the reference instrument.

A negative % means sensor's overestimation by more than two fold. The higher the positive value (close to 100%), the higher the sensor's accuracy.




Precision (PM_{2.5})



100% represents high precision.

Sensor's ability to generate precise measurements of PM_{2.5} concentration at low, medium, and high pollutant levels were evaluated under 9 combinations of T and RH, including extreme weather conditions like cold and dry (5 °C and 15% RH) cold and humid (5 °C and 65% RH), hot and humid (35 °C and 65% RH), or hot and dry (35 °C and 15% RH).

Coefficient of Determination



The Ecomasure EcomSmart sensors showed very strong correlations with the corresponding FEM PM_{2.5} data ($R^2 \sim 0.92$) at 20 °C and 40% RH.

For conc. ramping experiments of PM_{1.0}, please see the lab report.

Climate Susceptibility

From the laboratory studies, temperature and relative humidity had minimal effect on the Ecomasure EcomSmart sensors' precision.

Observed Interferents

N/A



All documents, reports, data, and other information provided in this document are for informational use only. Mention of trade names or commercial products does not constitute endorsement or recommendation. As a Government Agency, the South Coast AQMD and its AQ-SPEC program highly recommend interested entities to make use and purchase decisions based on the requirements of their study design, the technical aspects and features of their specific project applications.