



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

---

## SOURCE TEST REPORT

13-307 and 13-308

### CONDUCTED AT

Exide Technologies  
2700 S. Indiana Street  
Vernon, CA 90058

## MULTIPLE METAL AND TOXIC ORGANIC EMISSIONS FROM THE HARD AND SOFT LEAD BAGHOUSE EXHAUST STACKS

TESTED: August 8 and 23, 2013  
and September 20, 2013

LAB DATA RECEIVED: October 11, 2013

ISSUED: October 17, 2013

REPORTED BY: Jason Aspell  
Air Quality Engineer II

REVIEWED BY:

A handwritten signature in blue ink, appearing to read "Michael Garibay".

Michael Garibay  
Supervising Air Quality Engineer

SOURCE TEST ENGINEERING BRANCH

---

MONITORING & ANALYSIS DIVISION

**TABLE OF CONTENTS**

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
<b>SUMMARY</b>	<b>4</b>
<b>EXECUTIVE SUMMARY</b>	<b>5</b>
<b>RESULTS</b>	
<i>Table 1: Summary of Mass Emission Rates for Contaminants of Concern</i>	<b>6</b>
<i>Table 2: Summary of Test Production Rates</i>	<b>7</b>
<i>Table 3: Summary of Test Operating Parameters</i>	<b>8</b>
<i>Table 4: Air Pollution Control Device Differential Pressures</i>	<b>9</b>
<i>Table 5: Summary of Test Results for Metal Emissions from Hard Lead Baghouse</i>	<b>10</b>
<i>Table 6: Summary of Test Results for Metal Emissions from Soft Lead Baghouse</i>	<b>11</b>
<i>Table 7: Summary of Test Results for Toxic Organic Emissions from Hard Lead Baghouse</i>	<b>12</b>
<i>Table 8: Summary of Test Results for Toxic Organic Emissions from Soft Lead Baghouse</i>	<b>13</b>
<b>INTRODUCTION</b>	<b>14</b>
<b>EQUIPMENT AND PROCESS DESCRIPTION</b>	<b>14</b>
<b>SAMPLING AND ANALYTICAL PROCEDURES</b>	
<i>Gas Flow Rate</i>	<b>15</b>
<i>Multiple Metals Sampling and Analysis</i>	<b>16</b>
<i>Toxic Organic Compounds Sampling and Analysis</i>	<b>16</b>
<i>Integrated Gas Sampling and Analysis</i>	<b>17</b>
<b>TEST CRITIQUE</b>	<b>17</b>
<b>FIGURES</b>	
1) <i>Blast Furnace Feed and Exhaust Schematic Diagram</i>	<b>19</b>
2) <i>Hard Lead Baghouse Exhaust Stack</i>	<b>20</b>
3) <i>Soft Lead Baghouse Exhaust Stack</i>	<b>21</b>
4) <i>SCAQMD Methods 1.1 and 2.1</i>	<b>22</b>
5) <i>Hard Lead and Soft Lead Baghouses Stack Diagram and Sampling Locations</i>	<b>23</b>
6) <i>CARB Method 436 Sampling Train Diagram</i>	<b>24</b>

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-3-

Date(s): 8/8/13, 8/23/13 and 9/20/13

<i>7) CARB Method 436 Field Sampling Train and Probe</i>	<b>25</b>
<i>8) SCAQMD Method 10.1</i>	<b>26</b>
<i>9) Blast Furnace Static Pressure (8/23/13)</i>	<b>27</b>
<i>10) Blast Furnace Static Pressure (9/20/13)</i>	<b>28</b>
<i>11) Reverb Furnace Static Pressure (8/23/13)</i>	<b>29</b>
<i>12) Reverb Furnace Static Pressure (9/20/13)</i>	<b>30</b>
<b>CALCULATIONS</b>	<b>31</b>
<b>APPENDICES</b>	<b>46</b>
<i>Appendix A: Field Data</i>	<b>47</b>
<i>Appendix B: Process Data</i>	<b>64</b>
<i>Appendix C: Calibration Records</i>	<b>117</b>
<i>Appendix D: District Laboratory Data</i>	<b>133</b>

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-4-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SUMMARY

- a. Firm ..... Exide Technologies
- b. Test Location ..... 2700 S. Indiana St., Vernon, CA 90023
- c. Unit Tested ..... Soft Lead Baghouse (Dev. ID C47)  
Hard Lead Baghouse (Device ID C46)
- d. Test Requested by ..... Barry Wallerstein, D. Env; Executive Officer  
(909) 396-3131
- e. Reason for Test Request..... Simultaneous sampling of multiple  
metal and toxic organic emission rates
- f. Dates of Test ..... August 8, 2013,  
August 23, 2013, and September 20, 2013
- g. Source Test Performed by..... M. Garibay, R. Lem, C. Willoughby  
E. Padilla, W. Stredwick, J. Aspell
- h. Test Arrangements Made  
Through..... Ed Mopas (Environmental Manager)  
Exide Technologies (323) 262-1101 x 259
- i. Source Test Observed by ..... Michal Haynes, AQ Inspector III (909) 396-2369
- j. Company I.D. No. .... 124838
- k. Permit No. .... RECLAIM/Title V Facility Permit
- l. Application Nos. .... 501060, 374234

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-5-

Date(s): 8/8/13, 8/23/13 and 9/20/13

### **EXECUTIVE SUMMARY**

In March 2013, the South Coast Air Quality Management District (SCAQMD) approved the Health Risk Assessment for the Exide Technologies facility in Vernon that was submitted to meet the requirements of Assembly Bill (AB) 2588 and SCAQMD Rule 1402. In response to the high levels of toxic air contaminants (TAC) reported, modifications were made to equipment at the facility in an attempt to mitigate the toxic emissions. Specifically, an isolation door was installed on the feed chute of the Blast Furnace to keep the Blast Furnace closed during times when material is not being charged to the furnace. This was designed to direct emissions to the Afterburner and Neptune Scrubber control system, instead of routing the emissions to the Hard Lead Baghouse, which is not designed to properly control emissions from the Blast Furnace feed chute. Prior to installation of the Isolation Door, arsenic emissions from the Hard Lead Baghouse contributed approximately 90% of the facility's health risk. In addition, 1,3-butadiene emissions, a toxic organic compound, from the same exhaust stack contributed 4% of the facility's risk.

Early screening source tests were performed on the Hard Lead Baghouse. Testing was performed for multiple metals (including lead and arsenic) and toxic organic emissions while the facility's Blast Furnace, Reveratory (Reverb) Furnace and Refining Kettles were in operation. At the time of early screening testing, the facility was not capable of full-scale production. This current testing was conducted under more representative conditions of the facility's full production capacity. These tests are considered more comprehensive because the Hard and Soft Lead exhaust stacks were sampled simultaneously. In addition, for one of the test runs, the North and South Torit Filter exhaust stacks were included in the simultaneous sampling. The Torit stacks were included because of observations during the earlier test runs of visible emissions released by the furnaces inside of the building. The air within the building is designed to be collected and controlled by the Torit Filter system.

Some improvements continue to be observed with the installation and operation of the Blast Furnace Isolation Door. Overall, the door has reduced the amount of emissions released directly from the feed chute into the Hard Lead Baghouse collection vents. However, the Isolation Door should not be considered as the definitive solution to prevent excessive arsenic and toxic organic emissions from the Blast Furnace. A correlation has been established through this testing that the emissions from the Blast Furnace, both fugitives into the building and at the Hard Lead exhaust stack, are dependent on the pressure inside the Blast Furnace. Greater positive pressures have resulted in higher arsenic emissions and visible fugitive emissions. The pressure has been monitored continuously inside both furnaces since early August 2013, and a relationship between increased fugitive emissions and furnace pressures has been established through this test program, monitoring and limitations for the pressure are recommended for the purposes of minimizing arsenic emissions.

There is no confidence that the emissions presented in this report can be maintained in the future during normal operations at Exide. This is due to the variable nature of the furnace operations and the insufficient capacity of the air pollution control equipment to maintain negative pressure in the Blast Furnace. Records have shown greater pressure spikes and greater average pressures during non-test periods, which most likely resulted in greater emissions than the measured emissions.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-6-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**RESULTS**

**Table 1. Summary of Mass Emission Rates for Contaminants of Concern**

<b>Lead</b>	Run No. 1 8/8/13	Run No. 2 8/23/13	Run No. 3 9/20/13	Test Average	2010 HRA Test Average	2012 HRA Test Average
	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr
Hard Lead Baghouse	$2.23 \times 10^{-2}$	$5.45 \times 10^{-3}$	$2.14 \times 10^{-2}$	$1.64 \times 10^{-2}$ *	$1.02 \times 10^{-3}$	$1.80 \times 10^{-3}$
Soft Lead Baghouse	N/A	$4.97 \times 10^{-3}$	$1.54 \times 10^{-2}$	$1.02 \times 10^{-2}$ #	$8.51 \times 10^{-4}$	N/A

\* Exceeds SCAQMD Rule 1420.1 limit of 0.01 lb lead per hour.

# Within allowable 10% margin of error of Rule 1420.1 emission limit.

<b>Arsenic</b>	Run No. 1 8/8/13	Run No. 2 8/23/13	Run No. 3 9/20/13	Test Average	2010 HRA Test Average	2012 HRA Test Average
	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr
Hard Lead Baghouse	$7.31 \times 10^{-4}$	$1.61 \times 10^{-3}$	$1.02 \times 10^{-3}$	$1.12 \times 10^{-3}$	$7.59 \times 10^{-2}$	$2.12 \times 10^{-2}$
Soft Lead Baghouse	N/A	$8.36 \times 10^{-6}$	$8.82 \times 10^{-5}$	$4.83 \times 10^{-5}$	$1.00 \times 10^{-4}$	N/A

<b>1,3- Butadiene</b>	Run No. 1 8/23/13	Run No. 2 8/23/13	Run No. 3 9/20/13	Test Average	2011 HRA Test Average	2012 HRA Test Average
	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr
Hard Lead Baghouse	$2.97 \times 10^{-2}$	$2.48 \times 10^{-2}$	$1.85 \times 10^{-2}$	$2.43 \times 10^{-2}$	$3.45 \times 10^{-1}$	$1.50 \times 10^{-1}$
Soft Lead Baghouse	$2.95 \times 10^{-3}$	$5.37 \times 10^{-4}$	$1.22 \times 10^{-2}$	$5.23 \times 10^{-3}$	$9.77 \times 10^{-2}$	N/A

<b>Benzene</b>	Run No. 1 8/23/13	Run No. 2 8/23/13	Run No. 3 9/20/13	Test Average	2010 HRA Test Average	2012 HRA Test Average
	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr
Hard Lead Baghouse	$1.46 \times 10^{-1}$	$1.27 \times 10^{-1}$	$8.41 \times 10^{-2}$	$1.19 \times 10^{-1}$	1.41	$5.30 \times 10^{-1}$
Soft Lead Baghouse	$4.94 \times 10^{-2}$	$2.08 \times 10^{-2}$	$1.64 \times 10^{-1}$	$7.81 \times 10^{-2}$	$6.19 \times 10^{-2}$	N/A

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-7-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**Table 2. Summary of Test Production Rates**

		Run No. 1	Run No. 2	Run No. 3
<b>Date</b>		8/8/13	8/23/13	9/20/13
<b>Time</b>	HH:MM	11:10 – 13:45	09:11 - 13:21	9:03 - 13:15
<b>Sampling time</b>	min	120	240	240
<b>Charge Rate During Sampling*</b>				
Blast Furnace	ton/hr	5.31	7.24	5.79
Reverb Furnace	ton/hr	6.3	13.6	13.0
<b>Percent of Permitted Limit During Sampling#</b>				
Blast Furnace	%	71.4	97.5	77.9
Reverb Furnace	%	34.6	74.3	71.0
<b>Overall Charge (Day and Night Shift)</b>				
Blast Furnace	tons	113.5	154	134.2
Reverb Furnace	tons	263	282	172
<b>Overall Percent of Permitted Limit (Day and Night Shift)</b>				
Blast Furnace	%	66.0	86.4	75.3
Reverb Furnace	%	59.9	64.2	39.2
<b>Kettle Arsenic Additions</b>	lb	0	55	0
<b>Time of Arsenic Addition</b>	HH:MM	N/A	11:45	N/A

\* Charge rate based on material charged during test period.

# Test period charge rate extrapolated to 24 hours divided by daily permit limit of equipment.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-8-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**Table 3. Summary of Test Operating Parameters**

		Run No. 1	Run No. 2	Run No. 3	Average
Date		8/8/13	8/23/13	9/20/13	
<b>EXHAUST FLOW RATES</b>					
Hard Lead Baghouse	acfm	106,000	105,800	112,200	108,000
	dscfm	93,000	92,700	98,700	94,800
Soft Lead Baghouse	acfm	*	89,000	95,900	92,500
	dscfm	*	78,300	83,400	80,900
Neptune/Venturi Scrubber (from CEMS)	dscfm	22,700	23,000	21,000	22,200
<b>BLAST FURNACE</b>					
Blast Furnace Static Pressure					
Maximum	“ H <sub>2</sub> O	#	+0.59	+0.24	
Minimum	“ H <sub>2</sub> O		-0.07	-0.021	
Average	“ H <sub>2</sub> O		+0.18	+0.06	
Blast Baghouse Temperature	°F	412	434	440	
Blast Baghouse Dilution Air Damper Position		CLOSED	CLOSED	OPEN	
<b>REVERB FURNACE</b>					
Reverb Furnace Static Pressure					
Maximum	“ H <sub>2</sub> O	#	+0.46	+0.69	
Minimum	“ H <sub>2</sub> O		+0.10	+0.41	
Average	“ H <sub>2</sub> O		+0.32	+0.50	

\* Sampling was not conducted on Soft Lead Baghouse on 8/8/13

# Pressure gauges not operational on furnaces until 8/14/13



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-9-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**Table 4. Air Pollution Control Device Differential Pressures (inches H<sub>2</sub>O)**

		Baghouse Cell No.									
Control Device	Run	1	2	3	4	5	6	7	8	9	10
<b>Reverb Baghouse</b>	1	Cells 1-5 not used					-1.0	-0.5	-1.5	-1.25	-1.0
	2						-1.25	-1.0	-2.25	-1.5	-1.0
	3						-2.0	-1.75	-2.0	-1.5	-1.0
<b>Soft Lead Baghouse</b>	1*	-2.0	-2.0	-2.75	-2.75	-4.0	-2.0	-2.0	-3.75	-	-
	2	-2.0	-2.0	-3.5	-3.0	-3.25	-1.75	-1.75	-3.0	-	-
	3	-2.0	-2.0	-3.5	-3.25	2.75	-1.5	-2.0	-3.0	-	-
<b>Blast Baghouse</b>	1	-0.25	-0.75	0	-1.0	-1.0	-	-	-	-	-
	2	-0.5	-0.75	-0.25	-1.0	-1.0	-	-	-	-	-
	3	-0.5	-1.0	0	-1.0	-1.25	-	-	-	-	-
<b>Hard Lead Baghouse</b>	1	*	-1.25	-6.5	-2.5	-3.75	-3.75	-6.25	-2.0	-	-
	2	-4.5	-1.0	-6.5	-6.5	-5.5	-3.0	-3.0	-2.0	-	-
	3	-4.0	-0.5	-5.5	-6.0	-4.5	-2.5	-2.5	-2.0	-	-
<b>Venturi/ Neptune Scrubber#</b>	1	<b>32</b>	-	-	-	-	-	-	-	-	-
	2	<b>34</b>	-	-	-	-	-	-	-	-	-
	3	<b>32</b>	-	-	-	-	-	-	-	-	-

\* Some readings were unreadable due to clouded gauges. Gauges were replaced after first run.

# The Venturi/Neptune Scrubber has a permit limit of a minimum of 36 inches of H<sub>2</sub>O when both the Reverb and Blast Furnaces are in operation. The other control devices listed in this table do not have differential pressure permit limits (but are required to have triboelectric broken bag sensors). Both furnaces were in operation during these readings.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-10-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**Table 5. Summary of Test Results for Metal Emissions from Hard Lead Baghouse**

**HARD LEAD BAGHOUSE**

	Run No. 1	Run No. 2	Run No. 3	Average
	8/8/13	8/23/13	9/20/13	
	lb/hr	lb/hr	lb/hr	lb/hr
Lead	<b><math>2.23 \times 10^{-2}</math></b>	$5.45 \times 10^{-3}$	<b><math>2.14 \times 10^{-2}</math></b>	<b><math>1.64 \times 10^{-2}</math>*</b>
Arsenic	$7.31 \times 10^{-4}$	$1.61 \times 10^{-3}$	$1.02 \times 10^{-3}$	$1.12 \times 10^{-3}$
Cadmium	$2.87 \times 10^{-4}$	$3.51 \times 10^{-5}$	$8.71 \times 10^{-5}$	$1.36 \times 10^{-4}$
Manganese	$3.03 \times 10^{-4}$	$1.79 \times 10^{-4}$	$3.19 \times 10^{-5}$	$1.71 \times 10^{-4}$
Nickel	$3.98 \times 10^{-4}$	$4.61 \times 10^{-5}$	$5.81 \times 10^{-5}$	$1.67 \times 10^{-4}$
Chromium	$1.75 \times 10^{-4}$	$5.70 \times 10^{-5}$	$7.18 \times 10^{-5}$	$1.01 \times 10^{-4}$
Antimony	$1.06 \times 10^{-4}$	$3.51 \times 10^{-5}$	$1.04 \times 10^{-4}$	$8.15 \times 10^{-5}$
Selenium	$4.68 \times 10^{-5}$	$1.56 \times 10^{-4}$	$1.96 \times 10^{-5}$	$7.40 \times 10^{-5}$
Barium	$7.99 \times 10^{-4}$	$1.45 \times 10^{-4}$	$2.70 \times 10^{-4}$	$4.04 \times 10^{-4}$
Zinc	$8.77 \times 10^{-3}$	$5.08 \times 10^{-4}$	$6.38 \times 10^{-4}$	$3.31 \times 10^{-3}$
Tin <sup>#</sup>	$1.22 \times 10^{-3}$	$3.52 \times 10^{-2}$	$5.72 \times 10^{-2}$	$3.12 \times 10^{-2}$
Titanium	$2.34 \times 10^{-4}$	$1.97 \times 10^{-4}$	$1.58 \times 10^{-4}$	$1.96 \times 10^{-4}$
Copper	$2.19 \times 10^{-3}$	$1.16 \times 10^{-4}$	$1.91 \times 10^{-4}$	$8.33 \times 10^{-4}$
Cobalt	$3.09 \times 10^{-5}$	Non-Detect	$2.90 \times 10^{-6}$	$1.13 \times 10^{-5}$
Iron	$1.15 \times 10^{-2}$	$1.07 \times 10^{-3}$	$2.28 \times 10^{-3}$	$4.96 \times 10^{-3}$

\* Exceeds SCAQMD Rule 1420.1 limit of 0.01 lb lead per hour.

# Tin is present in the hydrogen peroxide impinger solution as a stabilizer.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-11-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**Table 6. Summary of Test Results for Metal Emissions from Soft Lead Baghouse\***

**SOFT LEAD BAGHOUSE**

	Run No. 1	Run No. 2	Average
	8/23/13	9/20/13	
	lb/hr	lb/hr	lb/hr
Lead	$4.97 \times 10^{-3}$	$1.54 \times 10^{-2}$	$1.02 \times 10^{-2\#}$
Arsenic	$8.36 \times 10^{-6}$	$8.82 \times 10^{-5}$	$4.83 \times 10^{-5}$
Cadmium	$4.60 \times 10^{-5}$	$1.38 \times 10^{-4}$	$9.20 \times 10^{-5}$
Manganese	$1.59 \times 10^{-4}$	$8.24 \times 10^{-5}$	$1.21 \times 10^{-4}$
Nickel	$4.72 \times 10^{-5}$	$8.60 \times 10^{-5}$	$6.66 \times 10^{-5}$
Chromium	$7.23 \times 10^{-5}$	$1.03 \times 10^{-4}$	$8.76 \times 10^{-5}$
Antimony	$3.29 \times 10^{-5}$	$1.05 \times 10^{-4}$	$6.90 \times 10^{-5}$
Selenium	Non-Detect	$2.57 \times 10^{-5}$	$1.29 \times 10^{-5}$
Barium	$1.26 \times 10^{-4}$	$2.38 \times 10^{-4}$	$1.82 \times 10^{-4}$
Zinc	$8.94 \times 10^{-4}$	$2.56 \times 10^{-3}$	$1.73 \times 10^{-3}$
Tin <sup>+</sup>	$3.04 \times 10^{-2}$	$5.67 \times 10^{-2}$	$4.35 \times 10^{-2}$
Titanium	$1.85 \times 10^{-4}$	$3.05 \times 10^{-4}$	$2.45 \times 10^{-4}$
Copper	$2.17 \times 10^{-4}$	$3.01 \times 10^{-4}$	$2.59 \times 10^{-4}$
Cobalt	Non-Detect	$7.35 \times 10^{-6}$	$3.68 \times 10^{-6}$
Iron	$2.86 \times 10^{-2}$	$6.06 \times 10^{-3}$	$1.73 \times 10^{-2}$
Beryllium	Non-Detect	$2.94 \times 10^{-7}$	$1.47 \times 10^{-7}$

\*Only two runs were conducted on the Soft Lead Baghouse Exhaust Stack. SCAQMD Rule 1420.1 requires triplicate runs for compliance.

# Average lead emissions are within the allowable 10% margin of error of the Rule 1420.1 compliance limit of 0.01 lb lead per hour.

+ Tin is present in the hydrogen peroxide impinger solution as a stabilizer.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-12-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**Table 7. Summary of Toxic Organic Emissions from Hard Lead Baghouse**

**HARD LEAD BAGHOUSE**

Compound	Run No. 1	Run No. 2	Run No. 3	Average
	8/23/13	8/23/13	9/20/13	
	lb/hr	lb/hr	lb/hr	
1,3-butadiene	$2.97 \times 10^{-2}$	$2.48 \times 10^{-2}$	$1.85 \times 10^{-2}$	$2.43 \times 10^{-2}$
benzene	$1.46 \times 10^{-1}$	$1.27 \times 10^{-1}$	$8.41 \times 10^{-2}$	$1.19 \times 10^{-1}$
acrolein	$1.64 \times 10^{-3}$	$1.97 \times 10^{-3}$	$2.63 \times 10^{-3}$	$2.08 \times 10^{-3}$
methylene chloride	$6.23 \times 10^{-4}$	$7.48 \times 10^{-4}$	$3.98 \times 10^{-4}$	$5.89 \times 10^{-4}$
MEK	$1.80 \times 10^{-3}$	$1.69 \times 10^{-3}$	$1.69 \times 10^{-3}$	$1.73 \times 10^{-3}$
chloroform	$7.00 \times 10^{-4}$	$5.25 \times 10^{-4}$	$3.73 \times 10^{-4}$	$5.33 \times 10^{-4}$
toluene	$3.43 \times 10^{-2}$	$2.97 \times 10^{-2}$	$2.68 \times 10^{-2}$	$3.03 \times 10^{-2}$
ethylbenzene	$8.72 \times 10^{-3}$	$7.01 \times 10^{-3}$	$3.81 \times 10^{-3}$	$6.51 \times 10^{-3}$
m+p xylenes	$1.56 \times 10^{-2}$	$9.81 \times 10^{-3}$	$6.63 \times 10^{-3}$	$1.07 \times 10^{-2}$
styrene	$1.59 \times 10^{-1}$	$1.20 \times 10^{-1}$	$5.42 \times 10^{-2}$	$1.11 \times 10^{-1}$
o-xylene	$4.52 \times 10^{-3}$	$2.65 \times 10^{-3}$	$3.32 \times 10^{-3}$	$3.49 \times 10^{-3}$
n-hexane	$4.42 \times 10^{-3}$	$5.18 \times 10^{-3}$	$2.02 \times 10^{-3}$	$3.88 \times 10^{-3}$
propylene	$1.20 \times 10^{-1}$	$9.57 \times 10^{-2}$	$9.01 \times 10^{-2}$	$1.02 \times 10^{-1}$
tetrachloroethylene	Non-Detect	Non-Detect	$2.59 \times 10^{-4}$	$8.64 \times 10^{-5}$
carbon tetrachloride	Non-Detect	Non-Detect	$2.40 \times 10^{-4}$	$8.01 \times 10^{-5}$

NOTE: Table only lists compounds identified as SCAQMD Rule 1401 Toxic Air Contaminants. Other non-toxic compounds detected in analysis are listed in Calculations section of this report.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-13-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**Table 8. Summary of Toxic Organic Emissions from Soft Lead Baghouse**

**SOFT LEAD BAGHOUSE**

Compound	Run No. 1	Run No. 2	Run No. 3	Average
	8/23/13	8/23/13	9/20/13	
	lb/hr	lb/hr	lb/hr	lb/hr
1,3-butadiene	$2.95 \times 10^{-3}$	$5.37 \times 10^{-4}$	$1.22 \times 10^{-2}$	$5.23 \times 10^{-3}$
benzene	$4.94 \times 10^{-2}$	$2.08 \times 10^{-2}$	$1.64 \times 10^{-1}$	$7.81 \times 10^{-2}$
acrolein	$7.65 \times 10^{-4}$	$6.26 \times 10^{-4}$	$3.03 \times 10^{-3}$	$1.47 \times 10^{-3}$
methylene chloride	$4.21 \times 10^{-4}$	$5.27 \times 10^{-4}$	Non-Detect	$3.16 \times 10^{-4}$
MEK	$1.52 \times 10^{-3}$	$7.16 \times 10^{-4}$	$9.52 \times 10^{-4}$	$1.06 \times 10^{-3}$
chloroform	$5.92 \times 10^{-4}$	$2.96 \times 10^{-4}$	$1.58 \times 10^{-4}$	$3.49 \times 10^{-4}$
toluene	$8.91 \times 10^{-3}$	$4.34 \times 10^{-3}$	$3.27 \times 10^{-2}$	$1.53 \times 10^{-2}$
ethylbenzene	$3.82 \times 10^{-3}$	$2.63 \times 10^{-3}$	$2.66 \times 10^{-3}$	$3.04 \times 10^{-3}$
m+p xylenes	$1.55 \times 10^{-2}$	$1.05 \times 10^{-2}$	$1.40 \times 10^{-2}$	$1.34 \times 10^{-2}$
styrene	$1.81 \times 10^{-3}$	$3.87 \times 10^{-4}$	$3.01 \times 10^{-2}$	$1.08 \times 10^{-2}$
o-xylene	$4.35 \times 10^{-3}$	$2.50 \times 10^{-3}$	$2.66 \times 10^{-3}$	$3.17 \times 10^{-3}$
n-hexane	$5.34 \times 10^{-4}$	$4.28 \times 10^{-4}$	$9.10 \times 10^{-4}$	$6.24 \times 10^{-4}$
propylene	$1.07 \times 10^{-2}$	$6.68 \times 10^{-3}$	$1.06 \times 10^{-1}$	$4.10 \times 10^{-2}$
carbon tetrachloride	Non-Detect	Non-Detect	$2.03 \times 10^{-4}$	$6.77 \times 10^{-5}$

NOTE: Table only lists compounds identified as SCAQMD Rule 1401 Toxic Air Contaminants. Other non-toxic compounds detected in analysis are listed in Calculations section of this report.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-14-

Date(s): 8/8/13, 8/23/13 and 9/20/13

## **INTRODUCTION**

On August 8 and 23, and September 20, 2013, engineers from the SCAQMD conducted source tests for multiple metal and toxic organic emissions from the Hard Lead Baghouse and Soft Lead Baghouse exhaust stacks at Exide Technologies in Vernon. A series of tests has been performed in response to high levels of toxic air contaminants (arsenic in particular) from the Hard Lead Baghouse that were detected during previous source tests used to determine the facility-wide health risk. These tests were performed in addition to an earlier screening source test program. During the initial runs for this test and previous testing, fugitive emissions from the Reverb and Blast Furnaces were observed to be vented into the building enclosing these processes. Because the North and South Torit exhaust stacks ventilate the building air to cartridge and HEPA filters, a simultaneous one-run test was conducted on these two additional stacks during the testing on September 20. Almega Environmental was contracted to perform the additional testing on the Torit exhaust stacks, and the results will be reported separately by Almega.

## **EQUIPMENT AND PROCESS DESCRIPTION**

Exide Technologies is a Cycle 1 RECLAIM facility for NO<sub>x</sub> and SO<sub>x</sub>, and is in the Title V permitting program. The facility operates a secondary lead smelting process to recover lead from recycled automotive batteries.

The facility receives lead-acid batteries from off-site collection facilities and breaks them down in the Raw Material Preparation System (RMPS) using a hammer mill. The components are then drained of acid and separated into metallic lead, polypropylene, rubber and plastic fractions. Emissions from this process are vented to a packed bed scrubber followed by a HEPA filter.

Following the RMPS, the metallic portion is fed to the furnaces for smelting. This consists of two different streams, the Reverb Furnace to process lead acid and battery scrap, and the Blast Furnace to process lead slag and scrap. The emissions from Reverb Feed Hopper are controlled by the MAC Baghouse, and fugitive emissions from the Kiln Dryer are collected by two vents leading to the Hard Lead Baghouse. The Reverb Feed Hopper feeds the 8 MMBTU/hr natural gas-fired Rotary Kiln Dryer. The Kiln Dryer is used to drive off moisture and other contaminants prior to feeding the furnace, which is vented to a baghouse with Teflon-coated bags. The scrap is then fed to the 30 MMBTU/hr natural gas-fired Reverb Furnace. The lead is reduced in the furnace and slag is removed from the bottom to feed the Blast Furnace, while the crude lead is refined further in the soft lead process. The soft lead refined in this process is typically 99.9% pure lead. Emissions from the Reverb Furnace are quenched before entering the Reverb Baghouse, which is followed by the Venturi and Neptune scrubbers. The crude lead removed from the Reverb Furnace is fed into receiving kettles and then refined in four refining kettles. Emissions from this refining process are collected and controlled by the Soft Lead Baghouse. The Soft Lead Baghouse also collects fugitive emissions from the tapping ports on either side of the Reverb Furnace. On the south side of the building, the slag from the Reverb

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-15-

Date(s): 8/8/13, 8/23/13 and 9/20/13

Furnace is fed into the top of a 4 MMBTU/hr coke and natural gas-fired Blast Furnace. Lead removed from this process is further refined into hard lead in refining kettles which are vented by the Hard Lead Baghouse. Emissions from the inside of the Blast Furnace are vented to a 10 MMBTU/hr natural gas-fired afterburner, the Blast Baghouse, and then manifolded with the exhaust from the Reverb Furnace to the Venturi and Neptune Scrubbers. Emissions from the tapping ports on either side of the Blast Furnace are vented to the Hard Lead Baghouse.

The Blast Furnace feed chute, located on top of the Blast Furnace, was recently equipped with an isolation door in March/April 2013 for the purpose of addressing the high arsenic emissions from the Hard Lead Baghouse stack. When the furnace is not being charged, the door remains closed. The feed cart is loaded in the Blast Feed Room and is hoisted with cables to the top of the furnace. As the cart approaches the top of the furnace, it mechanically opens the isolation door and the contents of the cart are unloaded into the furnace. Dust created during the charging is collected by various ducts surrounding the door that vent the emissions to the Hard Lead Baghouse. As the Feed Cart begins its descent back down to the Feed Room, the door closes again. A schematic diagram of this process is located in Figure 1.

## **SAMPLING AND ANALYTICAL PROCEDURES**

Source testing was conducted on the Hard Lead and Soft Lead Baghouse exhaust stacks at Exide Technologies (Figures 2 and 3). Testing consisted of multi-run sampling performed for multiple metals using California Air Resources Board (CARB) Method 436. Fixed gases testing, to determine the molecular weight of the stack gases pursuant to SCAQMD Method 10.1, and toxic organic emissions testing, following U.S. EPA Method TO-15, were both performed using integrated 6-liter summa canister samples.

### **Gas Flow Rate**

The gas velocity was measured during the sampling runs in accordance with SCAQMD Methods 1.1 and 2.1. This was done using an S type Pitot tube (permanently attached to the probe, with the impact opening of the Pitot tube even with the nozzle entry plane) with a differential pressure manometer, and a type "K" thermocouple (also permanently attached to the probe so that the tip of the sensor extended beyond the leading edge of the probe sheath, and touching no metal) with a digital potentiometer (Figure 4). The apparatus was leak checked both before and after use by introducing a pressure head of at least 80 percent of full scale and blocking the flow at the Pitot tip. An observation of the resulting non-diminishing pressure for at least 15 seconds at the manometer verified the absence of leaks in the system.

The access ports on both stacks were greater than five diameters downstream and greater than four stack diameters upstream from any flow disturbances along the vertical exhaust stack. Velocity sampling was performed at 24 traverse points positioned across the ports along the

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-16-

Date(s): 8/8/13, 8/23/13 and 9/20/13

stack diameters. Details regarding traverse point locations and locations of the access ports for the exhaust stacks can be found in Figure 5 of this report.

The volumetric flow rate was calculated from the exhaust stack cross sectional area and average gas velocities. The absence of cyclonic flow conditions was verified during previous source tests. The flow rate was corrected to standard conditions by using the stack temperature and pressure along with the barometric pressure measured with a calibrated aneroid barometer. The flow rates were also corrected to dry conditions using the moisture content as determined by SCAQMD Method 4.1 weight gain from the multiple metals samples described in the following sections.

### **Multiple Metals Sampling and Analysis**

Testing was conducted using CARB Method 436. Each sampling train consisted of a borosilcate probe and nozzle, which was used to draw the stack sample isokinetically from the source. The sample was then drawn through two impingers each filled with an aqueous solution of 5% nitric acid and 10% hydrogen peroxide, an empty impinger, a 2" Teflon-coated glass fiber filter, and an impinger bubbler filled with tared silica gel. Each sampling train was connected to a leak free vacuum pump, a dry gas meter, and a calibrated orifice. The impingers were contained in a dry ice bath to condense water vapor and other condensable matter present in the sample stream (Figures 6 and 7). The method option for two impingers containing an acidic potassium permanganate solution used solely to collect mercury vapor emissions was not used because previous testing did not indicate that mercury emissions were significant. A modification was made by moving the filter prior to the impinger containing the silica gel.

The SCAQMD laboratory analyzed the metals in the samples by EPA Method 200.7. Metals deposited in the filter, probe, nozzle and impingers were acid digested and analyzed by ICP/MS (Inductively Coupled Plasma Mass Spectrometry) by the SCAQMD laboratory. Moisture content was determined gravimetrically and volumetrically.

### **Toxic Organic Compounds Sampling and Analysis**

Testing was conducted using U.S. EPA Method TO-15. The sample was collected continuously from the exhaust stack. The gas sampling apparatus consisted of a stainless steel probe, a Teflon line, and a specially prepared 6-liter summa canister. The equipment is similar to that described in Figure 8 used for Integrated Gas Sampling (SCAQMD Method 10.1) except no rotameter was used. Analysis involves using a high resolution gas chromatograph coupled with a mass spectrometer. Previous testing on similar sources using this method has shown it yields similar results obtained simultaneously with CARB Method 422.



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-17-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**Integrated Gas Sampling and Analysis**

An integrated gas sample was collected continuously from the exhaust stack during each day of testing. The gas sampling apparatus consisted of a stainless steel probe, a Teflon line, and a 6-liter summa canister (Figure 8). The sample was collected at a rate of approximately 0.10 liters per minute controlled by a rotameter.

The samples were analyzed by the SCAQMD laboratory for carbon monoxide, carbon dioxide, and oxygen. The gases were separated by gas chromatography. The carbon dioxide was determined by a gas chromatograph with a nickel catalyzed methanizer and flame ionization detector (GC/Ni-FID). Carbon monoxide was combusted to carbon dioxide and analyzed by SCAQMD Method 25.1. Oxygen was analyzed by thermal conductivity.

**TEST CRITIQUE**

The testing was conducted on a pre-scheduled basis during normal working hours, to gather multiple metal and toxic organics emissions data to monitor emissions from the facility. Sampling commenced on August 8, 2013 on only the Hard Lead Baghouse. The Soft Lead Baghouse was included the testing program on August 23 and September 20 after fugitive emissions from the Reverb Furnace were observed being collected by the Soft Lead Baghouse vents. Similarly, the Torit exhaust stacks were included in the testing after fugitive emissions from both the Reverb and Blast Furnace were observed being collected by those vents. Due to the timing of the observations, multiple metals testing only consisted of two test runs for the Soft Lead Baghouse and one test run for the Torit Filters.

Based upon previous testing for metals on this equipment, it was determined that a 120 minute sampling time would give analytical results above the detection limits for lead, arsenic and other metals. After the first run was completed, the sampling time was increased to 240 minutes due to the variable operation of the furnaces, with respect to charge rates and fugitive emissions.

The average of the triplicate test runs on the Hard Lead Baghouse resulted in an exceedance of the SCAQMD Rule 1420.1 limit of 0.01 lb lead per hour. In addition, the recorded total differential pressure across the Venturi/Neptune Scrubber system did not meet the minimum requirement of 36" H<sub>2</sub>O (Permit Condition C8.7) for each test run.

Pressure gauges were installed on both furnaces for the second and third runs of the test. Continuous pressure readings were provided by Exide after the testing. Periods of high positive pressure in the Blast Furnace were typically accompanied by visible emissions when the Isolation Door was open, and from other places on the Blast Furnace, that were collected by either the Hard Lead Baghouse or the Torit Filter system. In addition, it was observed that pressure spikes greater than 1.0" H<sub>2</sub>O in the Reverb Furnace resulted in visible fugitive

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-18-

Date(s): 8/8/13, 8/23/13 and 9/20/13

emissions being released into the building, which were collected by the Torit Filters. During the test run that included the Torit Filters on September 20, a lesser amount of these fugitive emissions occurrences were observed.


Although periods of both negative and positive pressures were recorded during the test for the Blast Furnace, the average pressures (obtained from one-minute readings) were positive for both furnaces. During periods of negative pressure in the Blast Furnace during the tests, no visible emissions were observed from the Blast Furnace. Conversely, during periods of positive pressure in the Blast Furnace, visible emissions were observed from various seams in the Blast Furnace, as well as during opening and charging to the Isolation Door and feed chute. It should be noted that the highest arsenic emissions from the Hard Lead Baghouse occurred during the test run with the highest Blast Furnace feed rate and the highest average Blast Furnace pressure. Testing included an arsenic addition, and a high temperature antimony addition, to the refining kettles during the second run of testing. Although there was an increase in arsenic emissions measured during this run compared to the next highest arsenic measurement, it is thought that the Blast Furnace pressure has a greater effect on arsenic emissions.

Emissions of benzene and 1,3-butadiene from the Hard Lead Baghouse were consistent regardless of feed rate or Blast Furnace pressure. Emissions for lead, arsenic, 1,3-butadiene and benzene from the Soft Lead Baghouse were all higher during the third run, which experienced the highest Reverb Furnace pressure of all three of the test runs. The emission rates of these four compounds from the Soft Lead Baghouse are still much less than the emission rates from the Hard Lead Baghouse from the 2010 and 2012 Health Risk Assessment tests. Charts of the Reverb and Blast Furnaces Pressures from the test days are located in Figures 9 through 12.

1,3-butadiene emissions are typically tested in accordance with CARB Method 422.102. For this testing program, EPA Method TO-15 was used to measure 1,3-butadiene emissions as a screening tool. However, based on previous testing Method TO-15 is expected to yield similar and accurate results as compared to Method 422.102.

The Blast Baghouse is equipped with a dilution air damper to cool the flue gas prior to the baghouse. This damper is automatically controlled and was observed to be open during the test on September 20. The air flow into the duct was not quantified. Future testing for NESHAP Subpart X compliance should include a quantification of the dilution air to verify compliance with the concentration limit.

### Exide Blast/Cupola Furnace




**Figure 1: Blast Furnace Feed and Exhaust Schematic Diagram**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-20-

Date(s): 8/8/13, 8/23/13 and 9/20/13




**Figure 2: Hard Lead Baghouse Exhaust Stack**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765


Test No. 13-307 and 13-308

-21-

Date(s): 8/8/13, 8/23/13 and 9/20/13



**Figure 3: Soft Lead Baghouse Exhaust Stack**



**Figure 4: SCAQMD Methods 1.1 and 2.1**


SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-23-

Date(s): 8/8/13, 8/23/13 and 9/20/13

Stack Orientation: Vertical, Circular



Traverse Point Number	Distance from inner stack wall (in.)
1, 7, 13, 19	28.45
2, 8, 14, 20	20.00
3, 9, 15, 21	14.18
4, 10, 16, 22	9.45
5, 11, 17, 23	5.36
6, 12, 18, 24	1.70


**Figure 5: Hard Lead and Soft Lead Baghouses Stack Diagram and Sampling Locations**  
(Both exhaust stacks are identical in dimensions)

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test No. 13-307 and 13-308

-24-

Date(s): 8/8/13, 8/23/13 and 9/20/13



**Figure 6: CARB Method 436 Sampling Train Diagram**  
(Modified by moving filter before the fourth impinger)



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765


Test No. 13-307 and 13-308

-25-


Date(s): 8/8/13, 8/23/13 and 9/20/13




**Figure 7: CARB Method 436 Field Sampling Train and Probe**




**Figure 8: SCAQMD Method 10.1**




**Figure 9: Blast Furnace Static Pressure (8/23/13)**



**Figure 10: Blast Furnace Static Pressure (9/20/13)**



**Figure 11: Reverb Furnace Static Pressure (8/23/13)**



**Figure 12: Reverb Furnace Static Pressure (9/20/13)**

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
**21865 Copley Drive, Diamond Bar, California 91765**

Test Nos. 13-307 and 13-308

-31-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**CALCULATIONS**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
 21865 E. Copley Dr. Diamond Bar, California 91765-4182

Test No. 1

Test Date: 8/8/13

SOURCE TEST CALCULATIONS

Sampling Location: Exide Hard Lead Baghouse Exhaust  
 Sample Train: 10

Input by: J. Aspell

SUMMARY

A. Average Traverse Velocity.....	32.54	fps
B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters).....	83.1875	deg F
C. Gas Meter Correction Factor.....	1.0085	
D. Average Orifice Pressure.....	0.65	"H <sub>2</sub> O
E. Nozzle Diameter.....	0.1700	inch
F1. Stack Diameter or Dimension #1.....	80	inch
F2. Stack Dim #2 (blank if circular).....		inch
G. Stack Cross Sect. Area.....	34.907	ft <sup>2</sup>
H. Average Stack Temp.....	118.8	deg F
I. Barometric Pressure.....	30.01	"HgA
J. Gas Meter Pressure (I+(D/13.6))....	30.06	"HgA
K. Static Pressure.....	-0.60	"H <sub>2</sub> O
L. Total Stack Pressure (I+(K/13.6))....	29.97	"HgA
M. Pitot Correction Factor.....	0.84	
N. Sampling Time.....	120	min
O. Nozzle X-Sect. Area.....	0.00016	ft
P. Net Sample Collection.....	0	mg
Q. Net Solid Collection.....	0	mg
R. Water Vapor Condensed.....	16	ml
S. Gas Volume Metered.....	46.847	dcf
T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C].....	45.436	dscf

PERCENT MOISTURE/GAS DENSITY

U. Percent Water Vapor in Gas Sample ((4.64 x R)/((0.0464 x R) + T))..... 1.61 %

V. Average Molecular Weight (Wet):

Component	Vol. Fract.	x	Moist. Fract.	x	Molecular Wt.	=	Wt./Mole
Water	0.016		1.000		18.0	,	0.29
Carbon Dioxide	0.000	Dry Basis	0.984		44.0	,	0.01
Carbon Monoxide	0.000	Dry Basis	0.984		28.0	,	0.00
Oxygen	0.208	Dry Basis	0.984		32.0	,	6.55
Nitrogen & Inerts	0.792	Dry Basis	0.984		28.2	,	21.97
					Sum		28.82

FLOW RATE

W. Gas Density Correction Factor (28.95/V)<sup>0.5</sup>..... 1.00  
 X. Velocity Pressure Correction Factor (29.92/L)<sup>0.5</sup>..... 1.00  
 Y. Corrected Velocity\* (A x M x W x X)..... 50.61 fps  
 Z. Flow Rate\* (Y x G x 60)..... 106008 cfm  
 AA. Flow Rate (Standard)\* {Z x (L/29.92) x [520/(460+H)]}..... 94549 scfm  
 BB. Dry Flow Rate\* (AA x (U/100))..... 93029 dscfm

\* Values taken from velocity traverse conducted immediately after sampling because of blocked pitot tube

SAMPLE CONCENTRATION/EMISSION RATE

	Arsenic	Cadmium	Chromium	Lead	Manganese	Nickel	Antimony
Net Sample (mg)	0.0027	0.00106	0.000646	0.0823	0.00112	0.00147	0.00039
Sample Conc. (gr/dscf)	9.17E-07	3.60E-07	2.19E-07	2.79E-05	3.80E-07	4.99E-07	1.32E-07
Mass Emission (lb/hr)	7.31E-04	2.87E-04	1.75E-04	2.23E-02	3.03E-04	3.98E-04	1.06E-04
Emission Conc. (ug/dscf)	0.059415	0.023326	0.014216	1.811051	0.024646	0.032348	0.008582
Emission Conc. (ug/dscm)	2.097936	0.823634	0.501951	63.94821	0.870255	1.14221	0.303035

	Barium	Zinc	Selenium	Tin	Titanium	Copper	Cobalt	Iron
Net Sample (mg)	0.00295	0.0324	0.000173	0.00451	0.000863	0.008099	0.000114	0.04254
Sample Conc. (gr/dscf)	1.00E-06	1.10E-05	5.88E-08	1.53E-06	2.93E-07	2.75E-06	3.87E-08	1.44E-05
Mass Emission (lb/hr)	7.99E-04	8.77E-03	4.68E-05	1.22E-03	2.34E-04	2.19E-03	3.09E-05	1.15E-02
Emission Conc. (ug/dscf)	0.064916	0.712978	0.003807	0.099245	0.018991	0.178222	0.002509	0.936113
Emission Conc. (ug/dscm)	2.29219	25.17524	0.134423	3.504331	0.670563	6.293032	0.08858	33.05415

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-32-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 E. Copley Dr. Diamond Bar, California 91765-4182

Test No. 2

Test Date: 8/8/13

SOURCE TEST CALCULATIONS

Sampling Location: Exide Hard Lead Baghouse Velocity Traverse  
Sample Train: N/A

Input by: J. Aspell

SUMMARY

A. Average Traverse Velocity..... 60.28 fps  
 B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters)..... 83.1875 deg F  
 C. Gas Meter Correction Factor..... 1.0085  
 D. Average Orifice Pressure..... 0.65 "H<sub>2</sub>O  
 E. Nozzle Diameter..... 0.1700 inch

F1. Stack Diameter or Dimension #1..	80	inch	M. Pitot Correction Factor.....	0.84	
F2. Stack Dim #2 (blank if circular).....		inch	N. Sampling Time.....	120	min
G. Stack Cross Sect. Area.....	34.907	ft <sup>2</sup>	O. Nozzle X-Sect. Area.....	0.00016	ft
H. Average Stack Temp.....	123.9	deg F	P. Net Sample Collection.....	0	mg
I. Barometric Pressure.....	30.01	"HgA	Q. Net Solid Collection.....	0	mg
J. Gas Meter Pressure (I+(D/13.6))...	30.06	"HgA	R. Water Vapor Condensed.....	16	ml
K. Static Pressure.....	-0.60	"H <sub>2</sub> O	S. Gas Volume Metered.....	46.847	dscf
L. Total Stack Pressure (I+(K/13.6))...	29.97	"HgA			

T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C]..... 45.436 dscf

PERCENT MOISTURE/GAS DENSITY

U. Percent Water Vapor in Gas Sample ((4.64 x R)/((0.0464 x R) + T))..... 1.61 %

V. Average Molecular Weight (Wet):

Component	Vol. Fract.	x	Moist. Fract.	x	Molecular Wt.	=	Wt./Mole
Water	0.016		1.000		18.0	,	0.29
Carbon Dioxide	0.000	Dry Basis	0.984		44.0	,	0.01
Carbon Monoxide	0.000	Dry Basis	0.984		28.0	,	0.00
Oxygen	0.208	Dry Basis	0.984		32.0	,	6.55
Nitrogen & Inerts	0.792	Dry Basis	0.984		28.2	,	21.97
					Sum		28.82

FLOW RATE

W. Gas Density Correction Factor (28.95/V)<sup>.5</sup>..... 1.00  
 X. Velocity Pressure Correction Factor (29.92/L)<sup>.5</sup>..... 1.00  
 Y. Corrected Velocity (A x M x W x X)..... 50.71 fps  
 Z. Flow Rate (Y x G x 60)..... 106213 cfm  
 AA. Flow Rate (Standard) {Z x (L/29.92) x [520/(460+H)]}..... 94732 scfm  
 BB. Dry Flow Rate (AA x (U/100))..... 93209 dscfm

SAMPLE CONCENTRATION/EMISSION RATE

CC. Sample Concentration [0.01543 x (P/T)]..... 0.00000 gr/dscf  
 DD. Sample Concentration [54,143xC (Molecular Wt.)]..... #DIV/0! ppm  
 EE. Sample Emission Rate (0.00857 x BB x CC)..... 0.000 lb/hr  
 FF. Solid Emission Rate [(0.0001322 x Q x BB)/T]..... 0.000 lb/hr  
 GG. Isokinetic Sampling Rate [(G x T x 100)/(N x O x BB)]..... 90.0 %



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-33-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

Run No. 1											
Traverse Point #	Velocity Head #1	Temp.	Calculated Velocity	Traverse Point #	Gas Meter Temp	Gas Meter Temp	Average Gas Meter	Traverse Point #	Orifice Pressure		
	("H <sub>2</sub> O)	(°F)	(fps)		In (°F)	Out (°F)	Temp (°F)		(" H <sub>2</sub> O)		
1	0.03	114	12.03	1	79	78	78.50	1	0.07		
2	0.02	115	9.83	2	78	80	79.00	2	0.04		
3	0.02	117	9.85	3	80	79	79.50	3	0.04		
4	0.02	115	9.83	4	81	78	79.50	4	0.04		
5	0.11	117	23.10	5	81	79	80.00	5	0.24		
6	0.10	117	22.03	6	81	79	80.00	6	0.22		
7	0.05	116	15.56	7	82	80	81.00	7	0.11		
8	0.09	121	20.97	8	82	80	81.00	8	0.2		
9	0.12	119	24.17	9	83	81	82.00	9	0.26		
10	0.08	119	19.74	10	83	81	82.00	10	0.18		
11	0.11	119	23.14	11	84	81	82.50	11	0.24		
12	0.07	119	18.46	12	85	82	83.50	12	0.15		
13	0.14	118	26.09	13	85	83	84.00	13	0.31		
14	0.16	118	27.89	14	85	83	84.00	14	0.35		
15	0.14	119	26.11	15	86	83	84.50	15	0.31		
16	0.14	122	26.18	16	86	84	85.00	16	0.31		
17	0.80	120	62.47	17	86	85	85.50	17	1.78		
18	0.70	120	58.43	18	86	84	85.00	18	1.55		
19	0.57	121	52.77	19	84	84	84.00	19	1.26		
20	0.83	121	63.68	20	86	84	85.00	20	1.84		
21	0.80	122	62.58	21	89	85	87.00	21	1.78		
22	0.72	121	59.31	22	90	85	87.50	22	1.61		
23	0.64	121	55.92	23	90	86	88.00	23	1.43		
24	0.53	121	50.89	24	91	86	88.50	24	1.19		
Average Temperature (°F) -			118.833	Average Velocity (fps) -			32.54				
Avg Gas Meter Temperature (°F)			83.1875	Average Orifice Press. ("H <sub>2</sub> O) -			0.65				

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-34-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

Velocity Traverse											
Traverse Point #	Velocity Head #1 ("H <sub>2</sub> O)	Temp. (°F)	Calculated Velocity (fps)	Traverse Point #	Gas Meter Temp In (°F)	Gas Meter Temp Out (°F)	Average Gas Meter Temp (°F)	Traverse Point #	Orifice Pressure (" H <sub>2</sub> O)		
1	0.78	125	61.95	1				1			
2	0.74	125	60.34	2				2			
3	0.77	125	61.55	3				3			
4	0.76	125	61.15	4				4			
5	0.80	125	62.74	5				5			
6	0.84	125	64.29	6				6			
7	0.83	124	63.85	7				7			
8	0.87	124	65.37	8				8			
9	0.86	123	64.94	9				9			
10	0.82	122	63.35	10				10			
11	0.70	123	58.58	11				11			
12	0.49	122	48.97	12				12			
13	0.82	124	63.46	13				13			
14	0.84	124	64.23	14				14			
15	0.84	124	64.23	15				15			
16	0.90	125	66.54	16				16			
17	0.85	124	64.61	17				17			
18	0.78	125	61.95	18				18			
19	0.78	124	61.89	19				19			
20	0.73	124	59.88	20				20			
21	0.67	124	57.36	21				21			
22	0.65	124	56.50	22				22			
23	0.58	123	53.33	23				23			
24	0.26	121	35.64	24				24			
Average Temperature (°F) -			123.917	Average Velocity (fps) -			60.28				
Avg Gas Meter Temperature (°F) #DIV/0!				Average Orifice Press. ("H <sub>2</sub> O) -			#DIV/0!				

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
 21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-35-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**CALCULATIONS**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
 21865 Copley Dr. Diamond Bar, California 91765-4182

Test No. 1

Test Date: 8/23/13

-----  
 SOURCE TEST CALCULATIONS  
 -----

Sampling Location: Exide Tech. - Soft Lead Baghouse Exhaust  
 Sample Train: 18 Input by: J. Aspell

SUMMARY

A. Average Traverse Velocity..... 50.45 fps  
 B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters)..... 100.8333 deg F  
 C. Gas Meter Correction Factor..... 1.0021  
 D. Average Orifice Pressure..... 1.85 "H<sub>2</sub>O  
 E. Nozzle Diameter..... 0.2320 inch

F1. Stack Diameter or Dimension #1.... 80 inch  
 F2. Stack Dim #2 (blank if circular)..... inch  
 G. Stack Cross Sect. Area..... 34.907 ft<sup>2</sup>  
 H. Average Stack Temp..... 122.2 deg F  
 I. Barometric Pressure..... 29.87 "HgA  
 J. Gas Meter Pressure (I+(D/13.6))..... 30.01 "HgA  
 K. Static Pressure..... -0.31 "H<sub>2</sub>O  
 L. Total Stack Pressure (I+(K/13.6)).... 29.85 "HgA

M. Pitot Correction Factor..... 0.84  
 N. Sampling Time..... 240 min  
 O. Nozzle X-Sect. Area..... 0.00029 ft<sup>2</sup>  
 P. Net Sample Collection..... mg  
 Q. Net Solid Collection..... mg  
 R. Water Vapor Condensed..... 45.1 ml  
 S. Gas Volume Metered..... 186.098 dcf

T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C]..... 173.406 dscf

PERCENT MOISTURE/GAS DENSITY

U. Percent Water Vapor in Gas Sample ((4.64 x R)/((0.0464 x R) + T))..... 1.19 %

V. Average Molecular Weight (Wet):

Component	Vol. Fract.	x	Moist. Fract.	x	Molecular Wt.	=	Wt./Mole
Water	0.012		1.000		18.0	,	0.21
Carbon Dioxide	0.001 Dry Basis		0.988		44.0	,	0.03
Carbon Monoxide	0.000 Dry Basis		0.988		28.0	,	0.00
Oxygen	0.207 Dry Basis		0.988		32.0	,	6.55
Nitrogen & Inerts	0.792 Dry Basis		0.988		28.2	,	22.07
					Sum		28.87

FLOW RATE

W. Gas Density Correction Factor (28.95/V)<sup>0.5</sup>..... 1.00  
 X. Velocity Pressure Correction Factor (29.92/L)<sup>0.5</sup>..... 1.00  
 Y. Corrected Velocity (A x M x W x X)..... 42.49 fps  
 Z. Flow Rate (Y x G x 60)..... 88987 cfm  
 AA. Flow Rate (Standard) {Z x (L/29.92) x [520/(460+H)]}..... 79291 scfm  
 BB. Dry Flow Rate (AA x (U/100))..... 78346 dscfm

SAMPLE CONCENTRATION/EMISSION RATE

GG. Isokinetic Sampling Rate [(G x T x 100)/(N x O x BB)]..... 109.7 %

	Arsenic	Cadmium	Chromium	Lead	Manganese	Nickel	Antimony	Beryllium
Net Sample (mg)	0.00014	0.00077	0.00121	0.08311	0.00266	0.00079	0.00055	0
Sample Conc. (gr/dscf)	1.25E-08	6.85E-08	1.08E-07	7.40E-06	2.37E-07	7.03E-08	4.89E-08	0.00E+00
Mass Emission (lb/hr)	8.36E-06	4.60E-05	7.23E-05	4.97E-03	1.59E-04	4.72E-05	3.29E-05	0.00E+00
Emission Conc. (ug/dscf)	0.000807	0.00444	0.006977	0.479206	0.0153374	0.004555	0.003171	0
Emission Conc. (ug/dscm)	0.028503	0.156768	0.24635	16.92076	0.541562	0.16084	0.111977	0

	Barium	Zinc	Selenium	Tin	Titanium	Copper	Iron	Thallium	Vanadium
Net Sample (mg)	0.00211	0.01496	0	0.50801	0.00309	0.00364	0.47889	0	0
Sample Conc. (gr/dscf)	1.88E-07	1.33E-06	0.00E+00	4.52E-05	2.75E-07	3.24E-07	4.26E-05	0.00E+00	0.00E+00
Mass Emission (lb/hr)	1.26E-04	8.94E-04	0.00E+00	3.04E-02	1.85E-04	2.17E-04	2.86E-02	0.00E+00	0.00E+00
Emission Conc. (ug/dscf)	0.012166	0.086258	0	2.929146	0.0178167	0.020988	2.761243	0	0
Emission Conc. (ug/dscm)	0.429585	3.045777	0	103.4282	0.6291077	0.741085	97.49948	0	0

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-36-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

RUN NO. 1 - Soft Lead											
Traverse Point #	Velocity Head #1	Temp.	Calculated Velocity	Traverse Point #	Gas Meter Temp In	Gas Meter Temp Out	Average Gas Meter Temp	Traverse Point #	Orifice Pressure		
	("H <sub>2</sub> O)	(°F)	(fps)		(°F)	(°F)	(°F)		(" H <sub>2</sub> O)		
1	0.66	116	56.54	1	91	87	89.00	1	2.26		
2	0.64	118	55.78	2	97	90	93.50	2	2.21		
3	0.60	118	54.01	3	103	91	97.00	3	2.1		
4	0.60	118	54.01	4	105	93	99.00	4	2.11		
5	0.53	118	50.76	5	109	95	102.00	5	1.89		
6	0.35	116	41.18	6	107	96	101.50	6	1.25		
7	0.57	118	52.64	7	100	96	98.00	7	2		
8	0.58	120	53.19	8	104	96	100.00	8	2.05		
9	0.54	121	51.37	9	106	96	101.00	9	1.91		
10	0.55	121	51.84	10	108	98	103.00	10	1.96		
11	0.48	122	48.47	11	108	97	102.50	11	1.71		
12	0.48	122	48.47	12	108	98	103.00	12	1.71		
13	0.63	122	55.53	13	101	97	99.00	13	2.21		
14	0.63	122	55.53	14	104	97	100.50	14	2.21		
15	0.55	123	51.93	15	106	97	101.50	15	1.95		
16	0.55	124	51.97	16	106	97	101.50	16	1.94		
17	0.45	124	47.01	17	105	97	101.00	17	1.59		
18	0.35	125	41.50	18	107	98	102.50	18	1.24		
19	0.58	127	53.51	19	105	100	102.50	19	2.04		
20	0.50	128	49.72	20	109	101	105.00	20	1.77		
21	0.48	128	48.72	21	109	101	105.00	21	1.7		
22	0.39	129	43.95	22	109	101	105.00	22	1.38		
23	0.45	125	47.05	23	106	100	103.00	23	1.59		
24	0.43	127	46.07	24	107	101	104.00	24	1.52		
Average Temperature (°F) -			122.167	Average Velocity (fps) -			50.45				
Avg Gas Meter Temperature (°F)			100.833	Average Orifice Press. ("H <sub>2</sub> O) -			1.85				

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
 21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-37-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**CALCULATIONS**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
 21865 E. Copley Dr. Diamond Bar, California 91765-4182

Test No. **2**

Test Date: **8/23/13**

-----  
 SOURCE TEST CALCULATIONS  
 -----

Sampling Location: **Exide Hard Lead Baghuse Exhaust**  
 Sample Train: **10**

Input by: **J. Aspell**

**SUMMARY**

A. Average Traverse Velocity..... 60.01 fps  
 B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters)..... 91.64583 deg F  
 C. Gas Meter Correction Factor..... 1.0085  
 D. Average Orifice Pressure..... 1.69 "H<sub>2</sub>O  
 E. Nozzle Diameter..... 0.2190 inch  
 F1. Stack Diameter or Dimension #1.... 80 inch  
 F2. Stack Dim #2 (blank if circular)..... inch  
 G. Stack Cross Sect. Area..... 34.907 ft<sup>2</sup>  
 H. Average Stack Temp..... 126.0 deg F  
 I. Barometric Pressure..... 29.87 "HgA  
 J. Gas Meter Pressure (I+(D/13.6)).... 29.99 "HgA  
 K. Static Pressure..... -0.36 "H<sub>2</sub>O  
 L. Total Stack Pressure (I+(K/13.6))... 29.84 "HgA  
 M. Pitot Correction Factor..... 0.84  
 N. Sampling Time..... 240 min  
 O. Nozzle X-Sect. Area..... 0.00026 ft<sup>2</sup>  
 P. Net Sample Collection..... mg  
 Q. Net Solid Collection..... mg  
 R. Water Vapor Condensed..... 38.5 ml  
 S. Gas Volume Metered..... 175.866 dcf

T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C]..... 167.600 dscf

**PERCENT MOISTURE/GAS DENSITY**

U. Percent Water Vapor in Gas Sample ((4.64 x R)/((0.0464 x R) + T))..... 1.05 %

**V. Average Molecular Weight (Wet):**

Component	Vol. Fract.	x	Moist. Fract.	x	Molecular Wt.	=	Wt./Mole
Water	0.011		1.000		18.0	,	0.19
Carbon Dioxide	0.001	Dry Basis	0.989		44.0	,	0.04
Carbon Monoxide	0.000	Dry Basis	0.989		28.0	,	0.00
Oxygen	0.209	Dry Basis	0.989		32.0	,	6.62
Nitrogen & Inerts	0.790	Dry Basis	0.989		28.2	,	22.05
					Sum		28.89

**FLOW RATE**

W. Gas Density Correction Factor (28.95/V)<sup>0.5</sup>..... 1.00  
 X. Velocity Pressure Correction Factor (29.92/L)<sup>0.5</sup>..... 1.00  
 Y. Corrected Velocity (A x M x W x X)..... 50.52 fps  
 Z. Flow Rate (Y x G x 60)..... 105810 cfm  
 AA. Flow Rate (Standard) {Z x (L/29.92) x [520/(460+H)]}..... 93646 scfm  
 BB. Dry Flow Rate (AA x (U/100))..... 92659 dscfm

**SAMPLE CONCENTRATION/EMISSION RATE**

GG. Isokinetic Sampling Rate [(G x T x 100)/(N x O x BB)]..... 100.6 %

	Arsenic	Cadmium	Chromium	Lead	Manganese	Nickel	Antimony	Beryllium	Cobalt
Net Sample (mg)	0.02202	0.00048	0.00078	0.07455	0.00245	0.00063	0.00048	0	0
Sample Conc. (gr/dscf)	2.03E-06	4.42E-08	7.18E-08	6.86E-06	2.26E-07	5.80E-08	4.42E-08	0.00E+00	0.00E+00
Mass Emission (lb/hr)	1.61E-03	3.51E-05	5.70E-05	5.45E-03	1.79E-04	4.61E-05	3.51E-05	0.00E+00	0.00E+00
Emission Conc. (ug/dscf)	0.131364	0.002864	0.004653	0.44474	0.0146159	0.003758	0.002864	0	0
Emission Conc.(ug/dscm)	4.638461	0.101111	0.164305	15.70378	0.5160867	0.132708	0.101111	0	0

	Barium	Zinc	Selenium	Tin	Titanium	Copper	Iron	Thallium	Vanadium
Net Sample (mg)	0.00198	0.00695	0.00213	0.48133	0.00269	0.00158	0.01468	0	0
Sample Conc. (gr/dscf)	1.82E-07	6.40E-07	1.96E-07	4.43E-05	2.48E-07	1.45E-07	1.35E-06	0.00E+00	0.00E+00
Mass Emission (lb/hr)	1.45E-04	5.08E-04	1.56E-04	3.52E-02	1.97E-04	1.16E-04	1.07E-03	0.00E+00	0.00E+00
Emission Conc. (ug/dscf)	0.011812	0.041461	0.012707	2.871454	0.0160476	0.009426	0.087576	0	0
Emission Conc.(ug/dscm)	0.417082	1.464001	0.448679	101.391	0.5666421	0.332823	3.092307	0	0

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-38-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

RUN NO. 1 Hard Lead											
Traverse Point #	Velocity Head #1 ("H <sub>2</sub> O)	Temp. (°F)	Calculated Velocity (fps)	Traverse Point #	Gas Meter Temp In (°F)	Gas Meter Temp Out (°F)	Average Gas Meter Temp (°F)	Traverse Point #	Orifice Pressure (" H <sub>2</sub> O)		
1	0.73	117	59.52	1	81	80	80.50	1	1.6		
2	0.68	118	57.49	2	83	81	82.00	2	1.5		
3	0.61	119	54.50	3	86	82	84.00	3	1.4		
4	0.59	120	53.65	4	88	82	85.00	4	1.3		
5	0.57	120	52.73	5	89	83	86.00	5	1.3		
6	0.58	122	53.28	6	90	84	87.00	6	1.3		
7	0.79	122	62.18	7	88	85	86.50	7	1.8		
8	0.80	122	62.58	8	91	85	88.00	8	1.8		
9	0.79	124	62.29	9	92	86	89.00	9	1.8		
10	0.75	125	60.74	10	94	87	90.50	10	1.7		
11	0.71	127	59.20	11	96	89	92.50	11	1.6		
12	0.65	127	56.65	12	96	90	93.00	12	1.5		
13	0.79	126	62.40	13	92	90	91.00	13	1.8		
14	0.81	127	63.24	14	96	90	93.00	14	1.9		
15	0.79	127	62.45	15	96	90	93.00	15	1.8		
16	0.81	128	63.29	16	97	91	94.00	16	1.9		
17	0.68	132	58.19	17	98	92	95.00	17	1.6		
18	0.69	130	58.51	18	98	92	95.00	18	1.6		
19	0.85	130	64.94	19	98	94	96.00	19	2		
20	0.88	131	66.14	20	102	96	99.00	20	2.1		
21	0.82	133	63.95	21	102	97	99.50	21	1.9		
22	0.88	133	66.25	22	102	97	99.50	22	2.1		
23	0.70	133	59.08	23	103	98	100.50	23	1.7		
24	0.65	132	56.89	24	102	98	100.00	24	1.5		
Average Temperature (°F) -			126.042	Average Velocity (fps) -			60.01				
Avg Gas Meter Temperature (°F) 91.6458				Average Orifice Press. ("H <sub>2</sub> O) -			1.69				

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
 21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-39-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**CALCULATIONS**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
 21865 Copley Dr. Diamond Bar, California 91765-4182

Test No. 3

Test Date: 9/20/13

SOURCE TEST CALCULATIONS

Sampling Location: **Exide Tech. - Soft Lead Baghouse Exhaust**  
 Sample Train: **4**

Input by: **J. Aspell**

SUMMARY

A. Average Traverse Velocity.....	53.89	fps
B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters).....	88.47917	deg F
C. Gas Meter Correction Factor.....	1.0021	
D. Average Orifice Pressure.....	1.36	"H <sub>2</sub> O
E. Nozzle Diameter.....	0.2190	inch
F1. Stack Diameter or Dimension #1....	80	inch
F2. Stack Dim #2 (blank if circular).....		inch
G. Stack Cross Sect. Area.....	34.907	ft <sup>2</sup>
H. Average Stack Temp.....	116.2	deg F
I. Barometric Pressure.....	29.44	"HgA
J. Gas Meter Pressure (I+(D/13.6)).....	29.54	"HgA
K. Static Pressure.....	-0.35	"H <sub>2</sub> O
L. Total Stack Pressure (I+(K/13.6))....	29.41	"HgA
M. Pitot Correction Factor.....	0.84	
N. Sampling Time.....	240	min
O. Nozzle X-Sect. Area.....	0.00026	ft
P. Net Sample Collection.....		mg
Q. Net Solid Collection.....		mg
R. Water Vapor Condensed.....	66.1	ml
S. Gas Volume Metered.....	159.878	dscf
T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C].....	149.964	dscf

PERCENT MOISTURE/GAS DENSITY

U. Percent Water Vapor in Gas Sample ((4.64 x R)/((0.0464 x R) + T))..... 2.00 %

V. Average Molecular Weight (Wet):

Component	Vol. Fract.	x	Moist. Fract.	x	Molecular Wt.	=	Wt./Mole
Water	0.020		1.000		18.0	,	0.36
Carbon Dioxide	0.001	Dry Basis	0.980		44.0	,	0.04
Carbon Monoxide	0.000	Dry Basis	0.980		28.0	,	0.00
Oxygen	0.203	Dry Basis	0.980		32.0	,	6.37
Nitrogen & Inerts	0.796	Dry Basis	0.980		28.2	,	21.99
					Sum		28.77

FLOW RATE

W. Gas Density Correction Factor (28.95/V) <sup>0.5</sup> .....	1.00	
X. Velocity Pressure Correction Factor (29.92/L) <sup>0.5</sup> .....	1.01	
Y. Corrected Velocity (A x M x W x X).....	45.80	fps
Z. Flow Rate (Y x G x 60).....	95914	cfm
AA. Flow Rate (Standard) [Z x (L/29.92) x {520/(460+H)}].....	85095	scfm
BB. Dry Flow Rate (AA x (U/100)).....	83389	dscfm

SAMPLE CONCENTRATION/EMISSION RATE

GG. Isokinetic Sampling Rate [(G x T x 100)/(N x O x BB)]..... 100.0 %

	Arsenic	Cadmium	Chromium	Lead	Manganese	Nickel	Antimony	Beryllium	Cobalt
Net Sample (mg)	0.0012	0.00187	0.0014	0.20995	0.00112	0.00117	0.00143	0.000004	0.0001
Sample Conc. (gr/dscf)	1.23E-07	1.92E-07	1.44E-07	2.16E-05	1.15E-07	1.20E-07	1.47E-07	4.12E-10	1.03E-08
Mass Emission (lb/hr)	8.82E-05	1.38E-04	1.03E-04	1.54E-02	8.24E-05	8.60E-05	1.05E-04	2.94E-07	7.35E-06
Emission Conc. (ug/dscf)	0.008001	0.012468	0.009334	1.399788	0.0074673	0.007801	0.009534	2.67E-05	0.000667
Emission Conc. (ug/dscm)	0.282504	0.440236	0.329588	49.4265	0.2636708	0.275442	0.336651	0.000942	0.023542

	Barium	Zinc	Selenium	Tin	Titanium	Copper	Iron	Thallium	Vanadium
Net Sample (mg)	0.00323	0.03479	0.00035	0.77163	0.00415	0.0041	0.08236	0	0
Sample Conc. (gr/dscf)	3.32E-07	3.58E-06	3.60E-08	7.94E-05	4.27E-07	4.22E-07	8.47E-06	0.00E+00	0.00E+00
Mass Emission (lb/hr)	2.38E-04	2.56E-03	2.57E-05	5.67E-02	3.05E-04	3.01E-04	6.06E-03	0.00E+00	0.00E+00
Emission Conc. (ug/dscf)	0.021535	0.231953	0.002334	5.144644	0.0276691	0.027336	0.549114	0	0
Emission Conc. (ug/dscm)	0.760408	8.190273	0.082397	181.6574	0.9769944	0.965223	19.38922	0	0

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-40-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

Soft Lead		Run No. 3									
Traverse Point #	Velocity Head #1 ("H <sub>2</sub> O)	Temp. (°F)	Calculated Velocity (fps)	Traverse Point #	Gas Meter Temp In (°F)	Gas Meter Temp Out (°F)	Average Gas Meter Temp (°F)	Traverse Point #	Orifice Pressure (" H <sub>2</sub> O)		
1	0.66	108	56.15	1	79	79	79.00	1	1.45		
2	0.66	109	56.20	2	81	79	80.00	2	1.46		
3	0.60	111	53.68	3	85	79	82.00	3	1.33		
4	0.65	111	55.87	4	88	79	83.50	4	1.45		
5	0.48	111	48.01	5	90	81	85.50	5	1.08		
6	0.44	110	45.93	6	90	81	85.50	6	0.99		
7	0.62	112	54.61	7	87	82	84.50	7	1.38		
8	0.60	114	53.82	8	91	83	87.00	8	1.35		
9	0.65	115	56.06	9	92	84	88.00	9	1.46		
10	0.57	115	52.50	10	94	85	89.50	10	1.29		
11	0.55	115	51.57	11	94	86	90.00	11	1.25		
12	0.55	117	51.66	12	95	86	90.50	12	1.25		
13	0.79	117	61.92	13	88	85	86.50	13	1.76		
14	0.76	117	60.73	14	92	85	88.50	14	1.7		
15	0.72	117	59.11	15	96	86	91.00	15	1.63		
16	0.65	120	56.31	16	97	87	92.00	16	1.47		
17	0.58	120	53.19	17	98	88	93.00	17	1.32		
18	0.35	110	40.96	18	96	89	92.50	18	0.81		
19	0.70	121	58.48	19	91	87	89.00	19	1.56		
20	0.67	124	57.36	20	95	88	91.50	20	1.5		
21	0.62	125	55.23	21	96	89	92.50	21	1.4		
22	0.57	125	52.96	22	98	90	94.00	22	1.29		
23	0.52	123	50.49	23	98	90	94.00	23	1.18		
24	0.52	122	50.45	24	98	90	94.00	24	1.18		
Average Temperature (°F) -			116.208	Average Velocity (fps) -			53.89				
Avg Gas Meter Temperature (°F)			88.4792	Average Orifice Press. ("H <sub>2</sub> O) -			1.36				



**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
**21865 Copley Drive, Diamond Bar, California 91765**

Test Nos. 13-307 and 13-308

-41-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**CALCULATIONS**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
 21865 E. Copley Dr. Diamond Bar, California 91765-4182

Test No. **3**

Test Date: **9/20/13**

-----  
**SOURCE TEST CALCULATIONS**  
 -----

Sampling Location: **Exide Hard Lead Baghuse Exhaust**  
 Sample Train: **5**

Input by: **J. Aspell**

**SUMMARY**

A. Average Traverse Velocity..... 63.08 fps  
 B. Gas Meter Temperature (Use 60 deg.F for Temp Comp. Meters)..... 80.16667 deg F  
 C. Gas Meter Correction Factor..... 1.0085  
 D. Average Orifice Pressure..... 1.94 "H<sub>2</sub>O  
 E. Nozzle Diameter..... 0.2200 inch

F1. Stack Diameter or Dimension #1.... 80 inch  
 F2. Stack Dim #2 (blank if circular)..... inch  
 G. Stack Cross Sect. Area..... 34.907 ft<sup>2</sup>  
 H. Average Stack Temp..... 111.8 deg F  
 I. Barometric Pressure..... 29.44 "HgA  
 J. Gas Meter Pressure (I+(D/13.6))..... 29.58 "HgA  
 K. Static Pressure..... -0.34 "H<sub>2</sub>O  
 L. Total Stack Pressure (I+(K/13.6)).... 29.42 "HgA

M. Pitot Correction Factor..... 0.84  
 N. Sampling Time..... 240 min  
 O. Nozzle X-Sect. Area..... 0.00026 ft<sup>2</sup>  
 P. Net Sample Collection..... mg  
 Q. Net Solid Collection..... mg  
 R. Water Vapor Condensed..... 64.2 ml  
 S. Gas Volume Metered..... 187.326 dcf

T. Corrected Gas Volume [(S x J/29.92) x 520/(460+B) x C]..... 179.813 dscf

**PERCENT MOISTURE/GAS DENSITY**

U. Percent Water Vapor in Gas Sample ((4.64 x R)/(0.0464 x R) + T)..... 1.63 %

**V. Average Molecular Weight (Wet):**

Component	Vol. Fract.	x	Moist. Fract.	x	Molecular Wt.	=	Wt./Mole
Water	0.016		1.000		18.0	,	0.29
Carbon Dioxide	0.001	Dry Basis	0.984		44.0	,	0.03
Carbon Monoxide	0.000	Dry Basis	0.984		28.0	,	0.00
Oxygen	0.204	Dry Basis	0.984		32.0	,	6.42
Nitrogen & Inerts	0.795	Dry Basis	0.984		28.2	,	22.06
					Sum		28.81

**FLOW RATE**

W. Gas Density Correction Factor (28.95/V)<sup>0.5</sup>..... 1.00  
 X. Velocity Pressure Correction Factor (29.92/L)<sup>0.5</sup>..... 1.01  
 Y. Corrected Velocity (A x M x W x X)..... 53.57 fps  
 Z. Flow Rate (Y x G x 60)..... 112197 cfm  
 AA. Flow Rate (Standard) {Z x (L/29.92) x [520/(460+H)]}..... 100313 scfm  
 BB. Dry Flow Rate (AA x (U/100))..... 98678 dscfm

**SAMPLE CONCENTRATION/EMISSION RATE**

GG. Isokinetic Sampling Rate [(G x T x 100)/(N x O x BB)]..... 100.4 %

	Arsenic	Cadmium	Chromium	Lead	Manganese	Nickel	Antimony	Beryllium	Cobalt
Net Sample (mg)	0.01408	0.0012	0.00099	0.29437	0.00044	0.0008	0.00143	0	0.00004
Sample Conc. (gr/dscf)	1.21E-06	1.03E-07	8.50E-08	2.53E-05	3.78E-08	6.86E-08	1.23E-07	0.00E+00	3.43E-09
Mass Emission (lb/hr)	1.02E-03	8.71E-05	7.18E-05	2.14E-02	3.19E-05	5.81E-05	1.04E-04	0.00E+00	2.90E-06
Emission Conc. (ug/dscf)	0.078292	0.006673	0.005505	1.63684	0.0024466	0.004448	0.007951	0	0.000222
Emission Conc. (ug/dscm)	2.764478	0.235609	0.194377	57.79682	0.0863899	0.157073	0.280767	0	0.007854

	Barium	Zinc	Selenium	Tin	Titanium	Copper	Iron	Thallium	Vanadium
Net Sample (mg)	0.00372	0.00879	0.00027	0.78782	0.00218	0.00263	0.03139	0	0
Sample Conc. (gr/dscf)	3.19E-07	7.54E-07	2.32E-08	6.76E-05	1.87E-07	2.26E-07	2.69E-06	0.00E+00	0.00E+00
Mass Emission (lb/hr)	2.70E-04	6.38E-04	1.96E-05	5.72E-02	1.58E-04	1.91E-04	2.28E-03	0.00E+00	0.00E+00
Emission Conc. (ug/dscf)	0.020685	0.048877	0.001501	4.380662	0.0121219	0.014624	0.174544	0	0
Emission Conc. (ug/dscm)	0.730388	1.725835	0.053012	154.6812	0.4280228	0.516376	6.163136	0	0

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-42-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

Hard Lead Run No. 3											
Traverse Point #	Velocity Head #1 ("H <sub>2</sub> O)	Temp. (°F)	Calculated Velocity (fps)	Traverse Point #	Gas Meter Temp In (°F)	Gas Meter Temp Out (°F)	Average Gas Meter Temp (°F)	Traverse Point #	Orifice Pressure (" H <sub>2</sub> O)		
1	0.83	108	62.97	1	69	68	68.50	1	1.85		
2	0.73	110	59.16	2	73	70	71.50	2	1.64		
3	0.69	110	57.51	3	76	71	73.50	3	1.56		
4	0.65	110	55.82	4	78	72	75.00	4	1.48		
5	0.53	110	50.40	5	79	74	76.50	5	1.21		
6	0.57	110	52.27	6	80	74	77.00	6	1.31		
7	0.97	109	68.13	7	78	75	76.50	7	2.22		
8	0.93	111	66.83	8	81	76	78.50	8	2.14		
9	0.88	112	65.06	9	83	77	80.00	9	2.03		
10	0.86	112	64.32	10	84	78	81.00	10	2		
11	0.76	112	60.46	11	84	79	81.50	11	1.77		
12	0.54	112	50.97	12	84	79	81.50	12	1.26		
13	1.05	110	70.95	13	78	77	77.50	13	2.41		
14	1.07	112	71.74	14	82	78	80.00	14	2.47		
15	1.08	113	72.14	15	84	79	81.50	15	2.51		
16	0.96	113	68.02	16	86	80	83.00	16	2.24		
17	0.84	114	63.68	17	87	81	84.00	17	1.96		
18	0.67	114	56.87	18	87	82	84.50	18	1.57		
19	1.05	111	71.01	19	85	82	83.50	19	2.46		
20	1.05	113	71.13	20	86	82	84.00	20	2.46		
21	0.96	114	68.08	21	88	83	85.50	21	2.26		
22	0.87	115	64.86	22	90	83	86.50	22	2.05		
23	0.81	114	62.53	23	89	84	86.50	23	1.91		
24	0.72	114	58.95	24	89	84	86.50	24	1.7		
Average Temperature (°F) -			111.792	Average Velocity (fps) -			63.08				
Avg Gas Meter Temperature (°F)			80.1667	Average Orifice Press. ("H <sub>2</sub> O) -			1.94				

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-43-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

EPA Method TO-15 Calculations				EPA Method TO-15 Calculations			
Location		Exide Hard Lead Baghouse Exhaust		Location		Exide Hard Lead Baghouse Exhaust	
Run No.	1	Date	8/23/2013	Run No.	2	Date	8/23/2013
Measured Flowrate	92659	dscfm		Measured Flowrate	92659	dscfm	
Compound	Conc. (ppb)	MW	lb/hr	Compound	Conc. (ppb)	MW	lb/hr
1,3 butadiene	37.4	54.09	2.97E-02	1,3 butadiene	31.3	54.09	2.48E-02
benzene	127	78.11	1.46E-01	benzene	111	78.11	1.27E-01
acrolein	2	56.06	1.64E-03	acrolein	2.4	56.06	1.97E-03
acetone	57.9	58.08	4.93E-02	acetone	32.8	58.08	2.79E-02
methylene chloride	0.5	84.93	6.23E-04	methylene chloride	0.6	84.93	7.48E-04
MEK	1.7	72.11	1.80E-03	MEK	1.6	72.11	1.69E-03
chloroform	0.4	119.38	7.00E-04	chloroform	0.3	119.38	5.25E-04
toluene	25.4	92.13	3.43E-02	toluene	22	92.13	2.97E-02
ethylbenzene	5.6	106.16	8.72E-03	ethylbenzene	4.5	106.16	7.01E-03
m+p xylenes	10	106.17	1.56E-02	m+p xylenes	6.3	106.17	9.81E-03
styrene	104	104.14	1.59E-01	styrene	78.4	104.14	1.20E-01
o-xylene	2.9	106.17	4.52E-03	o-xylene	1.7	106.17	2.65E-03
isoprene	8.6	68.12	8.59E-03	isoprene	7.6	68.12	7.59E-03
Acetylene+ethylene	662	27.045	2.63E-01	Acetylene+ethylene	595	27.045	2.36E-01
ethane	4440	30.07	1.96E+00	ethane	4400	30.07	1.94E+00
propylene	194	42.08	1.20E-01	propylene	155	42.08	9.57E-02
propane	909	44.1	5.88E-01	propane	949	44.1	6.14E-01
isobutane	41.9	58.12	3.57E-02	isobutane	47.6	58.12	4.06E-02
1-butene	9.8	56.11	8.07E-03	1-butene	8.5	56.11	7.00E-03
n-butane	71.2	58.12	6.07E-02	n-butane	64.7	58.12	5.52E-02
n-pentane	27.6	72.15	2.92E-02	n-pentane	25.9	72.15	2.74E-02
1-hexene	4.5	84.16	5.56E-03	1-hexene	4	84.16	4.94E-03
n-hexane	3.5	86.18	4.42E-03	n-hexane	4.1	86.18	5.18E-03
n-heptane	2.6	100.21	3.82E-03	n-heptane	2.7	100.21	3.97E-03
n-octane	1.4	114.23	2.35E-03	n-octane	1.3	114.23	2.18E-03
n-nonane	0.4	128.2	7.52E-04	n-nonane	0.4	128.2	7.52E-04
n-decane	0.3	142.29	6.26E-04	n-decane	0.3	142.29	6.26E-04
n-undecane	0.3	156.31	6.88E-04	n-undecane	0.3	156.31	6.88E-04
n-dodecane	0.3	170.33	7.50E-04	n-dodecane	0.4	170.33	9.99E-04
thiophene	0	84.14	0.00E+00	thiophene	0	84.14	0.00E+00
2,4 dimethyl-1-heptene	0	126.24	0.00E+00	2,4 dimethyl-1-heptene	0	126.24	0.00E+00
acetonitrile	0	41.05	0.00E+00	acetonitrile	0	41.05	0.00E+00
ethanol	19.8	46.07	1.34E-02	ethanol	6.6	46.07	4.46E-03
lb/hr = (ppbv/1000)* (Q*60)*MW/379/1000000				lb/hr = (ppbv/1000)* (Q*60)*MW/379/1000000			

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-44-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

EPA Method TO-15 Calculations				EPA Method TO-15 Calculations			
Location	Exide Hard Lead Baghouse Exhaust			Location	Exide Soft Lead Baghouse Exhaust		
Run No.	3	Date	9/20/2013	Run No.	1	Date	8/23/2013
Measured Flowrate	98678	dscfm		Measured Flowrate	78346	dscfm	
Compound	Conc. (ppb)	MW	lb/hr	Compound	Conc. (ppb)	MW	lb/hr
1,3 butadiene	21.9	54.09	1.85E-02	1,3 butadiene	4.4	54.09	2.95E-03
benzene	68.9	78.11	8.41E-02	benzene	51	78.11	4.94E-02
acrolein	3	56.06	2.63E-03	acrolein	1.1	56.06	7.65E-04
acetone	42	58.08	3.81E-02	acetone	98.4	58.08	7.09E-02
methylene chloride	0.3	84.93	3.98E-04	methylene chloride	0.4	84.93	4.21E-04
MEK	1.5	72.11	1.69E-03	MEK	1.7	72.11	1.52E-03
chloroform	0.2	119.38	3.73E-04	chloroform	0.4	119.38	5.92E-04
toluene	18.6	92.13	2.68E-02	toluene	7.8	92.13	8.91E-03
ethylbenzene	2.3	106.16	3.81E-03	ethylbenzene	2.9	106.16	3.82E-03
m+p xylenes	4	106.17	6.63E-03	m+p xylenes	11.8	106.17	1.55E-02
styrene	33.3	104.14	5.42E-02	styrene	1.4	104.14	1.81E-03
o-xylene	2	106.17	3.32E-03	o-xylene	3.3	106.17	4.35E-03
isoprene	19.4	68.12	2.06E-02	isoprene	0.3	68.12	2.53E-04
Acetylene+ethylene	551	27.045	2.33E-01	Acetylene+ethylene	467	27.045	1.57E-01
ethane	433	30.07	2.03E-01	ethane	192	30.07	7.16E-02
propylene	137	42.08	9.01E-02	propylene	20.5	42.08	1.07E-02
propane	144	44.1	9.92E-02	propane	269	44.1	1.47E-01
isobutane	7.8	58.12	7.08E-03	isobutane	3.8	58.12	2.74E-03
1-butene	14.4	56.11	1.26E-02	1-butene	1.5	56.11	1.04E-03
n-butane	17.2	58.12	1.56E-02	n-butane	25.6	58.12	1.85E-02
n-pentane	11.1	72.15	1.25E-02	n-pentane	3.1	72.15	2.77E-03
1-hexene	6.1	84.16	8.02E-03	1-hexene	0.2	84.16	2.09E-04
n-hexane	1.5	86.18	2.02E-03	n-hexane	0.5	86.18	5.34E-04
n-heptane	1.5	100.21	2.35E-03	n-heptane	0.4	100.21	4.97E-04
n-octane	0.8	114.23	1.43E-03	n-octane	0.2	114.23	2.83E-04
n-nonane	0.4	128.2	8.01E-04	n-nonane	0	128.2	0.00E+00
n-decane	0.3	142.29	6.67E-04	n-decane	0	142.29	0.00E+00
n-undecane	0.4	156.31	9.77E-04	n-undecane	0	156.31	0.00E+00
n-dodecane	0.6	170.33	1.60E-03	n-dodecane	0	170.33	0.00E+00
thiophene	0	84.14	0.00E+00	thiophene	0	84.14	0.00E+00
tetrachloroethylene	0.1	165.83	2.59E-04	2,4 dimethyl-1-heptene	0	126.24	0.00E+00
carbon tetrachloride	0.1	153.82	2.40E-04	acetonitrile	0	41.05	0.00E+00
ethanol	13.5	46.07	9.72E-03	ethanol	26.1	46.07	1.49E-02
lb/hr = (ppbv/1000)*(Q*60)*MW/379/1000000				lb/hr = (ppbv/1000)*(Q*60)*MW/379/1000000			

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-45-

Date(s): 8/8/13, 8/23/13 and 9/20/13

CALCULATIONS

EPA Method TO-15 Calculations				EPA Method TO-15 Calculations			
Location	Exide Soft Lead Baghouse Exhaust			Location	Exide Soft Lead Baghouse Exhaust		
Run No.	2	Date	8/23/2013	Run No.	3	Date	9/20/2013
Measured Flowrate	78346	dscfm		Measured Flowrate	83389	dscfm	
Compound	Conc. (ppb)	MW	lb/hr	Compound	Conc. (ppb)	MW	lb/hr
1,3 butadiene	0.8	54.09	5.37E-04	1,3 butadiene	17.1	54.09	1.22E-02
benzene	21.5	78.11	2.08E-02	benzene	159	78.11	1.64E-01
acrolein	0.9	56.06	6.26E-04	acrolein	4.1	56.06	3.03E-03
acetone	75.4	58.08	5.43E-02	acetone	40	58.08	3.07E-02
methylene chloride	0.5	84.93	5.27E-04	methylene chloride	0	84.93	0.00E+00
MEK	0.8	72.11	7.16E-04	MEK	1	72.11	9.52E-04
chloroform	0.2	119.38	2.96E-04	chloroform	0.1	119.38	1.58E-04
toluene	3.8	92.13	4.34E-03	toluene	26.9	92.13	3.27E-02
ethylbenzene	2	106.16	2.63E-03	ethylbenzene	1.9	106.16	2.66E-03
m+p xylenes	8	106.17	1.05E-02	m+p xylenes	10	106.17	1.40E-02
styrene	0.3	104.14	3.87E-04	styrene	21.9	104.14	3.01E-02
o-xylene	1.9	106.17	2.50E-03	o-xylene	1.9	106.17	2.66E-03
isoprene	0	68.12	0.00E+00	isoprene	5.6	68.12	5.04E-03
Acetylene+ethylene	450	27.045	1.51E-01	Acetylene+ethylene	888	27.045	3.17E-01
ethane	208	30.07	7.76E-02	ethane	119	30.07	4.72E-02
propylene	12.8	42.08	6.68E-03	propylene	190	42.08	1.06E-01
propane	398	44.1	2.18E-01	propane	75	44.1	4.37E-02
isobutane	4.6	58.12	3.32E-03	isobutane	3.5	58.12	2.69E-03
1-butene	0.8	56.11	5.57E-04	1-butene	46.3	56.11	3.43E-02
n-butane	21.8	58.12	1.57E-02	n-butane	11.4	58.12	8.75E-03
n-pentane	2.1	72.15	1.88E-03	n-pentane	20	72.15	1.90E-02
1-hexene	0	84.16	0.00E+00	1-hexene	2.5	84.16	2.78E-03
n-hexane	0.4	86.18	4.28E-04	n-hexane	0.8	86.18	9.10E-04
n-heptane	0.4	100.21	4.97E-04	n-heptane	0.9	100.21	1.19E-03
n-octane	0	114.23	0.00E+00	n-octane	0.6	114.23	9.05E-04
n-nonane	0	128.2	0.00E+00	n-nonane	0.4	128.2	6.77E-04
n-decane	0	142.29	0.00E+00	n-decane	0.4	142.29	7.51E-04
n-undecane	0	156.31	0.00E+00	n-undecane	0	156.31	0.00E+00
n-dodecane	0	170.33	0.00E+00	n-dodecane	0	170.33	0.00E+00
thiophene	0	84.14	0.00E+00	thiophene	0	84.14	0.00E+00
2,4 dimethyl-1-heptene	0	126.24	0.00E+00	2,4 dimethyl-1-heptene	0	126.24	0.00E+00
acetonitrile	0	41.05	0.00E+00	carbon tetrachloride	0.1	153.82	2.03E-04
ethanol	6.3	46.07	3.60E-03	ethanol	10.8	46.07	6.57E-03
lb/hr = (ppbv/1000)* (Q*60)*MW/379/1000000				lb/hr = (ppbv/1000)* (Q*60)*MW/379/1000000			

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-46-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**APPENDICES**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-47-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**APPENDIX A**

Field Data

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-48-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**South Coast Air Quality Management District**

Test No. 13-307 Company: EXIDE  
Sampling Location: HARD LEAD B/H - EXH

Date: 8/8/13  
Sample Train: 10

**Traverse Source Test Data**

Pre-Test Leak Check:  
Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 0.00 cfm @ 15 "Hg vac  
Pitot Tube Leak Check: Pass / Fail

Post-Test Leak Check:  
Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 0 cfm @ 8 "Hg vac  
Pitot Tube Leak Check: Pass / Fail

Time	Sample Point #	Gas Meter Reading (dcf)	Stack		Calculated			Probe Temp. °F	Filter Temp. °F	Imp. Temp. °F	Meter Temp. °F		Vacuum "Hg
			Velocity Head ("H <sub>2</sub> O)	Temp. °F	Velocity (fps)	Sampling Rate (cfm)	Orifice ΔP ("H <sub>2</sub> O)				In.	Out	
11:10	1	774.96 775.35	.03	114	12.03	0.14	.07			50	79	76	<1
	2	775.81	.02	115	9.83	0.11	.04			49	78	80	<1
	3	776.32	.02	117	9.85	.11	.04			53	80	79	<1
	4	777.0	.02	115	9.83	.11	.04			54	81	78	<1
	5	778.25	.11	117	23.1	.27	.24			53	81	79	1
	6	779.66	0.10	117	22.0	.25	.22			57	81	79	1
1	1	780.65	.05	116	15.56	.18	.11			51	82	80	<1
	2	781.73	.09	121	20.97	.24	.20			53	82	80	1
	3	783.26	0.12	119	24.17	.28	.26			48	83	81	1
	4	784.52	0.08	119	19.74	.23	.18			47	83	81	1
	5	785.74	0.11	119	23.74	.27	.24			49	84	81	1
	6	786.96	0.07	119	18.46	.21	.15			45	85	82	1
2	1	788.53	0.14	118	26.10	.30	.31			48	85	83	1
	2	790.20	0.16	118	27.89	.32	.35			48	85	83	1
	3	791.80	0.14	119	26.11	.30	.31			50	86	83	1
	4	793.42	0.14	122	26.18	.30	.31			48	86	84	1
	5	797.0	0.20	120	30.47	.37	.36			46	86	85	4
	6	800.60	0.70	120	58.43	.67	1.55			43	86	84	4
10	1	803.60	0.57	121	52.77	.60	1.26			44	87	84	4
	2	807.25	0.83	121	63.68	.73	1.84			44	86	84	6
	3	811.20	0.80	122	62.58	.72	1.78			48	89	85	7
	4	814.90	0.72	121	59.31	.68	1.61			50	90	85	7
	5	818.50	0.64	121	55.92	.64	1.43			47	90	86	5
	6	821.34	0.53	121	50.89	.58	1.19			47	91	86	3

(Net Vol. Uncorr.)


Avg.

K-Factor: 0.5639 Stack Moisture: ~ 1% Canister #: \_\_\_\_\_ Start: \_\_\_\_\_ "Hg vac

Nozzle Diameter: 0.17 " <sup>0.174</sup>  
Barometric Pressure: 30.0 "HgA  
Static Pressure in Stack: + 0.6 "H<sub>2</sub>O

Recorded By: RL  
Pitot Factor: 0.87

Calibration Data	
Inclined Manometer	(Cal: N/A)
Magnehelic No. <u>30403</u>	(Cal: 8/16/13)
Pitot Tube No. <u>30415</u>	(Cal: 4/12/13)
Potentiometer No. <u>NO313</u>	(Cal: 6/21/13)
Thermocouple No. <u>50115</u>	(Cal: 6/21/13)
Gas Meter No. <u>NO713</u>	(Cal: 6/21/13)
Meter Corr. Factor: <u>1.0085</u>	



Sampling Probe: Stainless Steel / Borosilicate / Quartz

Stack: Horizontal / Vertical Rectangular / Circular



**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-49-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**South Coast Air Quality Management District**

Test No. 13-307 Company: EXIDE Date: 8/8/13  
Sampling Location: HARD LEAD B/H - EXH Sample Train: \_\_\_\_\_

**Traverse Source Test Data**

Pre-Test Leak Check: \_\_\_\_\_ Post-Test Leak Check: \_\_\_\_\_  
Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac Probe: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Pitot Tube Leak Check: Pass / Fail Pitot Tube Leak Check: Pass / Fail

*VELOCITY P CHECK*

Time	Sample Point #	Gas Meter Reading (dcf) Start:	Stack		Calculated			Probe Temp. °F	Filter Temp. °F	Imp. Temp. °F	Meter Temp. °F		Vacuum "Hg
			Velocity Head ("H <sub>2</sub> O)	Temp. °F	Velocity (fps)	Sampling Rate (cfm)	Orifice ΔP ("H <sub>2</sub> O)				In	Out	
2:10	1		0.79	125									
	2		0.74	125									
	3		0.77	125									
	4		0.76	125									
	5		0.80	125									
	6		0.84	125									
	7		0.83	124									
	8		0.87	124									
	9		0.86	123									
	10		0.82	122									
	11		0.70	123									
	12		0.99	122									
	13		0.82	124									
	14		0.84	124									
	15		0.84	124									
	16		0.90	125									
	17		0.85	124									
	18		0.78	125									
	19		0.79	124									
	20		0.73	124									
	21		0.67	124									
	22		0.65	124									
	23		0.58	123									
	24		0.26	121									

(Net Vol. Uncorr.)

Avg.

K-Factor: \_\_\_\_\_ Stack Moisture: \_\_\_\_\_ Canister #: \_\_\_\_\_ Start: \_\_\_\_\_ "Hg vac

Nozzle Diameter: \_\_\_\_\_ "

Recorded By: RL


Barometric Pressure: \_\_\_\_\_ " HgA

Pitot Factor: 0.84

Static Pressure in Stack: +1- \_\_\_\_\_ " H<sub>2</sub>O

**Calibration Data**

Inclined Manometer	(Cal: N/A)
Magnehelic No.	(Cal: _____)
Pitot Tube No. <u>30903</u>	(Cal: <u>8/6/13</u> )
Potentiometer No. <u>20304</u>	(Cal: <u>8/6/13</u> )
Thermocouple No. <u>50112</u>	(Cal: <u>8/6/13</u> )
Gas Meter No.	(Cal: _____)
Meter Corr. Factor:	



Sampling Probe: Stainless Steel / Borosilicate / Quartz

Stack: Horizontal / Vertical Rectangular / Circular

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-50-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
TCA TEST DATA SHEET (METHOD 25.1)**

Date: 8/8/13 Page No.: \_\_\_\_\_  
 Test No.: \_\_\_\_\_ Recorded By: CW  
 Company/Sampling Location: Exide  
 Basic and Control Equipment: \_\_\_\_\_  
 Barometric Pressure: \_\_\_\_\_ \*HgA Static Pressure: +/- \_\_\_\_\_ \*H<sub>2</sub>O

SAMPLE A			
Tank #: <u>DA185</u>		Trap #:	Reg. #:
Pre-Test Leak Check:		Gauge Reading:	
		<u>Pass</u> / Fail	
Post-Test Leak Check:		Gauge Reading:	
		Pass / Fail	
Time	Vacuum (*Hg)	Flow (cc/min)	Comments
<u>11:48</u>	<u>30</u>		
<u>11:58</u>	<u>29</u>		
<u>12:00</u>	<u>25</u>		
<u>12:04</u>	<u>20</u>		
<u>12:10</u>	<u>16</u>		
<u>12:16</u>	<u>13</u>		

SAMPLE B			
Tank #: <u>E3385</u>		Vial #:	Reg. #:
Pre-Test Leak Check:		Gauge Reading:	
		<u>Pass</u> / Fail	
Post-Test Leak Check:		Gauge Reading:	
		Pass / Fail	
Time	Vacuum (*Hg)	Flow (cc/min)	Comments
<u>11:48</u>	<u>30</u>		
<u>11:48</u>	<u>0</u>		

TCA SAMPLING INTERVAL TABLE (ΔP)

Min. Δ °F	70	200	400	600	800	1000	1200	1400	1600
15	2.65	2.9							
20	2.20	2.45	2.7						
25	1.90	2.15	2.30	2.70					
30	1.65	1.85	2.00	2.40	2.85				
35	1.40	1.60	1.80	2.10	2.50	2.85			
40	1.20	1.40	1.60	1.90	2.25	2.50	2.95		
45	1.05	1.25	1.40	1.70	2.00	2.25	2.60	3.00	
50	0.95	1.15	1.25	1.50	1.85	2.05	2.40	2.70	
55	0.85	1.05	1.15	1.35	1.65	1.85	2.15	2.45	2.80
60	0.80	0.95	1.05	1.25	1.55	1.70	2.00	2.30	2.55
65	0.70	0.85	0.95	1.15	1.40	1.60	1.90	2.15	2.40
70	0.65	0.80	0.90	1.05	1.30	1.50	1.75	2.00	2.25
75	0.60	0.75	0.80	1.00	1.25	1.40	1.65	1.90	2.15
80	0.55	0.65	0.75	0.90	1.15	1.30	1.55	1.80	2.05
85	0.50	0.60	0.70	0.85	1.10	1.25	1.50	1.75	1.95
90	0.50	0.55	0.65	0.80	1.05	1.25	1.50	1.65	1.90

Revision: April 20, 2011



**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-51-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**South Coast Air Quality Management District**

Test No. 13-308 Company: EXIDE MANUFACTURING COMPANY Date: 8/23/13  
Sampling Location: HAND LEAD B/H STACK Sample Train: 10

**Traverse Source Test Data**

Pre-Test Leak Check:  
Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 0.015 cfm @ 15 "Hg vac  
Pitot Tube Leak Check: Pass / Fail

Post-Test Leak Check:  
Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 0.010 cfm @ 7 "Hg vac  
Pitot Tube Leak Check: Pass / Fail

Time	Sample Point #	Gas Meter Reading (dcf) Start: <u>821.909</u>	Stack		Calculated			Probe Temp. °F	Filter Temp. °F	Imp. Temp. °F	Meter Temp. °F		Vacuum *Hg
			Velocity Head (*H <sub>2</sub> O)	Temp. °F	Velocity (fps)	Sampling Rate (cfm)	Orifice ΔP (*H <sub>2</sub> O)				In	Out	
9:11 AM	1	829.03	0.73	117	59.5	0.70	1.6			42	81	80	1.5
	2	836.20	0.68	118	57.5	0.67	1.5			41	83	81	1.5
	3	842.85	0.61	119	54.5	0.64	1.4			50	86	82	1.5
	4	849.24	0.59	120	53.6	0.62	1.3			43	88	82	1.5
	5	855.66	0.57	120	52.7	0.61	1.3			47	89	83	1.5
	6	862.249	0.58	122	53.3	0.62	1.3			42	90	84	1.5
10:11 AM	1	869.96	0.79	122	62.2	0.72	1.8			43	88	85	3
	2	877.52	0.80	122	62.6	0.73	1.8			53	91	85	3
	3	884.90	0.79	124	62.3	0.72	1.8			44	92	86	3
	4	892.42	0.75	125	60.7	0.70	1.7			43	94	87	3
	5	899.85	0.71	127	59.2	0.68	1.6			45	96	89	3
	6	906.558	0.65	127	56.6	0.65	1.5			40	96	90	2
11:11 AM	1	914.42	0.79	126	62.4	0.72	1.8			42	92	90	3
	2	922.18	0.81	127	63.2	0.73	1.9			43	96	90	2
	3	929.45	0.79	127	62.4	0.72	1.8			45	96	90	3
	4	937.34	0.81	128	63.3	0.73	1.9			40	97	91	3
	5	944.60	0.68	132	58.7	0.66	1.6			35	98	92	2
	6	951.32	0.69	130	58.5	0.67	1.6			43	98	92	2
12:11 PM	1	959.49	0.85	130	64.9	0.74	2.0			43	98	94	3
	2	967.67	0.88	131	66.1	0.76	2.1			46	102	96	3
	3	975.46	0.82	133	63.9	0.73	1.9			53	102	97	3
	4	983.44	0.88	133	66.2	0.75	2.1			48	102	97	3
	5	990.85	0.70	133	59.1	0.67	1.7			48	103	98	3
	6	997.775	0.65	132	56.9	0.65	1.5			49	102	98	3
		(Net Vol. Uncorr.)		Avg.									


K-Factor: 0.5639  
Nozzle Diameter: 0.219 "  
Barometric Pressure: 29.87 "HgA  
Static Pressure in Stack: +10 0.36 "H<sub>2</sub>O

Canister #: \_\_\_\_\_ Start: \_\_\_\_\_ "Hg vac

Recorded By: RL  
Pitot Factor: 0.84

**Calibration Data**

Inclined Manometer	<u>✓</u>	(Cal: <u>N/A</u> )
Magnehelic No.	<u>N/A</u>	(Cal: _____)
Pitot Tube No.	<u>NO412</u>	(Cal: <u>7/10/13</u> )
Potentiometer No.	<u>NO313</u>	(Cal: <u>6/21/13</u> )
Thermocouple No.	<u>NO17</u>	(Cal: <u>6/21/13</u> )
Gas Meter No.	<u>NO713</u>	(Cal: <u>6/21/13</u> )
Meter Corr. Factor:	<u>1.0085</u>	



Sampling Probe: Stainless Steel / Borosilicate / Quartz

Stack: Horizontal / Vertical Rectangular / Circular

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-52-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**South Coast Air Quality Management District**

Test No. 13-308 Company: Exide Technologies Date: 8-23-13  
Sampling Location: Soft Land Baghouse exhaust stack Sample Train: 18

**Traverse Source Test Data**

Pre-Test Leak Check: Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 1001 cfm @ 15 "Hg vac  
Pitot Tube Leak Check: Pass Fail

Post-Test Leak Check: Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 0 cfm @ 6 "Hg vac  
Pitot Tube Leak Check: Pass Fail

Time	Sample Point #	Gas Meter Reading (dcf) Start: <u>304.972</u>	Stack		Calculated			Probe Temp. °F	Filter Temp. °F	Imp. Temp. °F	Meter Temp. °F		Vacuum "Hg
			Velocity Head (H <sub>2</sub> O)	Temp. °F	Velocity (fps)	Sampling Rate (cfm)	Orifice ΔP (H <sub>2</sub> O)				In	Out	
	0910	1	352.875	0.66	116	56.54	0.816	2.26		45	91	87	6
		2	361.225	0.64	118	55.78	0.802	2.21		48	97	90	6
		3	369.510	0.60	118	54.00	0.776	2.10		49	103	91	6
		4	378.700	0.60	118	54.00	0.776	2.11		48	105	93	6
		5	386.600	0.53	118	50.76	0.730	1.89		53	109	95	5.5
		6	393.035	0.35	116	41.18	0.594	1.25		46	107	96	4.5
	1015	7	400.720	0.57	118	52.64	0.757	2.00		52	100	96	6
		8	408.950	0.58	120	53.20	0.762	2.05		45	104	96	6
		9	417.235	0.54	121	51.37	0.735	1.91		42	106	96	5.5
		10	425.330	0.55	121	51.84	0.741	1.96		51	108	98	5.5
		11	432.970	0.48	122	48.47	0.692	1.71		51	108	97	5.5
		12	440.270	0.48	122	48.47	0.692	1.71		47	108	98	5.5
	11:23	13	447.890	0.63	122	55.53	0.793	2.21		51	101	97	6.0
		14	457.000	0.63	122	55.53	0.793	2.21		54	104	97	6.0
		15	465.445	0.55	123	51.93	0.740	1.95		46	106	97	6.0
		16	473.895	0.55	124	51.97	0.739	1.94		48	106	97	6.0
		17	480.055	0.45	124	47.01	0.669	1.59		53	105	97	5.0
		18	486.927	0.35	125	41.49	0.589	1.24		53	107	98	4.5
		19	494.620	0.58	127	53.51	0.757	2.04		46	105	100	5.5
		20	502.700	0.50	128	49.72	0.703	1.77		50	109	101	5.5
		21	510.365	0.48	128	48.72	0.688	1.70		47	109	101	5.5
		22	516.900	0.39	129	43.95	0.620	1.38		52	109	101	4.5
		23	524.105	0.45	125	47.05	0.668	1.59		53	106	100	5.0
		24	531.070	0.43	127	46.07	0.652	1.52		52	107	101	5.0

(Net Vol. Uncorr.)

Aug.

54772 - MW  
53397 - T015

Canister #: E3383-T015 Start: \_\_\_\_\_ "Hg vac


K-Factor: 0.5732

Nozzle Diameter: 0.232"  
Barometric Pressure: 29.84" HgA  
Static Pressure in Stack: +16 0.31" H<sub>2</sub>O

Recorded By: W. Stredwick  
Pitot Factor: 0.84

**Calibration Data**

Inclined Manometer	(Cal: N/A)
Magnehelic No.	(Cal: _____)
Pitot Tube No. <u>50415</u>	(Cal: <u>4-12-13</u> )
Potentiometer No. <u>N0314</u>	(Cal: <u>0-21-13</u> )
Thermocouple No. <u>50115</u>	(Cal: <u>4-12-13</u> )
Gas Meter No. <u>N0714</u>	(Cal: <u>0-21-13</u> )
Meter Corr. Factor: <u>1.0021</u>	



Sampling Probe: Stainless Steel Borosilicate Quartz

Stack: Horizontal Vertical Rectangular Circular



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-53-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
TCA TEST DATA SHEET (METHOD 25.1)**

Date: 8/23/13 Page No.: \_\_\_\_\_

Test No.: 13-308 Recorded By: SE

Company/Sampling Location Exide - Hard Lead

Basic and Control Equipment \_\_\_\_\_

Barometric Pressure: 29.87 \*HgA Static Pressure: +10 0.36 \*H<sub>2</sub>O

SAMPLE A			
Tank #: <u>53484</u>	Trap #: _____	Reg. #: _____	
Pre-Test Leak Check:		Gauge Reading: <u>-30</u>	
<input checked="" type="radio"/> Pass / <input type="radio"/> Fail			
Post-Test Leak Check:		Gauge Reading: <u>-3</u>	
<input checked="" type="radio"/> Pass / <input type="radio"/> Fail			
Time	Vacuum (*Hg)	Flow (cc/min)	Comments
<u>9:15 Am</u>	<u>30</u>	<u>0.2</u>	
<u>9:20</u>	<u>30</u>	<u>"</u>	
<u>9:25</u>	<u>29</u>	<u>"</u>	
<u>9:30</u>	<u>26</u>	<u>"</u>	
<u>9:35</u>	<u>22</u>	<u>"</u>	
<u>9:40</u>	<u>15</u>	<u>"</u>	
<u>9:45</u>	<u>8</u>	<u>"</u>	
<u>9:50</u>	<u>3</u>	<u>"</u>	

SAMPLE B			
Tank #: <u>E4234</u>	Vial #: _____	Reg. #: _____	
Pre-Test Leak Check:		Gauge Reading: <u>-30</u>	
<input checked="" type="radio"/> Pass / <input type="radio"/> Fail			
Post-Test Leak Check:		Gauge Reading: <u>2</u>	
<input checked="" type="radio"/> Pass / <input type="radio"/> Fail			
Time	Vacuum (*Hg)	Flow (cc/min)	Comments
<u>9:55</u>	<u>30</u>	<u>0.2</u>	
<u>10:00</u>	<u>29</u>	<u>"</u>	
<u>10:05</u>	<u>28</u>	<u>"</u>	
<u>10:10</u>	<u>26</u>	<u>"</u>	
<u>10:15</u>	<u>23</u>	<u>"</u>	
<u>10:20</u>	<u>16</u>	<u>"</u>	
<u>10:25</u>	<u>10</u>	<u>"</u>	
<u>10:30</u>	<u>2</u>	<u>"</u>	

TCA SAMPLING INTERVAL TABLE (ΔP)

Min. ΔP °F	70	200	400	600	800	1000	1200	1400	1600
15	2.65	2.9							
20	2.20	2.45	2.7						
25	1.90	2.15	2.30	2.70					
30	1.65	1.85	2.00	2.40	2.85				
35	1.40	1.60	1.80	2.10	2.50	2.85			
40	1.20	1.40	1.60	1.90	2.25	2.50	2.95		
45	1.05	1.25	1.40	1.70	2.00	2.25	2.60	3.00	
50	0.95	1.15	1.25	1.50	1.85	2.05	2.40	2.70	
55	0.85	1.05	1.15	1.35	1.65	1.85	2.15	2.45	2.80
60	0.80	0.95	1.05	1.25	1.55	1.70	2.00	2.30	2.55
65	0.70	0.85	0.95	1.15	1.40	1.60	1.90	2.15	2.40
70	0.65	0.80	0.90	1.05	1.30	1.50	1.75	2.00	2.25
75	0.60	0.75	0.80	1.00	1.25	1.40	1.65	1.90	2.15
80	0.55	0.65	0.75	0.90	1.15	1.30	1.55	1.80	2.05
85	0.50	0.60	0.70	0.85	1.10	1.25	1.50	1.75	1.95
90	0.50	0.55	0.65	0.80	1.05	1.25	1.50	1.65	1.90

Revision: April 20, 2011

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-54-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
TCA TEST DATA SHEET (METHOD 25.4)

Date: 8/23/13 Page No.: \_\_\_\_\_  
 Test No.: 13-308 Recorded By: EP  
 Company/Sampling Location Exide - Hard Lead  
 Basic and Control Equipment Blast furnace & Baghouse  
 Barometric Pressure: 29.87 \*HgA Static Pressure: +0.36 \*H<sub>2</sub>O

SAMPLE A			
Tank #:	Trap #:	Reg. #:	
<u>54080</u>			
Pre-Test Leak Check:		Gauge Reading: <u>-30</u>	
<input checked="" type="checkbox"/> Pass / Fail			
Post-Test Leak Check:		Gauge Reading: <u>-2</u>	
<input checked="" type="checkbox"/> Pass / Fail			
Time	Vacuum (*Hg)	Flow (cc/min)	Comments
<u>9:15 Am</u>	<u>30</u>	<u>0.1</u>	
<u>9:20</u>	<u>30</u>	<u>1</u>	
<u>9:30</u>	<u>20</u>	<u>1</u>	
<u>9:40</u>	<u>22</u>	<u>1</u>	
<u>9:50</u>	<u>16</u>	<u>1</u>	
<u>10:00</u>	<u>8</u>	<u>1</u>	
<u>10:15</u>	<u>2</u>	<u>1</u>	

SAMPLE B			
Tank #:	Vial #:	Reg. #:	
Pre-Test Leak Check:		Gauge Reading: _____	
Pass / Fail			
Post-Test Leak Check:		Gauge Reading: _____	
Pass / Fail			
Time	Vacuum (*Hg)	Flow (cc/min)	Comments

TCA SAMPLING INTERVAL TABLE (AP)

Min. \ °F	70	200	400	600	800	1000	1200	1400	1600
15	2.65	2.9							
20	2.20	2.45	2.7						
25	1.90	2.15	2.30	2.70					
30	1.65	1.85	2.00	2.40	2.85				
35	1.40	1.60	1.80	2.10	2.50	2.85			
40	1.20	1.40	1.60	1.90	2.25	2.50	2.95		
45	1.05	1.25	1.40	1.70	2.00	2.25	2.60	3.00	
50	0.95	1.15	1.25	1.50	1.85	2.05	2.40	2.70	
55	0.85	1.05	1.15	1.35	1.65	1.85	2.15	2.45	2.80
60	0.80	0.95	1.05	1.25	1.55	1.70	2.00	2.30	2.55
65	0.70	0.85	0.95	1.15	1.40	1.60	1.90	2.15	2.40
70	0.65	0.80	0.90	1.05	1.30	1.50	1.75	2.00	2.25
75	0.60	0.75	0.80	1.00	1.25	1.40	1.65	1.90	2.15
80	0.55	0.65	0.75	0.90	1.15	1.30	1.55	1.80	2.05
85	0.50	0.60	0.70	0.85	1.10	1.25	1.50	1.75	1.95
90	0.50	0.55	0.65	0.80	1.05	1.25	1.50	1.65	1.90

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-55-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
TCA TEST DATA SHEET (METHOD 25.1)

Date: 8/23/13 Page No.: 2 OF 2  
 Test No.: 13-308 Recorded By: JA  
 Company/Sampling Location: EXIDE - SOFT LEAD B/H EXT  
 Basic and Control Equipment: \_\_\_\_\_  
 Barometric Pressure: 29.87 "HgA Static Pressure: +0.31 "H<sub>2</sub>O

SAMPLE A <u>TO15</u>			
Tank #: <u>53397</u>	Trap #: <u>N/A</u>	Reg. #: _____	
Pre-Test Leak Check:	Gauge Reading: <u>30</u>	<input checked="" type="radio"/> Pass / <input type="radio"/> Fail	
Post-Test Leak Check:	Gauge Reading: <u>2.5</u>	<input checked="" type="radio"/> Pass / <input type="radio"/> Fail	
Time	Vacuum (*Hg)	Flow (cc/min)	Comments
913	30	2.5 ft/h	
927	24	5.6 ft/h	
933	8	3	
942	3	3	
FINISH			

SAMPLE B <u>TOA - FRED GASES</u>			
Tank #: <u>54772</u>	Vial #: <u>N/A</u>	Reg. #: _____	
Pre-Test Leak Check:	Gauge Reading: <u>30</u>	<input checked="" type="radio"/> Pass / <input type="radio"/> Fail	
Post-Test Leak Check:	Gauge Reading: _____	<input checked="" type="radio"/> Pass / <input type="radio"/> Fail	
Time	Vacuum (*Hg)	Flow (cc/min)	Comments
913	30	0.5 ft/h	0.21 pm
927	24	0.21 pm	
933	22	0.3	
948	14	"	
959	10		
1015	2		FINISH

TCA SAMPLING INTERVAL TABLE (ΔP)

Min. Δ °F	70	200	400	600	800	1000	1200	1400	1600
15	2.65	2.9							
20	2.20	2.45	2.7						
25	1.90	2.15	2.30	2.70					
30	1.65	1.85	2.00	2.40	2.85				
35	1.40	1.60	1.80	2.10	2.50	2.85			
40	1.20	1.40	1.60	1.90	2.25	2.50	2.95		
45	1.05	1.25	1.40	1.70	2.00	2.25	2.60	3.00	
50	0.95	1.15	1.25	1.50	1.85	2.05	2.40	2.70	
55	0.85	1.05	1.15	1.35	1.65	1.85	2.15	2.45	2.80
60	0.80	0.95	1.05	1.25	1.55	1.70	2.00	2.30	2.55
65	0.70	0.85	0.95	1.15	1.40	1.60	1.90	2.15	2.40
70	0.65	0.80	0.90	1.05	1.30	1.50	1.75	2.00	2.25
75	0.60	0.75	0.80	1.00	1.25	1.40	1.65	1.90	2.15
80	0.55	0.65	0.75	0.90	1.15	1.30	1.55	1.80	2.05
85	0.50	0.60	0.70	0.85	1.10	1.25	1.50	1.75	1.95
90	0.50	0.55	0.65	0.80	1.05	1.25	1.50	1.65	1.90

Revision: April 29, 2011

Page 5

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-56-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

~~METHOD 3~~ TEST DATA SHEET

Date: 8/23/13 ~~METHOD 3~~ TO-15 Page No.: 1 of 2  
 Test No.: 13-308 Recorded By: JA  
 Company/Sampling Location EXIDE - SOFT LEAD B/H EXH  
 Basic and Control Equipment \_\_\_\_\_  
 Barometric Pressure: 29.87 "HgA Static Pressure: +10 0.31 "H<sub>2</sub>O

SAMPLE A TO15			
Tank #: <u>E3383</u>		Vial #: <u>N/A</u>	Reg. #: _____
Pre-Test Leak Check:		Gauge: <u>30</u>	_____
		<del>Pass</del> / Fail	_____
Post-Test Leak Check:		Gauge: _____	_____
		Pass / Fail	_____
Time	Vacuum ("Hg)	Flow (cc/min)	Comments
<u>948</u>	<u>30</u>	<u>3 sc/h</u>	
<u>959</u>	<u>22</u>	<u>3</u>	
<u>1015</u>	<u>2</u>		<u>FINISHED</u>

SAMPLE B			
Tank #: _____		Vial #: _____	Reg. #: _____
Pre-Test Leak Check:		Gauge: _____	_____
		Pass / Fail	_____
Post-Test Leak Check:		Gauge: _____	_____
		Pass / Fail	_____
Time	Vacuum ("Hg)	Flow (cc/min)	Comments

Approximate Time To Fill Tank (minutes)	20	30	40	50	60	90	120
ΔP Setting	62	30	21	14	8	5	2
	(max.)						



**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-57-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**South Coast Air Quality Management District**

Test No. 13-308 Company: ENVIXE TECHNOLOGIES Date: 9/20/13  
Sampling Location: HARD LEAD 13/H Sample Train: #5

**Traverse Source Test Data**

Pre-Test Leak Check: Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 0.013 cfm @ 15 "Hg vac  
Pitot Tube Leak Check: Pass / Fail

Post-Test Leak Check: Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 0.013 cfm @ 10 "Hg vac  
Pitot Tube Leak Check: Pass / Fail

Time	Sample Point #	Gas Meter Reading (dcf)	Stack		Calculated			Probe Temp. °F	Filter Temp. °F	Imp. Temp. °F	Meter Temp. °F		Vacuum "Hg
			Velocity Head ("H <sub>2</sub> O)	Temp. °F	Velocity (fps)	Sampling Rate (cfm)	Orifice ΔP ("H <sub>2</sub> O)				In	Out	
W	1	17.75	0.83	108	63.0	.75	1.85			45	69	68	3
	2	24.80	0.73	110	59.2	.71	1.64			49	73	70	3
	3	32.0	0.69	110	57.5	.69	1.56			48	76	71	3
	4	38.95	0.65	110	55.8	.67	1.48			48	78	72	3
	5	45.40	0.53	110	50.4	.60	1.21			41	79	74	3
	6	51.801	0.57	110	52.3	.62	1.31			42	80	74	3
S	1	60.25	0.97	109	68.1	.83	2.22			44	78	75	4
	2	68.45	0.93	111	66.8	.80	2.14			42	81	76	4
	3	76.51	0.88	112	65.1	.77	2.03			42	83	77	4
	4	84.54	0.86	112	64.3	.77	2.00			49	84	78	4
	5	92.10	0.76	112	60.5	.72	1.77			48	84	79	4
	6	98.296	0.54	112	51.9	.61	1.26			44	84	79	4
E	1	106.95	1.05	100	70.9	.85	2.41			43	78	77	5
	2	115.65	1.07	112	71.7	.85	2.47			43	82	78	5
	3	124.78	1.08	113	72.1	.86	2.51			47	84	79	6
	4	133.35	0.96	113	68.0	.81	2.24			45	86	80	5
	5	141.15	0.84	114	63.7	.76	1.96			47	87	81	3
	6	148.279	0.67	114	56.9	.67	1.57			44	87	82	3
N	1	157.28	1.05	111	71.0	.85	2.46			47	85	82	6
	2	165.93	1.05	113	71.1	.85	2.46			43	86	82	5
	3	174.43	0.96	114	68.1	.81	2.26			48	88	83	5
	4	182.64	0.87	115	64.9	.77	2.05			41	90	83	5
	5	190.33	0.81	114	62.5	.74	1.91			43	89	84	3
	6	197.668	0.72	114	59.0	.70	1.70			44	89	84	3
1:15 stop													

(Net Vol. Uncorr.)

Avg.


K-Factor: 0.5639 Stack Moisture: 1.5 Canister #: \_\_\_\_\_ Start: \_\_\_\_\_ "Hg vac

Nozzle Diameter: 0.720 "  
Barometric Pressure: 29.74 "HgA  
Static Pressure in Stack: +10 0.34 "H<sub>2</sub>O

Recorded By: EC  
Pitot Factor: 0.84

**Calibration Data**

Inclined Manometer	✓	(Cal: N/A)
Magnehelic No.	N/A	(Cal: )
Pitot Tube No.	50413	(Cal: 6/12/10)
Potentiometer No.	N0313	(Cal: 6/21/12)
Thermocouple No.	N0113	(Cal: 6/21/13)
Gas Meter No.	N0713	(Cal: 6/21/13)
Meter Corr. Factor:	1.0085	



Sampling Probe: Stainless Steel / Borosilicate / Quartz

Stack: Horizontal / Vertical Rectangular / Circular

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-58-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**South Coast Air Quality Management District**

Test No. 13308 Company: Exide Technologies Date: 9-20-13  
Sampling Location: Soft Lead Exhaust Stack Sample Train: 4

**Traverse Source Test Data**

Pre-Test Leak Check: Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 0 cfm @ 15 "Hg vac  
Pitot Tube Leak Check: Pass / Fail

Post-Test Leak Check: Filter: \_\_\_\_\_ cfm @ \_\_\_\_\_ "Hg vac  
Probe: 0 cfm @ 6 "Hg vac  
Pitot Tube Leak Check: Pass / Fail

Time	Sample Point #	Gas Meter Reading (dcf)	Stack		Calculated			Probe Temp. °F	Filter Temp. °F	Imp. Temp. °F	Meter Temp. °F		Vacuum "Hg
			Velocity Head ("H <sub>2</sub> O)	Temp. °F	Velocity (fps)	Sampling Rate (cfm)	Orifice ΔP ("H <sub>2</sub> O)				In	Out	
9:04	1	548.750	0.66	108	56.15	0.667	1.45			44	79	79	5.0
	2	555.515	0.66	109	56.20	0.666	1.46			42	81	79	5.0
	3	562.405	0.60	111	53.68	0.634	1.33			35	85	79	5.0
	4	569.100	0.65	111	55.87	0.660	1.45			42	88	79	5.0
	5	574.900	0.48	111	48.01	0.567	1.08			45	90	81	4.0
	6	580.958	0.44	110	45.93	0.544	0.99			37	90	81	4.0
10:06	7	587.970	0.62	112	54.61	0.644	1.38			39	87	82	5.0
	8	594.675	0.60	114	53.82	0.633	1.35			45	91	83	5.0
	9	601.250	0.65	115	56.06	0.659	1.46			51	92	84	5.0
	10	607.710	0.57	115	52.50	0.616	1.29			46	94	85	4.5
	11	614.320	0.55	115	51.57	0.605	1.25			51	94	86	4.5
	12	620.646	0.55	117	51.66	0.604	1.25			50	95	86	4.5
11:10	13	628.040	0.79	117	61.92	0.724	1.76			52	88	85	6.0
	14	635.315	0.76	117	60.73	0.710	1.70			48	92	85	6.0
	15	642.825	0.72	117	59.11	0.691	1.63			45	96	86	5.5
	16	649.830	0.65	120	56.31	0.655	1.47			54	97	87	5.0
	17	656.135	0.58	120	53.19	0.619	1.32			41	98	88	4.5
	18	661.265	0.35	110	40.96	0.485	0.81			49	96	89	3.0
12:15	19	668.390	0.70	121	58.48	0.679	1.56			47	91	87	5.0
	20	675.655	0.67	124	57.36	0.663	1.50			51	95	88	5.0
	21	682.680	0.62	125	55.23	0.637	1.40			48	96	89	5.0
	22	689.345	0.57	125	52.96	0.611	1.29			45	98	90	5.0
	23	695.555	0.52	123	50.49	0.584	1.18			50	98	90	4.5
	24	701.760	0.52	122	50.45	0.585	1.18			51	98	90	4.5

(Net Vol. Uncorr.)

Avg.

K-Factor: 0.5732

Canister #: 54731 Start: 30" "Hg vac

Nozzle Diameter: 0.219 "

Recorded By: W.S.


Barometric Pressure: 29.94 "HgA

Pitot Factor: 0.84

Static Pressure in Stack: +0.35 "H<sub>2</sub>O

**Calibration Data**

Inclined Manometer	(Cal: N/A)
Magnetic No. <u>10102</u>	(Cal: <u>712113</u> )
Pitot Tube No. <u>N0412</u>	(Cal: <u>612113</u> )
Potentiometer No. <u>N0314</u>	(Cal: <u>612113</u> )
Thermocouple No. <u>N0112</u>	(Cal: <u>612113</u> )
Gas Meter No. <u>N0714</u>	(Cal: <u>612113</u> )
Meter Corr. Factor: <u>1.0021</u>	



Sampling Probe: Stainless Steel (Borosilicate) Quartz

Stack: Horizontal Vertical Rectangular Circular

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-59-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
TCA TEST DATA SHEET

Date: 9/20/13 Page No.: \_\_\_\_\_  
 Test No.: 13308 Recorded by: ST  
 Company/Sampling Location: Exide Soft lead  
 Basic and Control Equipment: \_\_\_\_\_

Pined Gas SAMPLE A

Tank # 54731 Trap # \_\_\_\_\_ Control # \_\_\_\_\_  
 Pre-Test Leak Check: Gauge -30  
 Δ P \_\_\_\_\_  
 Post-Test Leak Check: Gauge -2  
 Δ P \_\_\_\_\_  
 Barometric Pressure 29.44 "HgA

10-15 SAMPLE B

Tank # E4224 Trap # \_\_\_\_\_ Control # \_\_\_\_\_  
 Pre-Test Leak Check: Gauge -30  
 Δ P \_\_\_\_\_  
 Post-Test Leak Check: Gauge -1  
 Δ P \_\_\_\_\_  
 Static Pressure \_\_\_\_\_ "HgA ( $\pm 0.35$  "H<sub>2</sub>O)

TIME	VACUUM ("Hg)	FLOW (cc/min)	COMMENTS
<u>10:00 AM</u>	<u>30</u>	<u>0.1</u>	
<u>10:15</u>	<u>25</u>	<u>"</u>	
<u>10:30</u>	<u>20</u>	<u>"</u>	
<u>10:45</u>	<u>10</u>	<u>"</u>	
<u>11:00</u>	<u>2</u>	<u>"</u>	

TIME	VACUUM ("Hg)	FLOW (cc/min)	COMMENTS
<u>10:00 AM</u>	<u>30</u>	<u>0.1</u>	
<u>10:15</u>	<u>21</u>	<u>"</u>	
<u>10:30</u>	<u>12</u>	<u>"</u>	
<u>10:45</u>	<u>8</u>	<u>"</u>	
<u>11:00</u>	<u>1</u>	<u>"</u>	

TCA SAMPLING INTERVAL TABLE (Δ P)

Min.	0F	70	200	400	600	800	1000	1200	1400	1600
15	2.65	2.90								
20	2.20	2.45	2.70							
25	1.90	2.15	2.30	2.70						
30	1.65	1.85	2.00	2.40	2.85					
35	1.40	1.60	1.80	2.10	2.50	2.85				
40	1.20	1.40	1.60	1.90	2.25	2.50	2.95			
45	1.05	1.25	1.40	1.70	2.00	2.25	2.60	3.00		
50	0.95	1.15	1.25	1.50	1.85	2.05	2.40	2.70		
55	0.85	1.05	1.15	1.35	1.65	1.85	2.15	2.45	2.80	
60	0.80	0.95	1.05	1.25	1.55	1.70	2.00	2.30	2.65	
65	0.70	0.85	0.95	1.15	1.40	1.60	1.90	2.15	2.40	
70	0.65	0.80	0.90	1.05	1.30	1.50	1.75	2.00	2.25	
75	0.60	0.75	0.80	1.00	1.25	1.40	1.65	1.90	2.15	
80	0.65	0.65	0.75	0.90	1.15	1.30	1.55	1.80	2.05	
85	0.50	0.60	0.70	0.85	1.10	1.25	1.50	1.75	1.95	
90	0.50	0.55	0.65	0.80	1.05	1.25	1.50	1.65	1.90	



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-60-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
**TCA TEST DATA SHEET (METHOD 25.1)**

Date: 9/20/13 Page No.: \_\_\_\_\_  
 Test No.: \_\_\_\_\_ Recorded By: CW  
 Company/Sampling Location: Exide  
 Basic and Control Equipment: Hard head  
 Barometric Pressure: 29.44 "HgA Static Pressure: + 0.34 "H<sub>2</sub>O

SAMPLE A				SAMPLE B			
Tank #: <u>5A775</u> Trap #: _____		Reg. #: _____		Tank #: <u>EH281</u> Vial #: _____		Reg. #: _____	
Pre-Test Leak Check:		Gauge Reading: <u>30"</u>		Pre-Test Leak Check:		Gauge Reading: <u>30"</u>	
		<input checked="" type="radio"/> Pass / Fail				<input checked="" type="radio"/> Pass / Fail	
Post-Test Leak Check:		Gauge Reading: <u>2"</u>		Post-Test Leak Check:		Gauge Reading: <u>2"</u>	
		<input checked="" type="radio"/> Pass / Fail				<input checked="" type="radio"/> Pass / Fail	
Time	Vacuum (*Hg)	Flow (cc/min)	Comments	Time	Vacuum (*Hg)	Flow (cc/min)	Comments
<u>9:00am</u>	<u>30</u>	<u>0.1</u>		<u>10:00am</u>	<u>30</u>	<u>0.1</u>	
<u>9:14</u>	<u>25</u>			<u>10:10</u>	<u>27</u>		
<u>9:24</u>	<u>18</u>			<u>10:20</u>	<u>22</u>		
<u>9:34</u>	<u>13</u>			<u>10:30</u>	<u>19</u>		
<u>9:44</u>	<u>7</u>			<u>10:40</u>	<u>14</u>		
<u>9:54</u>	<u>4</u>			<u>10:50</u>	<u>8</u>		
<u>10:04</u>	<u>2</u>			<u>11:00</u>	<u>3</u>		

TCA SAMPLING INTERVAL TABLE (ΔP)

Min. \ °F	70	200	400	600	800	1000	1200	1400	1600
15	2.65	2.9							
20	2.20	2.45	2.7						
25	1.90	2.15	2.30	2.70					
30	1.65	1.85	2.00	2.40	2.85				
35	1.40	1.60	1.80	2.10	2.50	2.85			
40	1.20	1.40	1.60	1.90	2.25	2.50	2.95		
45	1.05	1.25	1.40	1.70	2.00	2.25	2.60	3.00	
50	0.95	1.15	1.25	1.50	1.85	2.05	2.40	2.70	
55	0.85	1.05	1.15	1.35	1.65	1.85	2.15	2.45	2.80
60	0.80	0.95	1.05	1.25	1.55	1.70	2.00	2.30	2.55
65	0.70	0.85	0.95	1.15	1.40	1.60	1.90	2.15	2.40
70	0.65	0.80	0.90	1.05	1.30	1.50	1.75	2.00	2.25
75	0.60	0.75	0.80	1.00	1.25	1.40	1.65	1.90	2.15
80	0.55	0.65	0.75	0.90	1.15	1.30	1.55	1.80	2.05
85	0.50	0.60	0.70	0.85	1.10	1.25	1.50	1.75	1.95
90	0.50	0.55	0.65	0.80	1.05	1.25	1.50	1.65	1.90

Revision: April 20, 2011

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-61-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**PROPRIETARY PROCESS INFORMATION  
REDACTED FOR PUBLIC DISTRIBUTION**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-62-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**PROPRIETARY PROCESS INFORMATION  
REDACTED FOR PUBLIC DISTRIBUTION**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-63-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**PROPRIETARY PROCESS INFORMATION  
REDACTED FOR PUBLIC DISTRIBUTION**

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-64-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**APPENDIX B**

Process Data



Appendix B has been removed from this file because it may contain proprietary information.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-117-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**APPENDIX C**

Calibration Records

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-118-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
PITOT TUBE CALIBRATION

Date : 8-6-13  
Calibrated by : T. Nguyen  
At : HQ

S-Type STQC# : 30403

Standard S/N : N/R  
Cp (STD): 0.99  
OD : 3/8" Length : 4 ft

OD : 3/8" Length : 8'

A-Side Calibration				
ΔP STD (in.H2O)	ΔP (in.H2O) S	Cp (S)	Dev.	95% CI
Geometrical check is OK				
Average : $\bar{C}_p$ (A)		0.84		

B-Side Calibration				
ΔP STD (in.H2O)	ΔP (in.H2O) S	Cp (S)	Dev.	95% CI
Average : $\bar{C}_p$ (B)				

$$C_p (S) = C_p (STD) \sqrt{\frac{\Delta P_{STD}}{\Delta P_S}}$$
 Remarks:

$$Dev. = C_p (S) - \bar{C}_p \quad ( \text{ must be } < 0.01 )$$

$$\bar{C}_p (A) - \bar{C}_p (B) = \dots \quad ( \text{ must be } < 0.01 )$$

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-119-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
DRY GAS METER CALIBRATION WORKSHEET

Page 1

SOUTH COAST  
DRY GAS MET

DATE: 06/21/2013  
 AMBIENT AIR 75 o F  
 PBAR: 29.34 In.Hg  
 PERFORMED BY: T. Nguyen  
 DRY GAS METER ID : N0713  
 DRY GAS MET

STANDARD DRY GAS METER ID#: 7812470  
 STANDARD DI  
 With 1

TRIAL	CFM	TOTAL TEMP cubicF	H2O PRESSURE		H2O	METER (in cubic F)			TOTAL cubicF	HRS	MIN	SEC	TIME Decimal	UC FL RT CFM	TRIAL	CFM
			IN	OUT		READ1	READ2									
1	1/4	5.9	75	2	2	2.0	166.6	172.5	5.9	23	51	32	23.86	0.2473	1	1/4
2	1/4	5.3	75	2	2	2.0	172.6	177.9	5.3	21	30	57	21.51	0.2464	2	1/4
3	1/4	12.4	75	2	2	2.0	178.0	190.4	12.4	50	22	28	50.37	0.2462	3	1/4
1	1/2	10.0	76	2.2	2.2	2.2	631.7	641.7	10.0	18	8	37	18.14	0.5513	1	1/2
2	1/2	12.0	76	2.2	2.2	2.2	641.8	653.8	12.0	21	47	10	21.79	0.5508	2	1/2
3	1/2	23.0	76	2.2	2.2	2.2	663.9	686.9	23.0	41	34	87	41.58	0.5531	3	1/2
1	3/4	11.7	72	2.6	2.6	2.6	241.4	253.1	11.7	12	15	07	12.25	0.9550	1	3/4
2	3/4	25.2	72	2.6	2.6	2.6	263.2	278.4	25.2	26	23	56	26.39	0.9548	2	3/4
3	3/4	11.3	72	2.6	2.6	2.6	278.6	289.9	11.3	11	50	03	11.83	0.9549	3	3/4
1	1	12.0	75	2.4	2.4	2.4	301.6	313.6	12.0	15	55	09	15.92	0.7539	1	1
2	1	7.9	75	2.4	2.4	2.4	313.7	321.6	7.9	10	28	53	10.48	0.7541	2	1
3	1	10.4	75	2.4	2.4	2.4	321.7	332.1	10.4	13	48	13	13.80	0.7535	3	1

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
DRY GAS METER CALIBRATION WORKSHEET

Page 2

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-120-

Date(s): 8/8/13, 8/23/13 and 9/20/13

PERFORMED BY: T. Nguyen

DATE: 06/21/2013

DRY GAS METER ID : N0713

TRIAL	CFM	TOTAL TEMP cubicF	H2O PRESSURE			H2O	METER		CubicF	HRS	MIN	SEC	TIME Decimal	UC FL RT CFM
			IN	OUT	READ1 (in cubic F)		READ2 (in cubic F)							
1	1/4	5.7	75	1.8	1.5	1.7	219.5	225.2	5.7	23	10.71	23.18	0.2459	
2	1/4	5.6	75	1.8	1.5	1.7	225.3	230.9	5.6	22	55.89	22.93	0.2442	
3	1/4	12.2	75	1.8	1.5	1.7	231.0	243.2	12.2	49	59.81	50.00	0.2440	
1	1/2	10.0	75	2.2	1.0	1.6	584.1	594.1	10.0	18	14.18	18.24	0.5484	
2	1/2	12.0	75	2.2	1.0	1.6	584.2	606.2	12.0	21	52.63	21.88	0.5485	
3	1/2	10.1	75	2.2	1.0	1.6	606.1	616.2	10.1	18	20.81	18.35	0.5505	
1	3/4	11.7	75	1.5	0.0	0.8	87.0	98.7	11.7	12	18.38	12.31	0.9507	
2	3/4	24.9	75	1.5	0.0	0.8	99.0	123.9	24.9	26	12.31	26.21	0.9502	
3	3/4	11.2	75	1.5	0.0	0.8	124.0	135.2	11.2	11	46.37	11.77	0.9513	
1	1	11.9	75	0.9	0.0	0.5	147.0	158.9	11.9	15	47.82	15.80	0.7533	
2	1	7.8	75	0.9	0.0	0.5	159.2	167.0	7.8	10	21.99	10.37	0.7524	
3	1	10.4	75	0.9	0.0	0.5	167.1	177.5	10.4	13	48.95	13.62	0.7528	

DATE: 06/21/2013

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-121-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
CALIBRATION WORKSHEET

Page 3

DATE: 06/21/2013  
PERFORMED BY: T.Nguyen

COEFFICIENT CALCULATIONS

DRY GAS METER ID#: 7812470      DRY GAS METER ID: N0713  
Coefficient of 1.0000

U/C FlowRate	TEMP	H2O	Corrected FlowRate	U/C FlowRate	TEMP	H2O	Corrected FlowRate	COEF	AVE:	OVERALL
0.2473	75	2	0.2369	0.2459	75	1.65	0.2354	1.0066	1.0087	1.0085
0.2464	75	2	0.2360	0.2442	75	1.65	0.2337	1.0099		
0.2462	75	2	0.2358	0.2440	75	1.65	0.2335	1.0097		
0.5513	76	2.2	0.5274	0.5484	75	1.6	0.5247	1.0050	1.0044	
0.5508	76	2.2	0.5269	0.5485	75	1.6	0.5249	1.0039		
0.5531	76	2.2	0.5291	0.5505	75	1.6	0.5268	1.0044		
0.9550	72	2.6	0.9213	0.9507	75	0.75	0.9079	1.0148	1.0147	
0.9548	72	2.6	0.9211	0.9502	75	0.75	0.9074	1.0152		
0.9549	72	2.6	0.9212	0.9513	75	0.75	0.9084	1.0141		
0.7539	75	2.4	0.7228	0.7533	75	0.45	0.7188	1.0056	1.0062	
0.7541	75	2.4	0.7231	0.7524	75	0.45	0.7180	1.0072		
0.7535	75	2.4	0.7225	0.7528	75	0.45	0.7183	1.0059		

DRY GAS METER ID: N0713      CORRECTION FACTOR: 1.0085  
DATE: 06/21/2013

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-122-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
DRY GAS METER CALIBRATION WORKSHEET

Page 1

DATE: 06-21-2013  
 AMBIENT AIR: 75 o F  
 PBAR: 29.34 In.Hg  
 PERFORMED BY: T.Nguyen  
 DRY GAS METER ID : N0714

7812470

STANDARD DRY GAS METER ID#:

TRIAL	CFM	TOTAL cubicF	TEMP	H2O PRESSURE			METER			TOTAL cubicF	HRS	MIN	SEC	TIME Decimal	UC FL RT CFM
				IN	OUT	H2O	READ1 (in cubic F)	READ2							
1	1/4	6.9	76	1.1	1.1	1.1	486.6	493.5	6.9	24	10.74	24.18	0.2854		
2	1/4	11.1	76	1.1	1.1	1.1	493.6	504.7	11.1	38	58.06	38.37	0.2849		
3	1/4	10.3	76	1.1	1.1	1.1	504.8	515.1	10.3	36	2.46	36.04	0.2858		
1	1/2	10.0	76	2.2	2.2	2.2	631.7	641.7	10.0	18	8.37	18.14	0.5513		
2	1/2	12.0	76	2.2	2.2	2.2	641.8	653.8	12.0	21	47.10	21.79	0.5508		
3	1/2	23.0	76	2.2	2.2	2.2	663.9	686.9	23.0	41	34.87	41.58	0.5531		
1	3/4	15.9	76	5	5	5.0	782.8	798.7	15.9	20	10.21	20.17	0.7883		
2	3/4	19.9	76	5	5	5.0	798.8	818.7	19.9	25	12.80	25.21	0.7893		
3	3/4	12.8	76	5	5	5.0	818.8	831.6	12.8	16	13.00	16.22	0.7893		
1	1	7.4	76	9.2	9.2	9.2	833.0	840.4	7.4	6	47.24	6.79	1.0903		
2	1	9.1	76	9.2	9.2	9.2	840.7	849.8	9.1	8	19.16	8.32	1.0938		
3	1	6.2	76	9.2	9.2	9.2	850.0	856.2	6.2	5	41.82	5.70	1.0883		

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
DRY GAS METER CALIBRATION WORKSHEET

Page 2

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-123-

Date(s): 8/8/13, 8/23/13 and 9/20/13

PERFORMED BY: T. Nguyen

DATE: 06-21-2013

DRY GAS METER ID : N0714

TRIAL	CFM	TOTAL cubicF	TEMP	H2O PRESSURE		H2O	METER READ1 READ2 (in cubic F)		CubicF	HRS	MIN	SEC	TIME Decimal	UC FL RT CFM
				IN	OUT		READ1	READ2						
1	1/4	7.1	76	1.0	0.2	0.6	538.9	546.0	7.1	24	50.08	24.83	0.2859	
2	1/4	11.1	76	1.0	0.2	0.6	546.1	557.2	11.1	38	52.56	38.88	0.2855	
3	1/4	10.2	76	1.0	0.2	0.6	557.3	567.5	10.2	35	43.24	35.72	0.2855	
1	1/2	10.0	76	2.2	1.0	1.6	584.1	594.1	10.0	18	14.18	18.24	0.5484	
2	1/2	12.0	76	2.2	1.0	1.6	594.2	606.2	12.0	21	52.63	21.88	0.5485	
3	1/2	10.1	76	2.2	1.0	1.6	606.1	616.2	10.1	18	20.81	18.35	0.5505	
1	3/4	16.0	76	5.0	2.0	3.5	334.8	350.8	16.0	20	21.38	20.36	0.7860	
2	3/4	19.8	76	5.0	2.0	3.5	350.9	370.7	19.8	25	10.82	25.18	0.7863	
3	3/4	12.9	76	5.0	2.0	3.5	370.7	383.6	12.9	16	23.34	16.39	0.7871	
1	1	7.8	76	9.0	4.1	6.6	384.9	392.7	7.8	7	4.86	7.08	1.1015	
2	1	9.2	76	9.0	4.1	6.6	392.9	402.1	9.2	8	20.17	6.34	1.1036	
3	1	6.0	76	9.0	4.1	6.6	402.5	408.5	6.0	5	26.60	5.44	1.1023	

DATE: 06-21-2013



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-124-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
DRY GAS METER CALIBRATION WORKSHEET

Page 3

DATE: 06-21-2013  
PERFORMED BY: T.Nguyen

DRY GAS METER COEFFICIENT CALCULATIONS

STANDARD DRY GAS METER ID#: 7812470      DRY GAS METER ID: N0714  
With Coefficient of 1.0000

TRIAL	CFM	U/C	U/C	FlowRate	TEMI	H2O	Corrected	U/C	FlowRate	TEMP	H2O	Corrected	COEF	AVE:	OVERALL
							FlowRate					FlowRate			
1	1/4	0.2854	76	1.1	0.2722	0.2859	76	0.6	0.2724	0.9994	1.0001	1.0023			
2	1/4	0.2849	76	1.1	0.2717	0.2855	76	0.6	0.2720	0.9989					
3	1/4	0.2858	76	1.1	0.2726	0.2855	76	0.6	0.2721	1.0021					
1	1/2	0.5513	76	2.2	0.5274	0.5484	76	1.6	0.5238	1.0068	1.0063				
2	1/2	0.5508	76	2.2	0.5269	0.5485	76	1.6	0.5239	1.0057					
3	1/2	0.5531	76	2.2	0.5281	0.5505	76	1.6	0.5258	1.0063					
1	3/4	0.7883	76	5	0.7593	0.7860	76	3.5	0.7543	1.0057	1.0069				
2	3/4	0.7893	76	5	0.7603	0.7863	76	3.5	0.7546	1.0075					
3	3/4	0.7893	76	5	0.7603	0.7871	76	3.5	0.7554	1.0065					
1	1	1.0803	76	9.2	1.0611	1.1015	76	6.55	1.0651	0.9962	0.9959				
2	1	1.0838	76	9.2	1.0646	1.1036	76	6.55	1.0672	0.9976					
3	1	1.0883	76	9.2	1.0692	1.1023	76	6.55	1.0658	0.9938					

DRY GAS METER ID: N0714      CORRECTION FACTOR: 1.0023  
DATE: 06-21-2013

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-125-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
PITOT TUBE CALIBRATION

Date : 7-2-13  
Calibrated by : FN  
At : file

S-Type STQC# : N0412  
OD : 7/8 Length : 6'

Standard S/N : \_\_\_\_\_  
Cp (STD): 0.99  
OD : 3/8" Length : 4 ft

A-Side Calibration				
ΔP (in.H2O) STD	ΔP (in.H2O) S	Cp (S)	Dev.	95% CI
Geometrical check is ok				
Average : $\bar{Cp}$ (A)		0.84		

B-Side Calibration				
ΔP (in.H2O) STD	ΔP (in.H2O) S	Cp (S)	Dev.	95% CI
Average : $\bar{Cp}$ (B)				

$$Cp (S) = Cp (STD) \sqrt{\frac{\Delta P_{STD}}{\Delta P_S}}$$
 Remarks:

$$Dev. = Cp (S) - \bar{Cp} \quad (\text{must be } < 0.01)$$

$$\bar{Cp} (A) - \bar{Cp} (B) = \underline{\hspace{2cm}} \quad (\text{must be } < 0.01)$$

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-126-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
PITOT TUBE CALIBRATION

Date : 2-22-13  
Calibrated by : T. Nguyen  
At : HQ

S-Type STQC# : 40413  
OD : 3/8 Length : 41

Standard S/N : \_\_\_\_\_  
Cp (STD): 0.99  
OD : 3/8" Length : 4 ft

A-Side Calibration				
ΔP STD (in.H2O)	ΔP (in.H2O) S	Cp (S)	Dev.	95% CI
	Geometrical Check is OK			
Average : $\bar{C}_p$ (A)		0.84		

B-Side Calibration				
ΔP STD (in.H2O)	ΔP (in.H2O) S	Cp (S)	Dev.	95% CI
Average : $\bar{C}_p$ (B)				

$$C_p (S) = C_p (STD) \sqrt{\frac{\Delta P_{STD}}{\Delta P_S}} \quad \text{Remarks:}$$

$$Dev. = C_p (S) - \bar{C}_p \quad ( \text{ must be } < 0.01 )$$

$$\bar{C}_p (A) - \bar{C}_p (B) = \underline{\hspace{2cm}} \quad ( \text{ must be } < 0.01 )$$

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-127-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
PITOT TUBE CALIBRATION

Date : 4-12-13  
Calibrated by : TN  
At : HR

S-Type STQC# : 50415  
OD : 3/8 Length : 6'

Standard S/N : \_\_\_\_\_  
Cp (STD): 0.99  
OD : 3/8" Length : 4 ft

A-Side Calibration				
ΔP STD (in.H2O)	ΔP (in.H2O) S	Cp (S)	Dev.	95% CI
Geometrical Check				
is OK				
Average : $\bar{C}_p$ (A)		0.84		

B-Side Calibration				
ΔP STD (in.H2O)	ΔP (in.H2O) S	Cp (S)	Dev.	95% CI
Average : $\bar{C}_p$ (B)				

$$C_p (S) = C_p (STD) \sqrt{\frac{\Delta P_{STD}}{\Delta P_S}} \quad \text{Remarks:}$$

$$\text{Dev.} = C_p (S) - \bar{C}_p \quad (\text{ must be } < 0.01 )$$

$$\bar{C}_p (A) - \bar{C}_p (B) = \underline{\hspace{2cm}} \quad (\text{ must be } < 0.01 )$$

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-128-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
DATA SHEET FOR THERMOCOUPLE/POTENTIOMETER CALIBRATION

Field Meter STQC# : N0311 & N0313  
 Ref. Thermometer # : ASTM 08340  
 Temperature Source(s) : Jama

Date: 6-21-2013  
 Calibration By: J. C. [Signature]  
 Calibration Period:  
 Semiannual   
 Bimonthly \_\_\_\_\_  
 Other \_\_\_\_\_

Temp.*	A	N0311				N0313				COMMENTS
		Lead Wire STQC#		(B-A)100 A **		Lead Wire STQC#		(B-A)100 A **		
		Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2	
N0112	210	211				211				
N0113	210	211				210				
N0116	210	211				211				
S0115	210	210				211				
N0112	410	411				411				
N0113	410	411				410				
N0116	410	412				411				
S0115	410	411				412				
N0112	710	711				712				
N0113	710	710				711				
N0116	710	711				710				
S0115	710	712				711				

All temperatures are in degrees F.  
 \*Percent (%) difference should not exceed +/- 1.5%.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
 21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-129-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
 DATA SHEET FOR THERMOCOUPLE/POTENTIOMETER CALIBRATION

Field Meter STQC# : N0314 & N0315  
 Ref. Thermometer # : ASTMO 340  
 Temperature Source(s) : Japa

Date: 6-21-2013  
 Calibration By: J. Nguyen  
 Calibration Period:  
 Semiannual X  
 Bimonthly \_\_\_\_\_  
 Other \_\_\_\_\_

Temp.*	A	No 314 Lead Wire STQC# <u>NA</u>				No 315 Lead Wire STQC# <u>NA</u>				COMMENTS	
		B		(B-A)100 A **		B		(B-A)100 A **			
		Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2		
Sensor STQC#	Ref. Temp.										
	N0112 210	211				212					
	N0113 210	211				211					
	S0115 210	211				212					
	N0116 210	211				211					
	N0112 410	411				412					
	N0113 410	412				411					
	S0115 410	412				412					
	N0116 410	411				411					
	N0112 710	711				712					
	N0113 710	712				711					
	S0115 710	712				711					
	N0116 710	711				711					

All temperatures are in degrees F.  
 \*Percent (%) difference should not exceed +/- 1.5%.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-130-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
DATA SHEET FOR THERMOCOUPLE/POTENTIOMETER CALIBRATION

Field Meter STQC# : Infrared Ther.  
 Ref. Thermometer # : ASTM 08340  
 Temperature Source(s) : Tofra

Date: July 2, 13  
 Calibration By: TN  
 Calibration Period:  
 Semiannual X  
 Bimonthly \_\_\_\_\_  
 Other \_\_\_\_\_

Temp.*	A	Lead Wire STQC# _____				Lead Wire STQC# _____				COMMENTS
		B		(B-A)100 A **		B		(B-A)100 A **		
		Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2	
<del>I0101</del>	212	212								
<del>I0102</del>	212	212								
<del>I0103</del>	212	211								
<del>I0101</del>	412	411								
<del>I0102</del>	412	412								
<del>I0103</del>	412	413								
<del>I0101</del>	710	711								
<del>I0102</del>	710	712								
<del>I0103</del>	710	710								

\* All temperatures are in degrees F.  
 \*\*Percent (%) difference should not exceed +/- 1.5%.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-131-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
DATA SHEET FOR THERMOCOUPLE/POTENTIOMETER CALIBRATION

Field Meter STQC# : 20304 & C0301  
 Ref. Thermometer # : ASTM 08340  
 Temperature Source(s) : Jafra

Date: 8-6-13  
 Calibration By: T. Nguyen  
 Calibration Period:  
 Semiannual \_\_\_\_\_  
 Bimonthly X  
 Other \_\_\_\_\_

Temp.*	A	20304				C0301				COMMENTS
		Lead Wire STQC#		(B-A)100 A **		Lead Wire STQC#		(B-A)100 A **		
		Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2	
50112	212	213	213			213	214			
C0112	212	214	214			214	214			
50112	410	411	412			412	413			
C0112	410	412	411			413	412			
50112	710	711	712			712	713			
C0112	710	711	712			711	713			

\* All temperatures are in degrees F.  
 \*\*Percent (%) difference should not exceed +/- 1.5%.  
 Page Number 13



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-132-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
DATA SHEET FOR THERMOCOUPLE/POTENTIOMETER CALIBRATION

Field Meter STQC# : NO311  
 Ref. Thermometer # : ASTM08240  
 Temperature Source(s) : topra

Date: 9-24-13  
 Calibration By: T. Nguyen  
 Calibration Period:  
 Semiannual X  
 Bimonthly \_\_\_\_\_  
 Other \_\_\_\_\_

Temp.*	A	Lead Wire STQC# _____				Lead Wire STQC# _____				COMMENTS
		B		(B-A) 100 A **		B		(B-A) 100 A **		
		Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2	Ch#1	Ch#2	
N0112	210	210	211							
N0113	210	211	210							
N0112	410	411	411							
N0113	410	411	410							
N0112	710	710	711							
N0113	710	711	711							
N0112										
N0113										

\* All temperatures are in degrees F.  
 \*\*Percent (%) difference should not exceed +/- 1.5%.  
 Page Number 15

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-133-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**APPENDIX D**

District Laboratory Data

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-134-

Date(s): 8/8/13, 8/23/13 and 9/20/13



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Dr., Diamond Bar, CA 91765-4182

**MONITORING AND ANALYSIS  
REPORT OF LABORATORY ANALYSIS**

(Page 1 of 2)

**TO:** Mike Garibay, Supervising A.Q. Engineer  
Monitoring/Source Testing  
Science & Technology Advancement

**LABORATORY NO.** 1322105-02 to - 08

**REFERENCE NO.** ICPMS-YS-5-57

**SAMPLES DESCRIBED AS:**

Solutions and filters from CARB Method 436  
(Excl. mercury) performed at Exide  
Technologies. Samples consist of solutions  
and filters from source test trains # 10 & #15.  
(See details on page 2)

**SUBMITTED ON:** 7/30/2013

**REQUESTED BY:** Mike Garibay

**SAMPLE SOURCE:**

Exide Technologies  
2700 Indiana St.  
Vernon, CA 90058

---

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**


**Analysis of Metal by Inductively Coupled Plasma - Mass Spectrometry**

Aliquots of solutions from impingers, housing, tubing, probe and blank were treated with nitric acid prior to analysis. Filters samples were digested in a microwave oven using 1:1 Ultrapure Nitric Acid. Analysis for metals was performed in accordance with AQMD Method #0005, (*Standard Operating Procedure for the Analysis of Metals in Filters by Inductively Coupled Plasma - Mass Spectrometer*).

**Results:**

Results for solutions are given in ppb (ng/ml). Concentrations of metals on filters are given in ng/filter. Where results were found to be below the Method Reporting Limit (MRL), a < MRL value in ppb is reported. For example, if the MRL for a compound is 0.5 ppb and a sample was found to be not detected for that compound, the reported value is <0.5 ppb. Please see next page for full results.

Date Approved: 8/28/13

Approved By:   
Rudy Eden, Sr. Manager  
Laboratory & Source Test Engineering

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-135-

Date(s): 8/8/13, 8/23/13 and 9/20/13

(Page 2 of 2)

Lab. ID	1322105-02	1322105-03	1322105-04	1322105-05	1322105-06	1322105-07	1322105-08
	Blank Reagent 5% HNO <sub>3</sub> + 10% H <sub>2</sub> O <sub>2</sub>	Container #2 Train #10 Probe + Line	Container #3 Train #10 Impinger + Front of filter housing	Container #3 Blank Train #15 Impinger + Front of filter housing	Container #2 Blank Train #15 Tubing + Probe	Train #10 Container #1	Train #15 Filter Blank
Element	ng/mL	ng/mL	ng/mL	ng/mL	ng/mL	ng/filter	ng/filter
Antimony	<0.18	0.59	0.78	<0.18	<0.18	10	8
Arsenic	<0.06	2.63	6.26	0.12	0.19	20	<2
Barium	<0.06	0.82	2.25	1.53	<0.06	2,000	1,320
Beryllium	<0.06	<0.06	<0.06	<0.06	<0.06	<2	<2
Cadmium	0.48	0.91	2.52	0.76	<0.12	<3	<3
Chromium	<0.60	<0.60	1.51	<0.60	<0.60	90	70
Cobalt	<0.06	<0.06	0.31	0.13	<0.06	<2	5
Copper	1.03	23.1	12.5	15.8	2.69	40	70
Iron	<0.06	51.4	93.1	23.9	4.66	560	640
Lead	0.19	52	202	19.2	3.19	120	40
Manganese	<0.120	1.06	2.31	0.91	0.14	110	60
Nickel	0.128	4.19	2.22	1.12	0.80	30	20
Selenium	<0.240	<0.24	0.47	<0.24	<0.24	<6	<6
Thallium	<0.60	<0.60	<0.60	<0.60	<0.60	<20	<20
Tin*	51.5	0.63	11.5	10.6	<0.60	180	<20
Titanium	<0.60	1.09	1.9	1.37	<0.60	<20	<20
Vanadium	<0.60	<0.60	<0.60	<0.60	<0.60	<20	<20
Zinc	4.31	48.5	61.1	24.3	8.57	2,620	2,110

\*Tin can be used as a stabilizer in H2O2 by the manufacturer.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-136-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Dr., Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS  
REPORT OF LABORATORY ANALYSIS

(Page 1 of 2)

**TO:** Mike Garibay, Supervising AQ Engineer  
Source Test Engineering

**LABORATORY NO:** 1323517-04 to -12

**SAMPLE DESCRIBED AS:**

Solutions and filters from three CARB  
Method 436 (Excl. mercury) source test  
trains; Trains, #7, #10 and #18  
(See details on page 2)

**REFERENCE NO:** ICP-MS-YS-5-60

**SUBMITTED ON:** 8/27/2013

**REQUESTED BY:** Jason Aspell

**SOURCE TEST NO:** 13-308

**SAMPLE SOURCE:**

Exide Technologies  
2700 Indiana St.  
Vernon, CA 90058

---

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**

**Analytical Method**


**Analysis of Metals by Inductively Coupled Plasma - Mass Spectrometry**

Aliquots of solutions from impingers, housing, tubing, probe and blank were treated with nitric acid prior to analysis. Filter samples were digested in a microwave oven using 1:1 Ultrapure Nitric Acid. Analysis for metals was performed in accordance with AQMD Method #0005, (*Standard Operating Procedure for the Analysis of Metals in Filters by Inductively Coupled Plasma - Mass Spectrometer*).

**Results:**

See attachment.

Date Approved: 10/4/13

Approved By:   
Rudy Eden, Sr. Manager  
Laboratory & Source Test Engineering

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-137-

Date(s): 8/8/13, 8/23/13 and 9/20/13

(Page 2 of 2)

Exide Technologies: 2700 Indiana St., Vernon, CA 90058

LN 1323517-04 to -12

Metal analysis results for source test performed at Exide Technologies (Source Test # 13-308)

Element	1323517-05 Train #10 tubing & probe	1323517-06 Train #10 impinger & front half filter housing	1323517-04 filter for Train #10	1323517-08 Train #18 tubing & probe	1323517-09 Train #18 impinger & front half filter housing	1323517-07 filter for Train #18	1323517-11 Train #7 impinger & front half filter housing	1323517-12 Reagent blank 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	1323517-10 filter for Train #7
	ng/mL	ng/mL	ng/filter	ng/mL	ng/mL	ng/filter	ng/mL	ng/mL	ng/filter
Antimony	1.0	0.9	10	2.4	0.50	20	<0.2	<0.2	7
Arsenic	4.6	60	110	0.5	0.2	<1.0	<0.06	<0.06	<1.0
Barium	<0.05	1.4	1480	1.8	1.8	1210	1.4	<0.05	1440
Beryllium	<0.5	<0.5	<2.5	<0.5	<0.5	<2.5	<0.5	<0.5	<2.5
Cadmium	1.4	0.75	4	2.75	1	8	1	<0.05	<1.5
Chromium	<0.6	2	70	0.6	3	70	2.2	3.3	60
Cobalt	<0.5	<0.5	<1.5	<0.5	<0.5	<1.5	<0.5	<0.5	<1.5
Copper	2.3	3.5	<1.50	10	5.8	120	4.8	1.4	30
Iron	35	25	630	715	1060	340	15	7.7	450
Lead	109	164	320	342	91.7	450	18	0.4	30
Manganese	0.4	0.4	2250	8	4	70	0.4	0.2	50
Nickel	0.3	1.5	50	1.0	1.78	20	1.30	1.40	30
Selenium	<0.6	6.0	7	<0.6	<0.6	<2.0	<0.6	<0.6	<2.0
Thallium	<0.6	<0.6	<1.5	<0.6	<0.6	<1.5	<0.6	<0.6	<1.5
Tin	1	1360	150	3.21	1440	510	1140	2560	<0.1
Titanium	<0.6	7.6	<1.2	1.4	8.2	<1.2	7.5	10.9	<1.2
Vanadium	<0.5	<0.5	<1.0	<0.5	<0.5	<1.0	<0.5	<0.5	<1.0
Zinc	5	12	1960	24	26	2270	13	3	1690



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-139-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Dr., Diamond Bar, CA 91765-4182

MONITORING AND ANALYSIS  
REPORT OF LABORATORY ANALYSIS

(Page 1 of 2)

TO: Mike Garibay, Supervising A.Q. Engineer  
Laboratory & Source Test Engineering

LABORATORY NO. 1326709-03 to -11

**SAMPLE DESCRIBED AS:**

Solutions and filters from three CARB  
Method 436 (Excl. mercury) source test  
trains; Trains #4, #5 and #11  
(See details on page 2)

REFERENCE NO. ICP-MS-YS-5-78

SUBMITTED ON: 9/24/2013

REQUESTED BY: Jason Aspell

SOURCE TEST NO.: 13-308

**SAMPLE SOURCE:**

Exide Technologies  
2700 Indiana St.  
Vernon, CA 90058

---

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**

**Analytical Method**

**Analysis of Metals by Inductively Coupled Plasma - Mass Spectrometry**

Aliquots of solutions from impingers, housing, tubing, probe and blank were treated with nitric acid prior to analysis. Filters samples were digested in a microwave oven using 1:1 Ultrapure Nitric Acid. Analysis for metals was performed in accordance with AQMD Method #0005, (*Standard Operating Procedure for the Analysis of Metals in Filters by Inductively Coupled Plasma - Mass Spectrometer*).

**Results:**

See attachment.

Date Approved: 10/4/13

Approved By   
Rudy Eden, Sr. Manager  
Laboratory & Source Test Engineering



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-140-

Date(s): 8/8/13, 8/23/13 and 9/20/13

(Page 2 of 2)

Exide Technologies: 2700 Indiana St., Vernon, CA 90058

LN 1326709-03 to -11

Metal analysis results for source test performed at Exide Technologies (Source Test # 13-308)

Lab ID	1326709-03	1326709-04	1326709-05	1326709-06	1326709-07	1326709-08	1326709-09	1326709-10	1326709-11
Sample Description	Train #4 Filter ng/filter	Train #4 Probe and Line ng/mL	Train #4 Impinger & front half filter housing ng/mL	Train #5 Filter ng/filter	Train #5 Probe and Line ng/mL	Train #5 Impinger & front half filter housing ng/mL	Train #11 (blank) Filter ng/filter	Train #11 (blank) Impinger & front half filter housing ng/mL	Reagent Blank 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub> ng/mL
Antimony	40	5.6	1.4	10	1.7	3.0	9	<0.2	<0.2
Arsenic	30	2	2	40	3.2	34.8	<1.0	0.08	<0.06
Barium	1770	4.9	1.9	2840	0.7	2	2670	0.6	<0.5
Beryllium	4	<0.5	<0.5	<2.5	<0.5	<0.5	<2.5	<0.5	<0.5
Cadmium	60	6.74	2.05	20	2.1	2.2	<1.5	0.3	0.2
Chromium	70	1.8	2.65	40	<0.6	2.44	60	2.6	3.4
Cobalt	6	<0.5	<0.5	<1.5	<0.5	<0.5	<1.5	<0.5	<0.5
Copper	40	6	8	50	4.0	5.0	<0.5	3.0	1
Iron	37	220	124	1010	43	61	34	20	13
Lead	3490	645	279	86	170	690	4	13.9	0.2
Manganese	70	4.2	1.1	60	0.5	0.8	60	0.3	0.2
Nickel	20	2.7	1.9	30	0.6	1.7	20	1.4	1.5
Selenium	<2.0	<0.6	0.68	<2.0	<0.6	<0.6	<2.0	<0.6	<0.6
Thallium	<1.5	<0.6	<0.6	<1.5	<0.6	<0.6	<1.5	<0.6	<0.6
Tin	28	5.8	1920	36	3.0	2020	<1.5	2210	3440
Titanium	30	9.2	6.9	50	<0.6	5.47	<1.2	6.8	9
Vanadium	<1.0	<0.5	<0.5	<1.0	<0.5	<0.5	<1.0	<0.5	<0.5
Zinc	2640	140	29	1310	7	16	2900	15	1

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT**  
 21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-141-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**SOURCE TEST REQUEST FOR EQUIPMENT/ANALYSIS**

Company Exide Technologies Source Test No. 13-308  
 Address 2700 S. Indiana St Request Date September 17, 2013  
 Basic Equipment Blast Furnace, Reverb Furn., Refining Kettles Control Device HL/SL baghouses, Torii Stacks  
 Analysis/Equipment Requested By Jason Aspell Date Equipment Needed September 19, 2013  
 For Compliance, Rule(s) 1402, 1407, 1420, 1420.1  
 Other (specify) \_\_\_\_\_

**SAMPLE EQUIPMENT REQUEST**

Prep/Reference \_\_\_\_\_ Prep Laboratory No. 1326101  
 Dry Ice Needed

Quantity and Description	ID Nos
3 - 6L Canisters (Fixed Gases)	54775, 54164, 54731, 54731
4 - EPA Method TO-15 Canisters	24224, <del>E3747</del> , E3373, E4281
5 - CARB Method 436 Trains (excl. mercury)	Trains Nos: 4, 5, 11, 27, 31
	Reference: Blue Book No. 41 Pages 40, 41

**SAMPLE EQUIPMENT ANALYSIS REQUEST**

Source Test No. \_\_\_\_\_ Analysis Laboratory No. 1326709  
 Sample Description TRAW 4 & 5 + Sample Lines + Probe Analysis Requested TRAWS  
CAN 54775, 54731 Multi Metals  
CAN E4281, E4224 Fixed Gases  
TO-K  
Train #11 used as a blank 8/23/13

**SAMPLE EQUIPMENT CHAIN OF CUSTODY**

Sample Equipment #	From	To	For (S/T, Analysis, Cleanup, Not Used)	Date	Time
<u>①</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>ST</u>	<u>09/19/13</u>	<u>13:20</u>
<u>11</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>ANALYZE</u>	<u>9/20/13</u>	<u>1655</u>
				<u>4/23/13</u>	<u>7:15 AM</u>
					<u>ICP MS - 5-78</u>

Revision: January 2012

11 E 8 11

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-142-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**MONITORING & ANALYSIS  
REPORT OF LABORATORY ANALYSIS**

**TO:** Mike Garibay, Supervising AQ Engineer  
Source Testing

**LABORATORY NO:** 1323519-01 to -04

**REFERENCE NO:** MSF-7-49

**SAMPLE DESCRIPTION:**

**DATE SAMPLED:** 08/23/13

Canister # 53484, E4324, 53397, E3383

**DATE RECEIVED:** 08/23/13

**DATE ANALYZED:** 09/09/13

**SAMPLE LOCATION:**

Exide Technologies  
2700 S. Indiana St.  
Vernon, CA 90057

**ANALYZED BY:** Yadira De Haro-Hammock

**REQUESTED BY:** Jason Aspell

---

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**

Qualitative Analysis and Quantitation of Toxic Organics by Gas Chromatography(GC) -  
Mass Spectrometry(MS) and Flame Ionization Detection(FID)

Note: See attached results.

Date Approved: 10/3/13

Approved By: 

Rudy Eden, Sr. Manager  
Laboratory Services Branch  
(909) 396-2391

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-143-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**LAB NO:** 1323519

**Location:** Exide Technologies

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**

Qualitative Analysis and Quantitation of Toxic Organics by Gas Chromatography(GC) -  
Mass Spectrometry(MS) and Flame Ionization Detection(FID)

Sample Date	8/23/2013	8/23/2013	8/23/2013	8/23/2013
Canister	53484	E4324	53397	E3383

<u>Compound</u>	<u>Conc. (ppb)</u>	<u>Conc. (ppb)</u>	<u>Conc. (ppb)</u>	<u>Conc. (ppb)</u>
ethanol	19.8	6.6	26.1	6.3
vinyl chloride	N.D.	N.D.	N.D.	N.D.
1,3-butadiene	37.4	31.3	4.4	0.8
2-propenal (Acrolein)	2.0	2.4	1.1	0.9
acetone	57.9	32.8	98.4	75.4
methylene chloride	0.5	0.6	0.4	0.5
methyl tert butyl ether	N.D.	N.D.	N.D.	N.D.
2-butanone (MEK)	1.7	1.6	1.7	0.8
chloroform	0.4	0.3	0.4	0.2
1,2-dichloroethane	N.D.	N.D.	N.D.	N.D.
benzene	127	111	51.0	21.5
carbon tetrachloride	N.D.	N.D.	<0.1	<0.1
1,2-dichloropropane	N.D.	N.D.	N.D.	N.D.
trichloroethylene	<0.1	N.D.	N.D.	<0.1
toluene	25.4	22.0	7.8	3.8
1,2-dibromoethane	N.D.	N.D.	N.D.	N.D.
tetrachloroethylene	N.D.	<0.1	<0.1	<0.1
ethylbenzene	5.6	4.5	2.9	2.0
m+p-xylenes	10.0	6.3	11.8	8.0
Styrene	104	78.4	1.4	0.3
o-xylene	2.9	1.7	3.3	1.9
1,4-dichlorobenzene	N.D.	N.D.	<0.1	N.D.
1,2-dichlorobenzene	N.D.	N.D.	N.D.	N.D.
isoprene	8.6	7.6	0.3	<0.1

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-144-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**LAB NO:** 1323519  
**Location:** Exide Technologies

---

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**  
Qualitative Analysis and Quantitation of Toxic Organics by Gas Chromatography(GC) -  
Mass Spectrometry(MS) and Flame Ionization Detection(FID)

Sample Date	8/23/2013	8/23/2013	8/23/2013	8/23/2013
Canister	53484	E4324	53397	E3383

<u>Compound</u>	<u>Conc. (ppb)</u>	<u>Conc. (ppb)</u>	<u>Conc. (ppb)</u>	<u>Conc. (ppb)</u>
acetylene+ethylene	662 *	595 *	467 *	450 *
ethane	4440 *	4400 *	192	208
propylene	194	155	20.5	12.8
propane	909 *	949 *	269	398
isobutane	41.9	47.6	3.8	4.6
1-butene	9.8	8.5	1.5	0.8
n-butane	71.2	64.7	25.6	21.8
n-pentane	27.6	25.9	3.1	2.1
1-hexene	4.5	4.0	0.2	<0.1
n-hexane	3.5	4.1	0.5	0.4
n-heptane	2.6	2.7	0.4	0.4
n-octane	1.4	1.3	0.2	N.D.
n-nonane	0.4	0.4	<0.1	<0.1
n-decane	0.3	0.3	<0.1	<0.1
n-undecane	0.3	0.3	<0.1	<0.1
n-dodecane	0.3	0.4	<0.1	<0.1

\* = Data Flagged, above calibration range

Supplemental report to follow of "Hydrocarbon Speciation by GC/FID"

N.D. = Not Detected

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-145-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOURCE TEST REQUEST FOR EQUIPMENT/ANALYSIS

Company <u>Exide Technologies</u>	Source Test No. <u>13-308</u>
Address <u>2700 S. Indiana St.</u>	Request Date <u>August 14, 2013</u>
Basic Equipment <u>Blast Furnace, Reverb Furn., Refining Kettles</u>	Control Device <u>HL/SL baghouses, Nept Scrubber</u>
Analysis/Equipment Requested By <u>Jason Aspell</u>	Date Equipment Needed <u>See Below</u>
For Compliance, Rule(s) <u>1402, 1407, 1420, 1420.1</u>	
Other (specify) _____	

SAMPLE EQUIPMENT REQUEST

Prep Reference \_\_\_\_\_ Prep Laboratory No. 1322654

Dry Ice Needed

Quantity and Description	I.D. Nos.
Test Run No. 2 - Equip. need by 8/22/13 AM 5 - 6L Canisters (Fixed Gases) 5 - EPA Method TO-15 Canisters 5 - CARB Method 436 Trains (excl. mercury)	<u>54317, 54128, 54099, 54772, 54080, NR</u> <u>E4324, E3383, 53484, 53397, 54107, 54108</u> <u>Train Nos: 5-7-18-18-27</u> <u>8/23/13</u>  Reference: <u>BlueBook No. 41</u> <u>Pages Nos: 36, 37</u>

SAMPLE EQUIPMENT ANALYSIS REQUEST

Source Test No. _____	Analysis Laboratory No. <u>1323519</u>
Sample Description	Analysis Requested <u>TO-15 canister</u>
<u>TRAIN 10 + 18 + Probest Lines</u>	<u>Mixed Metals</u>
<u>I CANS 54080, 54772</u>	<u>Fixed Gases</u>
<u>CANS 53484, E4324, 53397, E3383</u>	<u>TO-15</u>
<u>Train II 7</u>	<u>Blank</u>

SAMPLE EQUIPMENT CHAIN OF CUSTODY

Sample Equipment #	From	To	For (S/T, Analysis, Cleanup, Not Used)	Date	Time
<u>I</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>ST</u>	<u>8/22/13</u>	<u>2:30</u>
<u>II</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>ANALYSIS</u>	<u>8/23/13</u>	<u>4:40</u>

Revised January 2012

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-146-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Dr., Diamond Bar, CA 91765-4182

MONITORING & ANALYSIS  
REPORT OF LABORATORY ANALYSIS

<b>TO:</b> Mike Garibay, Supervising AQ Engineer Source Testing	<b>LABORATORY NO:</b> <u>1326711</u>
	<b>REFERENCE NO:</b> <u>MSF-7-53</u>
<b>SAMPLE DESCRIPTION:</b>  Can #E4281, E4224	<b>DATE SAMPLED:</b> <u>09/20/13</u>
	<b>DATE RECEIVED:</b> <u>09/20/13</u>
	<b>DATE ANALYZED:</b> <u>10/08/13</u>
<b>SAMPLE LOCATION:</b>  Exide Technologies 2700 S. Indiana St. Vernon, CA 90057	<b>ANALYZED BY:</b> <u>Yadira De Haro-Hammock</u>
	<b>REQUESTED BY:</b> <u>Jason Aspell</u>

---

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**

Qualitative Analysis and Quantitation of Toxic Organics by Gas Chromatography(GC) -  
Mass Spectrometry(MS) and Flame Ionization Detection(FID)

Note: See attached results.

Date Approved: 10/9/13

Approved By: 

Rudy Eden, Sr. Manager  
Laboratory Services Branch  
(909) 396-2391

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-147-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**LAB NO:** 1326711  
**Location:** Exide Technologies

---

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**

Qualitative Analysis and Quantitation of Toxic Organics by Gas Chromatography(GC) -  
Mass Spectrometry(MS) and Flame Ionization Detection(FID)

Sample Date	9/20/2013	9/20/2013
Canister	E4224	E4281

<u>Compound</u>	<u>Conc. (ppb)*</u>	<u>Conc. (ppb)*</u>
ethanol	10.8	13.5
vinyl chloride	N.D.	N.D.
1,3-butadiene	17.1	21.9
2-propenal (Acrolein)	4.1	3.0
acetone	40.0	42.0
methylene chloride	N.D.	0.3
methyl tert butyl ether	N.D.	N.D.
2-butanone (MEK)	1.0	1.5
chloroform	0.1	0.2
1,2-dichloroethane	N.D.	N.D.
benzene	159	68.9
carbon tetrachloride	0.1	0.1
1,2-dichloropropane	N.D.	N.D.
trichloroethylene	N.D.	N.D.
toluene	26.9	18.6
1,2-dibromoethane	N.D.	N.D.
tetrachloroethylene	N.D.	0.1
ethylbenzene	1.9	2.3
m+p-xylenes	10.0	4.0
Styrene	21.9	33.3
o-xylene	1.9	2.0
1,4-dichlorobenzene	N.D.	N.D.
1,2-dichlorobenzene	N.D.	N.D.
isoprene	5.6	19.4



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-148-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**LAB NO:** 1326711  
**Location:** Exide Technologies

---

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**

Qualitative Analysis and Quantitation of Toxic Organics by Gas Chromatography(GC) -  
Mass Spectrometry(MS) and Flame Ionization Detection(FID)

Sample Date	9/20/2013	9/20/2013
Canister	E4224	E4281

<u>Compound</u>	<u>Conc. (ppb)*</u>	<u>Conc. (ppb)*</u>
acetylene+ethylene	888	551
ethane	119	433
propylene	190	137
propane	75.0	144
isobutane	3.5	7.8
1-butene	46.3	14.4
n-butane	11.4	17.2
n-pentane	20.0	11.1
1-hexene	2.5	6.1
n-hexane	0.8	1.5
n-heptane	0.9	1.5
n-octane	0.6	0.8
n-nonane	0.4	0.4
n-decane	0.4	0.3
n-undecane	N.D.	0.4
n-dodecane	N.D.	0.6

\* = Samples pressurized with argon- dilution factor applied

NMOC = Non-Methane Organic Compounds  
N.D. = Not Detected

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-149-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**SOURCE TEST REQUEST FOR EQUIPMENT/ANALYSIS**

Company Exide Technologies Source Test No. 13-308  
 Address 2700 S. Indiana St. Request Date September 17, 2013  
 Basic Equipment Blast Furnace, Reverb Furn., Refining Kettles Control Device HL/SL baghouses, Torit Stacks  
 Analysis/Equipment Requested By Jason Aspell Date Equipment Needed September 19, 2013  
 For Compliance, Rule(s) 1402, 1407, 1420, 1420.1  
 Other (specify) \_\_\_\_\_

**SAMPLE EQUIPMENT REQUEST**

Prep Reference \_\_\_\_\_ Prep Laboratory No. 1326101  
 Dry Ice Needed

Quantity and Description	I.D. Nos.
3 - 6L Canisters (Fixed Gases)	54775, 54164, <del>54731</del> , 54731 <sup>MR 9/18/13</sup>
4 - EPA Method TO-15 Canisters	E4224, <del>E3747</del> , E3373, E4281 <sup>SB 9/19/13</sup>
5 - CARB Method 436 Trains (excl. mercury)	<sup>E3718</sup>
①	→ Trains Nos: 4, 5, 11, 27, 31 Reference: Blue Book No. 41 Pages 40, 41

**SAMPLE EQUIPMENT ANALYSIS REQUEST**

Source Test No. \_\_\_\_\_ Analysis Laboratory No. 1326711  
 Sample Description \_\_\_\_\_ Analysis Requested TCA - TO15

① TRAIN 4 & 5 + SAMPLE LINE & PROBE  
 CARB 54775, 54731  
 CAN E4281, E4224  
 TO-15  
 Train #11 used as a blank <sup>9/23/13</sup>

**SAMPLE EQUIPMENT CHAIN OF CUSTODY**

Sample Equipment #	From	To	For (S/T, Analysis, Cleanup, Not Used)	Date	Time
① 11	<i>[Signature]</i>	<i>[Signature]</i> Jason Aspell Lead	ST ANALYZE	09/19/13 9/20/13 9/23/13	13:20 1655 7:15 AM

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-150-

Date(s): 8/8/13, 8/23/13 and 9/20/13

54

MAY 4-21

8-27-2013 (N) 1323518

Param = 729.0  
T = 23.0°C

w/t : not available  
Filled with Ar

Canister	P <sub>i</sub>	P <sub>f</sub>	V
#54080	709.1	985.2	6000
54772	709.6	990.7	6000

MR 8-27-2013

9-13-2013

Param = 727.8  
T = 22.6°C

w/t : not available  
Filled with Ar

Canister	P <sub>i</sub>	P <sub>f</sub>	V
ES113	726.4	1001.5	6000 mL
54156	728.2	992.6	6000 mL

MR 9-13-2013

Dilution bulb C	100mL from 54156	981.4	1800 mL
Dilution bulb E	100mL from ES113	993.4	1790 mL

MR 9-13-2013

9-26-2013

Param = 731.8  
T = 22.3°C

w/t = 734.6  
Filled with Ar

Canister	P <sub>i</sub>	P <sub>f</sub>	V
54775	713.7	946.9	6000mL
54731	744.4	949.4	6000mL
E4224	760.6	984.6	6000mL
E4281	702.6	981.7	6000mL

MR 9-26-2013

			To Page No.
SIGNATURE	DATE	WITNESSED & UNDERSTOOD BY	DATE

CONFIDENTIAL

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-151-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Dr., Diamond Bar, CA 91765-4182**

**MONITORING & ANALYSIS  
REPORT OF LABORATORY ANALYSIS**

<b>TO</b> Mike Garibay, Supervising AQ Engineer Source Test Engineering	<b>LABORATORY NO.</b>	<u>1322105</u>
	<b>ST NO</b>	<u>13-307</u>
<b>SAMPLE(S) DESCRIBED AS</b> Two CARB 436 Trains	<b>DATE RECEIVED</b>	<u>8/9/2013</u> 1401, 1407, 1420, 1420.1
	<b>PROJECT/ RULE</b>	<u>1420.1</u>
<b>SAMPLING LOCATION</b> Exide Technologies 2700 S Indiana St Vernon CA 90023	<b>REQUESTED BY</b>	<u>Jason Aspell</u>
	<b>DATE ANALYZED</b>	<u>8/9/2013</u>

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**


Moisture and multiple metals by CARB 436. <sup>(1)</sup>

MOISTURE	TRAIN 10	TRAIN 15
Moisture gain, g	16	<1
Silica gel%	50-55	<1
Notes	Probe #9, ~ 12' Teflon, no moisture or deposit visible. Clear colorless liquid.	Blank probe submitted. Clear colorless liquid in impingers.
<b>RECOVERY VOLUMES</b>		
Probe, mL	149.6	105.9
Impinger, mL	368.3	277.8
Filter, mL	NA <sup>(2)</sup>	NA <sup>(2)</sup>

NOTE (1) Additional significant figures provided for calculation purposes.

(2) Filter recovered without liquid. See ICP MS preparation for volume.

Date Approved: 8/23/13

Approved By:   
Rudy Eden, Senior Manager  
Laboratory Services  
(909) 396-2391

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-152-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Dr., Diamond Bar, CA 91765-4182

**MONITORING & ANALYSIS  
REPORT OF LABORATORY ANALYSIS**

<b>TO</b> Mike Garibay, Supervising AQ Engineer Source Test Engineering	<b>LABORATORY NO.</b>	<u>1323517-01,2,3</u>
	<b>ST NO</b>	<u>13-308</u>
<b>SAMPLE(S) DESCRIBED AS</b> Three CARB 436 Trains	<b>DATE RECEIVED</b>	<u>8/23/2013</u>
	<b>PROJECT/ RULE</b>	<u>1402, 1407, 1420, 1420.1</u>
<b>SAMPLING LOCATION</b> Exide Technologies 2700 S Indiana St Vernon CA 90023	<b>REQUESTED BY</b>	<u>Mohsen Nazemi</u>
	<b>DATE ANALYZED</b>	<u>8/23/2013</u>

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**

**Moisture and multiple metals by CARB 436. <sup>(1)</sup>**

MOISTURE	TRAIN 7	TRAIN 10	TRAIN 18
Moisture gain, g	<1	38.5	45.1
Silica gel%	<1	65-70	85-90
Notes	No probe or tubing. Clear colorless liquid w/ white ppt	~ 6'3" probe, 18'9" Teflon, dry and clean. Slightly cloudy colorless liquid.	~ 6'3" probe, 14' Teflon, dry and clean. Slightly cloudy colorless liquid, a drk brwn particles

**RECOVERY VOLUMES**


Probe, mL	NA <sup>(2)</sup>	148.8	147.3
Impinger, mL	341.3	353.7	352.1
Filter, mL	NA <sup>(3)</sup>	NA <sup>(3)</sup>	NA <sup>(3)</sup>

NOTE (1) Additional significant figures provided for calculation purposes.

(2) Probe and tubing not supplied

(3) Filter recovered without liquid. See ICP MS preparation for volume.

Date Approved: 10/4/13

Approved By:   
Rudy Eden, Senior Manager  
Laboratory Services  
(909) 396-2391

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-153-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Dr., Diamond Bar, CA 91765-4182

**MONITORING & ANALYSIS  
REPORT OF LABORATORY ANALYSIS**

<b>TO</b> Mike Garibay, Supervising AQ Engineer Source Test Engineering	<b>LABORATORY NO.</b>	<u>1326709-01.2,3</u>
	<b>ST NO</b>	<u>13-308</u>
<b>SAMPLE(S) DESCRIBED AS</b> Three CARB 436 Trains	<b>DATE RECEIVED</b>	<u>9/23/2013</u>
	<b>PROJECT/ RULE</b>	<u>1402, 1407, 1420, 1420.1</u>
<b>SAMPLING LOCATION</b> Exide Technologies 2700 S Indiana St Vernon CA 90023	<b>REQUESTED BY</b>	<u>Jason Aspell</u>
	<b>DATE ANALYZED</b>	<u>9/23/2013</u>

**ANALYTICAL WORK PERFORMED, METHOD OF ANALYSIS AND RESULTS**

Moisture and multiple metals by CARB 436. <sup>(1)</sup>

MOISTURE	TRAIN 4	TRAIN 5	TRAIN 11
Moisture gain, g	66.1	64.2	0.1
Silica gel%	90-95	95+	<1
Notes	~ 6'4" probe, 14'8" Teflon. dry and clean. Clear colorless liquid with white ppt.	~ 6'4" probe, 17'11" Teflon. dry and clean. Clear colorless liquid with white ppt.	No probe or tubing. Clear colorless liquid w/ white ppt

**RECOVERY VOLUMES**

Probe, mL	146.5	153.5	NA <sup>(2)</sup>
Impinger, mL	401.3	389.6	332.7
Filter, mL	NA <sup>(3)</sup>	NA <sup>(3)</sup>	NA <sup>(3)</sup>

NOTE (1) Additional significant figures provided for calculation purposes.

(2) Probe and tubing not supplied

(3) Filter recovered without liquid. See ICP MS preparation for volume.

Date Approved:

10/4/13

Approved By:

  
Rudy Eden, Senior Manager  
Laboratory Services  
(909) 396-2391

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-154-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar CA 91765-1482

MONITORING & ANALYSIS  
REPORT OF LABORATORY ANALYSIS

Page 1 of 2

<b>TO</b>	Mike Garibay, Supervising AQ Engineer Monitoring/Source Testing	<b>LABORATORY NO</b>	<u>1322107-01</u>
<b>SAMPLE DESCRIBED AS</b>	One 6L Canister	<b>DATE RECEIVED</b>	<u>08/09/2013</u>
<b>SAMPLING LOCATION</b>	Exide Technologies 2700 S. Indiana St. Vernon, CA 90058	<b>FACILITY ID NO</b>	<u>NA</u>
		<b>REQUESTED BY</b>	<u>Mohsen Nazemi</u>
		<b>ST NO / PROJECT</b>	<u>13-307</u>

---

Percent hydrogen (H<sub>2</sub>), nitrogen (N<sub>2</sub>), oxygen (O<sub>2</sub>) and methane (CH<sub>4</sub>)  
by SCAQMD Method 10.1 (GC TCD).

Type	Canister
Number	<u>54185</u>
Pressure (Torr)	406

H <sub>2</sub> , percent	< 0.2
O <sub>2</sub> , percent	20.9
N <sub>2</sub> , percent	78.7
CH <sub>4</sub> , percent	< 0.2

Date Approved: 10/2/13

Approved By:   
Rudy Eden, Senior Manager  
Laboratory Services  
909-396-2391

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-155-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar CA 91765-1482

MONITORING & ANALYSIS  
QUALITY CONTROL SUMMARY

Page 2 of 2

<b>SAMPLE DESCRIBED AS</b>	<b>LABORATORY NO</b>	<u>1322107-01</u>
One 6L Canister	<b>REQUESTED BY</b>	<u>Mohsen Nazemi</u>

**Percent hydrogen (H<sub>2</sub>), nitrogen (N<sub>2</sub>), oxygen (O<sub>2</sub>) and methane (CH<sub>4</sub>)  
by SCAQMD Method 10.1 (GC TCD).**

**QUALITY CONTROL -- End of run control recovery**

	MDL	Theoretical	Measured	Absolute Difference	QC Limit
CC12089					0.7% Abs.
H <sub>2</sub> , percent	0.2% abs	1.04	1.05	0.01	PASS
O <sub>2</sub> , percent	0.2% abs	1.01	1.07	0.06	PASS
N <sub>2</sub> , percent	0.2% abs	0.99	1.10	0.1	PASS
CH <sub>4</sub> , percent	0.2% abs	1.05	1.08	0.03	PASS

	MDL	Theoretical	Measured	Absolute Difference	QC Limit
CC73109					0.7% Abs.
H <sub>2</sub> , percent	0.2% abs	0.00	0.00	NA	NA
O <sub>2</sub> , percent	0.2% abs	24.63	24.92	0.29	PASS
N <sub>2</sub> , percent	0.2% abs	4.94	5.04	0.1	PASS
CH <sub>4</sub> , percent	0.2% abs	0.00	0.00	NA	NA

<b>DATE ANALYZED</b>	8/15/2013
<b>REFERENCE NO:</b>	13TC3ad TC3-18-74



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-156-

Date(s): 8/8/13, 8/23/13 and 9/20/13

**SOURCE TEST REQUEST FOR EQUIPMENT/ANALYSIS**

Company Exide Technologies Source Test No. 13-307  
 Address 2700 S. Indiana St. Request Date August 2, 2013  
 Basic Equipment Blast Furnace, Reverb Furn., Refining Kettles Control Device HL/SL baghouses, Nept Scrubber  
 Analysis/Equipment Requested By Jason Aspell Date Equipment Needed August 7, 2013 (AM)  
 For Compliance, Rule(s) 1402, 1407, 1420, 1420.1  
 Other (specify) \_\_\_\_\_

**SAMPLE EQUIPMENT REQUEST**

Prep Reference \_\_\_\_\_ Prep Laboratory No. 1322107-01  
 Dry Ice Needed

Quantity and Description	I.D. Nos.
I } 3 CARB Method 436 Trains (excl. mercury)	Trains Nos. 10, 11, 15
2 - 6L Canisters (Fixed Gases)	54185, 54138
2 EPA Method TO-15 Canister	53385, 53484 SP. 8/6/13
	Reference: Blue Book No. 41 Pages 34, 35

**SAMPLE EQUIPMENT ANALYSIS REQUEST**

Source Test No. \_\_\_\_\_ Analysis Laboratory No. 1322107-01  
 Sample Description RODE 9, TRAIN 10, SAMPLING & CONDENSERS Analysis Requested CAN. 54185  
 I } CAN. E 3385 MULT. METALS + MOISTURE  
 II } CAN. 54185 TO 15  
TRAIN 11, 15 / CAN 53484, 54138 FIXED GASES  
NOT USED / BLANK TBD BY ANALYST

**SAMPLE EQUIPMENT CHAIN OF CUSTODY**

Sample Equipment #	From	To	For (S/T, Analysis, Cleanup, Not Used)	Date	Time
I	<i>[Signature]</i>	<i>[Signature]</i>	ST	8/7/13	8:35
II	<i>[Signature]</i>	<i>[Signature]</i>	ANALYSIS	8/9/13	9:30

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-157-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar CA 91765-1482

MONITORING & ANALYSIS  
REPORT OF LABORATORY ANALYSIS

Page 1 of 2

<b>TO</b>	Mike Garibay, Supervising AQ Engineer Monitoring/Source Testing	<b>LABORATORY NO</b>	<u>1322107-01</u>
<b>SAMPLE DESCRIBED AS</b>	One 6L Canister	<b>DATE RECEIVED</b>	<u>08/09/2013</u>
<b>SAMPLING LOCATION</b>	Exide Technologies 2700 S. Indiana St. Vernon, CA 90058	<b>FACILITY ID NO</b>	<u>NA</u>
		<b>REQUESTED BY</b>	<u>Mohsen Nazemi</u>
		<b>ST NO / PROJECT</b>	<u>13-307</u>

---

Carbon monoxide (CO), methane (CH<sub>4</sub>), carbon dioxide (CO<sub>2</sub>), ethane (C<sub>2</sub>H<sub>6</sub>), and non-methane non-ethane organic carbon (NM/NEOC) in ppmvC by SCAQMD Method 25.1 (TCA FID).

Type	Canister
Number	<b><u>54185</u></b>
Pressure (Torr)	406
CO, ppm	59
CH <sub>4</sub> , ppm	173
CO <sub>2</sub> , ppm	730
Ethane, ppmC	11
NM/NEOC, ppmC	< 1

Date Approved: 10/2/13

Approved By: 

Rudy Eden, Senior Manager  
Laboratory Services  
909-396-2391

Pages 158-161 have been removed from this file because it may contain proprietary information.

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-162-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar CA 91765-1482

MONITORING & ANALYSIS  
QUALITY CONTROL SUMMARY

Page 2 of 2

<b>SAMPLE DESCRIBED AS</b>	<b>LABORATORY NO</b>	<u>1323518</u>
Two 6L Canisters	<b>REQUESTED BY</b>	<u>Jason Aspell</u>

**Carbon monoxide (CO), methane (CH<sub>4</sub>), carbon dioxide (CO<sub>2</sub>), ethane (C<sub>2</sub>H<sub>6</sub>), and non-methane non-ethane organic carbon (NM/NEOC) in ppmvC by SCAQMD Method 25.1 (TCA FID).**

**QUALITY CONTROL -- End of run control recovery**

CC91340 MDL	Theoretical	Measured	Percent Difference	QC Limit ±5% or ± 1
CO, ppmvC 0.31976058	10.40	10.17	-2.17	PASS
CH <sub>4</sub> , ppmvC 0.08319894	10.17	10.42	2.47	PASS
CO <sub>2</sub> , ppmvC 0.47061793	10.38	10.18	-1.90	PASS
C <sub>2</sub> H <sub>4</sub> , ppmvC 0.47061793	NA	NA	NA	NA
C <sub>2</sub> H <sub>6</sub> , ppmvC 0.2381613	11.00	10.14	-7.79	PASS
NM/NEOC, ppmvC 0.26158589	10.64	10.25	-3.64	PASS

CC12628 MDL	Theoretical	Measured	Percent Difference	QC Limit ±5% or ± 1
CO, ppmvC 0.31976058	1036	1041	0.51	PASS
CH <sub>4</sub> , ppmvC 0.08319894	1068	1088	1.85	PASS
CO <sub>2</sub> , ppmvC 0.47061793	1023	1023	0.04	PASS
C <sub>2</sub> H <sub>4</sub> , ppmvC 0.47061793	NA	NA	NA	NA
C <sub>2</sub> H <sub>6</sub> , ppmvC 0.2381613	1032	1059	2.59	PASS
NM/NEOC, ppmvC 0.26158589	1036	1028	-0.75	PASS

<b>DATE ANALYZED</b>	08/27/2013
<b>REFERENCE NO:</b>	13QM2AD QM2-101-18

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-163-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar CA 91765-1482

MONITORING & ANALYSIS  
REPORT OF LABORATORY ANALYSIS

Page 1 of 2

<b>TO</b>	Mike Garibay, Supervising AQ Engineer Monitoring/Source Testing	<b>LABORATORY NO</b>	<u>1326710-01,2</u>
		<b>DATE RECEIVED</b>	<u>09/20/2013</u>
<b>SAMPLE DESCRIBED AS</b>	Two 6L Canisters	<b>FACILITY ID NO</b>	<u>NA</u>
		<b>REQUESTED BY</b>	<u>Jason Aspell</u>
<b>SAMPLING LOCATION</b>	Exide Technologies 2700 S. Indiana St. Vernon, CA 90058	<b>ST NO / PROJECT</b>	<u>13-308</u>


---

Percent hydrogen (H<sub>2</sub>), nitrogen (N<sub>2</sub>), oxygen (O<sub>2</sub>) and methane (CH<sub>4</sub>)  
by SCAQMD Method 10.1 (GC TCD).

Type	Canister	Canister
Number	<u>54775</u>	<u>54731</u>
Pressure (Torr)	714	744
H <sub>2</sub> , percent	< 0.2	< 0.2
O <sub>2</sub> , percent	20.4	20.3
N <sub>2</sub> , percent	77.5	76.9
CH <sub>4</sub> , percent	< 0.2	< 0.2

Date Approved: 10/10/13

Approved By: \_\_\_\_\_

  
Rudy Eden, Senior Manager  
Laboratory Services  
909-396-2391

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-164-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar CA 91765-1482

**MONITORING & ANALYSIS**  
**QUALITY CONTROL SUMMARY**

Page 2 of 2

<b>SAMPLE DESCRIBED AS</b>	<b>LABORATORY NO</b>	<u>1326710-01,2</u>
Two 6L Canisters	<b>REQUESTED BY</b>	<u>Jason Aspell</u>

**Percent hydrogen (H<sub>2</sub>), nitrogen (N<sub>2</sub>), oxygen (O<sub>2</sub>) and methane (CH<sub>4</sub>)  
by SCAQMD Method 10.1 (GC TCD).**

**QUALITY CONTROL -- End of run control recovery**

				Absolute Difference	QC Limit 0.7% Abs.
CC12089	MDL	Theoretical	Measured		
H <sub>2</sub> , percent	0.2% abs	1.04	1.04	0.00	PASS
O <sub>2</sub> , percent	0.2% abs	1.01	1.08	0.07	PASS
N <sub>2</sub> , percent	0.2% abs	0.99	1.08	0.1	PASS
CH <sub>4</sub> , percent	0.2% abs	1.05	1.04	-0.01	PASS

				Absolute Difference	QC Limit 0.7% Abs.
CC73109	MDL	Theoretical	Measured		
H <sub>2</sub> , percent	0.2% abs	0.00	0.00	NA	NA
O <sub>2</sub> , percent	0.2% abs	24.63	24.54	-0.09	PASS
N <sub>2</sub> , percent	0.2% abs	4.94	5.02	0.1	PASS
CH <sub>4</sub> , percent	0.2% abs	0.00	0.00	NA	NA

<b>DATE ANALYZED</b>	10/3/2013
<b>REFERENCE NO:</b>	13TC3ae TC3-18-80

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-165-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar CA 91765-1482

MONITORING & ANALYSIS  
REPORT OF LABORATORY ANALYSIS

Page 1 of 2

TO Mike Garibay, Supervising AQ Engineer LABORATORY NO 1326710  
Monitoring/Source Testing

DATE RECEIVED 09/20/2013

SAMPLE DESCRIBED AS Two 6L Canisters FACILITY ID NO NA


REQUESTED BY Jason Aspell

SAMPLING LOCATION Exide Technologies ST NO / PROJECT 13-308  
2700 S. Indiana St.  
Vernon, CA 90058

Carbon monoxide (CO), methane (CH<sub>4</sub>), carbon dioxide (CO<sub>2</sub>), ethane (C<sub>2</sub>H<sub>6</sub>), and non-methane non-ethane organic carbon (NM/NEOC) in ppmvC by SCAQMD Method 25.1 (TCA FID).

Type	Canister	Canister
Number	<u>54775</u>	<u>54731</u>
Pressure (Torr)	714	744
CO, ppm	70	45
CH <sub>4</sub> , ppm	20	10
CO <sub>2</sub> , ppm	718	1040
Ethane, ppmC	< 1	< 1
NM/NEOC, ppmC	4	10

Date Approved: 10/11/13

Approved By:   
Rudy Eden, Senior Manager  
Laboratory Services  
909-396-2391

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, California 91765

Test Nos. 13-307 and 13-308

-166-

Date(s): 8/8/13, 8/23/13 and 9/20/13

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar CA 91765-1482

**MONITORING & ANALYSIS  
QUALITY CONTROL SUMMARY**

Page 2 of 2

<b>SAMPLE DESCRIBED AS</b>	<b>LABORATORY NO</b>	<u>1326710</u>
Two 6L Canisters	<b>REQUESTED BY</b>	<u>Jason Aspell</u>

**Carbon monoxide (CO), methane (CH<sub>4</sub>), carbon dioxide (CO<sub>2</sub>), ethane (C<sub>2</sub>H<sub>6</sub>), and non-methane non-ethane organic carbon (NM/NEOC) in ppmvC by SCAQMD Method 25.1 (TCA FID).**

**QUALITY CONTROL -- End of run control recovery**

			Percent Difference	QC Limit ±5% or ± 1
CC91340	MDL	Theoretical	Measured	
CO, ppmvC	0.32	10.40	10.31	-0.91 PASS
CH <sub>4</sub> , ppmvC	0.08	10.17	10.56	3.83 PASS
CO <sub>2</sub> , ppmvC	0.47	10.38	10.45	0.69 PASS
C <sub>2</sub> H <sub>4</sub> , ppmvC	0.47	NA	NA	NA NA
C <sub>2</sub> H <sub>6</sub> , ppmvC	0.24	11.00	10.39	-5.57 PASS
NM/NEOC, ppmvC	0.26	10.64	10.44	-1.85 PASS

			Percent Difference	QC Limit ±5% or ± 1
CC12628	MDL	Theoretical	Measured	
CO, ppmvC	0.32	1036	1065	2.75 PASS
CH <sub>4</sub> , ppmvC	0.08	1068	1115	4.36 PASS
CO <sub>2</sub> , ppmvC	0.47	1023	1048	2.47 PASS
C <sub>2</sub> H <sub>4</sub> , ppmvC	0.47	NA	NA	NA NA
C <sub>2</sub> H <sub>6</sub> , ppmvC	0.24	1032	1083	4.99 PASS
NM/NEOC, ppmvC	0.26	1036	1054	1.77 PASS

**DATE ANALYZED** 10/07/2013  
**REFERENCE NO:** 13QM2AD  
QM2-101-21