



Proposed Rule 1109.1 – NO_x Emission Reduction for Refinery Equipment and Related Operations

Working Group Meeting #20

April 30, 2021

Join Zoom Webinar

<https://scaqmd.zoom.us/j/94122770028>

Webinar ID: 941 2277 0028

Teleconference Dial-In: +1 669 900 6833



Agenda

2



Progress of Rule Development

Progress and Status Since Working Group Meeting 19

Implementation Compliance Plan & BARCT Equivalent Plan

Proposed Rule 429.1 – SU/SD Provisions at Petroleum Refineries

ClearSign Update

Progress of Rule Development

3

Summary of Working Group # 19 (02/11/21)

- Requested revised cost data and the reassessment of the following categories:
 - Boilers and heaters (≥ 40 MMBtu/hr)
 - FCCUs with SCR near BARCT limit
 - Vapor incinerators
- Cut-off time for revised cost data was March 12, 2021
- Provided update to implementation compliance plan (i-Plan)
- Presented initial concepts for BARCT equivalent compliance plan (b-Plan)

Progress and Status Since WGM 19


4

Status and Progress Since Last WGM

5



March Stationary Source Committee Update



Comment Letters Received



Continued Meeting with Stakeholders



Revised Cost Submission and Assessment

March Stationary Source Committee Update

6

- Staff provided an update to Stationary Source Committee on March 19th
- Staff presented the following topics:
 - Cost data submission and socioeconomic analyses for the rule
 - Third party reviews for the cost and socioeconomic analysis, details on next slide
 - Proposal to reassess of BARCT for various categories
 - Large Boilers & Heaters (≥ 40 MMBtu/hr)
 - Fluidized Catalytic Cracking Units (FCCU) with existing SCRs
 - Vapor Incinerators
 - Revised Implementation Compliance plan Targets and dates (i-Plan)
 - Initial concepts to the BARCT equivalency compliance plan (b-Plan)

Third Party Reviewers for Socioeconomic Impact Analysis

7

NORTON
engineering

Review of Cost Data

Norton Engineering Consultants Inc.

- Nearly 40 years of experience with petroleum and petrochemical industries worldwide
- Experienced with environmental control technologies
- Experienced in evaluation, design and selection of retrofit control applications for NOx , SOx, and PM
- Specializes in all areas of refining processes

Kleinhenz Economics
Cities | Regions

Review of Socioeconomic Analysis

Kleinhenz Economics

- Over 30 years of experience with economic forecasts, impact studies, and public policy analyses
- Principal Economist at Kleinhenz Economics
- Associate Director of Office of Economic Research at California State University, Long Beach
- Research Fellow, Inland Empire Economic Partnership
- South Coast AQMD Scientific, Technical & Modeling Peer Review Advisory Group for AQMP

IEC

Review of Benefits

Industrial Economics, Incorporated (IEC)

- 30 years of environmental consulting experience
- National leader in quantifying and monetizing the health and other benefits of reducing air pollution
- Conducted hundreds of studies on benefit-cost analyses of national air emissions rules, water quality policy, and waste management policy (U.S. EPA, U.S. Coast Guard, etc.)

Comment Letters Received

- Staff received six comments letters since last Working Group Meeting
 - Environmental Groups submitted two comment letters: April 1, 2021 and April 12, 2021
 - Tesoro Refining and Marketing Company LLC submitted comment letter on April 7, 2021
 - Latham and Watkins LLP on behalf of the Regulatory Flexibility Group and the Western States Petroleum Association submitted a comment letter on April 15, 2021
 - Torrance Refining Company LLC submitted two comment letters on April 16, 2021

Comment Letters Received

- Seven environmental and community groups submitted two comment letters:
 - Governing Board on April 1, 2021
 - Staff on April 12, 2021
- Letters expressed concern over recently proposed changes to the rule:
 - Opposes revising BARCT from 2 to 5 ppm for heaters and boilers (≥ 40 MMBtu/hr)
 - Opposes long compliance timelines and alternative compliance plans
 - Opposes start-up, shutdown, and malfunction provisions
 - Concerned provisions are loopholes that allow additional emissions
 - Supports shorter averaging times, believes longer averaging times will result in higher emissions
- Opposes further delay of the Public Hearing for PR 1109.1




Comment Letters Received – cont.



- Tesoro Refining and Marketing Company LLC submitted a comment letter on April 7, 2021
- Letter expressed the following concerns over PR 1109.1:
 - Tesoro considers units with existing LNB or SCR to be “well-controlled units”
 - Further retrofits to meet a 5 ppm NOx limit for many of the “well-controlled units” not cost-effective
 - Reiterated their viewpoint that South Coast AQMD is not calculating the incremental cost-effectiveness properly
 - Asked staff to reconsider the BARCT assessment for heaters operating with air preheat systems as they lead to higher NOx concentrations
 - Stated the high cost of operation and maintenance for high-performance SCR systems is not being included in cost-effectiveness calculations
 - Considers a 25-year useful life to be overstated
 - Supports a 10 to 15-year useful life to reflect Governor’s Executive Order to transition to zero-emission vehicles by 2035 and carbon neutrality goal by 2045



Comment Letters Received – cont.

- Latham and Watkins LLP submitted a comment letter on April 15, 2021 on behalf of the Regulatory Flexibility Group and the Western States Petroleum Association
- Letter maintains staff misinterprets California Health and Safety Code (HSC) in determining the Cost Effectiveness and Incremental Cost Effectiveness.
- HSC requires staff to:
 - Evaluate cost-effectiveness for each control options identified to be technologically feasible
 - Rank each potential control option and cost-effectiveness from least to most stringent and determine incremental cost-effectiveness
 - Present findings at the public hearing at which the regulation is adopted
- HSC prohibits Districts from imposing a more stringent control option unless it is incrementally cost-effective relative to the next less stringent control option



Comment Letters Received – cont.

- Torrance Refining Company LLC submitted two comment letters on April 16, 2021 in response to:
 - FERCo final study report (November 2020)
 - Norton study draft report (December 4, 2020)
- Letters expressed concern over some assumptions and perceived deficiencies in the FERCo and Norton reports regarding:
 - NOx formation in FCCU and SRU/TG Incinerators
 - The distinction between ULNB and LNB
 - Feasibility of achieving 2 ppm NOx BARCT limit with one SCR
 - Underestimation of SCR upgrade and ULNB installation cost
 - Combining control devices (e.g., ULNB and SCR)



Ongoing Stakeholder Meetings

- Staff is continuing to meet with refineries to discuss:
 - Feedback on proposed i-Plan and b-Plan
 - Site-specific challenges in meeting BARCT limits
 - Concerns about timelines and turnaround schedule
- Staff is continuing to meet with environmental and community groups to discuss:
 - Proposed NOx BARCT limits and implementation schedule
 - Concerns regarding the i-Plan and b-Plan
 - Process in vetting the recently submitted revised cost data
- All stakeholders requested that staff provide further clarity regarding the proposed implementation and compliance pathways



Continued Meetings with Stakeholders



¹ Biological Diversity, Coalition for Clean Air, Earth Justice, Communities for a Better Environment, Natural Resources Defense Council and East Yard Communities for Environmental Justice

Revised Cost and Cost-Effective Reassessment


15

- Received revised cost from facilities in March
 - Previously received cost for 58 SCR projects
 - 108 new or revised cost estimates
 - Costs provided for various projects and various units
 - SCR, SCR upgrades, wet gas scrubbers, burners, fuel gas treatment, and unit replacement
 - Heaters, boilers, SMR heaters, and FCCUs
 - Costs ranged from \$2 MM to \$300 MM per project
- Staff is currently reviewing and analyzing cost information
 - Working with facilities for clarification of data submission
 - Meeting with Norton Engineering to discuss their review of the revised cost data
- Facility provided costs are being used to revise the U.S. EPA cost model
 - Cost model used to estimate SCR projects where costs were not provided by facilities
- If costs for a unit were provided by facilities, the provided costs will be used
 - Controls must relate to NO_x reductions required by PR 1109.1
- Costs are being compiled and reviewed to reassess BARCT limits

Preliminary Revised Cost Estimates

16


- Scatter chart provides the difference between the original and revised cost estimates
- Chart includes:
 - Heaters and boilers ≥ 40 MMBtu/hr
 - SCR replacement and upgrades to achieve 5 ppm or less
- Revised cost data is being reviewed by Norton Engineering



Preliminary Revised Cost Estimates (*cont.*)

17

- Box chart provides difference between the original and revised cost estimates
 - Each box includes the minimum, maximum, and median values
 - Outlier data is noted as a points outside of boxes
- Chart includes:
 - Heaters and boilers ≥ 40 MMBtu/hr
 - SCR replacement and upgrades to achieve 5 ppm or less
- Revised cost data is being reviewed by Norton Engineering



BARCT Implementation and Compliance Plans

18

Alternative Compliance Options

19

- Staff has been conducting meetings with stakeholders to discuss the BARCT Implementation Plans (b-Plan) and Implementation Plans (i-Plans)
 - Discussing specific challenges at each facility
 - Considering number of units that require retrofits at each facility to meet proposed NOx limit
 - Requested clarification on how the plans would work together
- i-Plans
 - Trying to accommodate turnaround schedules within the i-Plans to minimize refinery downtime
- b-Plans
 - A few facilities have requested an alternative pathway based on a facility-wide mass cap

Considerations for a Mass Based Approach

20

- Alternative compliance options must result in emission reductions equivalent to BARCT, as defined in California Health and Safety Code § 40406:
“an emission limitation that is based on the maximum degree of reduction achievable by each class or category of source, taking into account environmental, energy, and economic impacts.”
- BARCT NO_x limits must be technically feasible and cost-effective based on class and category of equipment for all affected facilities
 - Cost-effectiveness is an average, there will be individual units with a cost-effectiveness above the threshold that will have to be retrofit to meet BARCT
- Must ensure it complies with AB 617
- Requirements for CEMS, SSM, missing data procedure, etc. would have to be similar to RECLAIM

Challenges with a Facility-Wide Mass Emissions Based Alternative b-Plan Compliance Options

21

Staff discussing concepts internally


Challenges

- Facility may be forced to reduce production or shutdown if the emissions cap is exceeded leading to an unexpected interruption in fuel supply
- Allowing vastly different compliance approaches could lead to inequities between facilities
- Potentially relieves sources from making any reductions if equipment shutdowns are allowed
- No commitment for per unit limitations, i.e. concentration or mass emission limit

NOx Limits and Implementation Schedule

22

Current proposal establishes various compliance pathways for BARCT equivalency and the implementation of BARCT requirements



* b-Plan is not required to include units that will be required to meet BARCT limits with Emerging Technology

Compliance with Table 1 NOx Limits

- Facilities with less than six units or that prefer not using the flexibility of the b-Plan, will meet the Table 1 NOx limits
- Facilities with less than six units are be required to submit a permit application by the deadline stated in Table 1 and meet the applicable emission limit 18 months after the permit to construct is issued (subdivision (d)(1))
- Facilities with six or more units can opt to comply with Table 1 emissions limits and comply with the implementation schedule in an approved i-Plan

TABLE 1: NO_x AND CO EMISSION LIMITS

STEAM METHANE REFORMER HEATERS				
Equipment Category	NO _x (ppmv)	CO (ppmv)	Averaging Time (Rolling Average)	Permit Application Submittal Deadline
	3% O ₂			
SMR Heater	5	400	24 hours	July 1, 2022 or pursuant to subdivision (k)

BARCT Equivalent Compliance Plan (b-Plan)

- The b-Plan is designed to address challenging retrofits that can achieve close to the BARCT limits, but would be very costly to meet the proposed BARCT limits
 - Achieve equivalent NOx reductions at reduced cost
 - Can select an alternative NOx concentration limit, provided emissions in aggregate representative of BARCT
- b-Plan will be facility-wide (all facilities within the company) and tailored to each facility's equipment
- A facility NOx **target** will be established as the sum of the mass emissions from all equipment meeting the BARCT limits
- Two approaches to comply being considered:
 - Facility selects a NOx concentration limit that can be met for each unit, provided the total annual emissions are less than or equal to facility NOx **target**
 - One-time demonstration, NOx concentration limit for each unit included on permit
 - Facility demonstrates total emissions are less than or equal to a facility NOx target (mass cap)
 - Require ongoing compliance demonstrations

Review of the Proposed b-Plan

25

Steps to Establish a Concentration b-Plan



Step 1

Operator selects the Alternative BARCT NO_x Limit for each unit



Step 2

- Calculate NO_x emissions for each unit using:
 - Alternative BARCT NO_x Limit in Step 1
 - Use emission data from 2017 as base year activity



Step 3

Calculate the Equivalent Mass Emissions by summing emissions for all units from Step 2



Step 4

- Confirm Equivalent Mass Emissions \leq Facility BARCT Emission Target
- Return to Step 1, if Equivalent Mass Emissions $>$ Facility BARCT Emission Target

Example of Calculating the Facility BARCT Emission Target*

- BARCT Control Efficiency is ratio of the PR 1109.1 Table 1 Proposed NOx Limit to the 2017 NOx Concentration
- Facility BARCT Emission Target is the product of:
 - BARCT Control Efficiency
 - 2017 Baseline Emissions
- Total Facility BARCT Emission Target is 26.1 tons/year (remaining emissions)

Category	Size (MMBtu/hr)	2017 Baseline Emissions (tpy)	2017 NOx Conc (ppmv)	PR 1109.1 Table 1 Proposed NOx Limit (ppmv)	BARCT Control Efficiency	Facility BARCT Emission Target (tpy)
Heater	100	8.8	20.0	5.0	75%	2.2
Heater	200	56.4	60.0	5.0	92%	4.7
Heater	150	16.8	40.0	5.0	88%	2.1
Boiler	300	104.4	60.0	5.0	92%	8.7
Heater	130	25.0	50.0	5.0	90%	2.5
Heater	100	6.0	25.0	5.0	80%	1.2
Heater	150	28.2	30.0	5.0	83%	4.7
						26.1

* Example assumes that Table 1 NOx limit for boilers and heaters ≥ 40 MMBtu/hr is 5 ppmv

Example of Calculating *Equivalent Mass Emissions*

- Alternative BARCT Control Efficiency is ratio of the Alternative NOx BARCT Limit to the 2017 NOx Concentration
- Equivalent Mass Emissions* is the product of the
 - Alternative BARCT Control Efficiency
 - 2017 Baseline Emissions
- Total Facility *Equivalent Mass Emissions* is 22.9 tons/year (remaining emissions)
- Emission reductions from units that are shutdown will be removed from the b-Plan

Category	Size (MMBtu/hr)	2017 NOx Conc (ppmv)	Alternative NOx BARCT Limit (ppmv)	Alternative BARCT Control Efficiency	Equivalent Mass Emissions (tpy)
Heater	100	20.0	8	60%	3.6
Heater	200	60.0	4	93%	3.7
Heater	150	40.0	3	93%	1.3
Boiler	300	60.0	5	92%	8.7
Heater	130	50.0	4	92%	2.0
Heater	100	25.0	7	72%	1.7
Heater	150	30.0	2	93%	1.9
					22.9

Comparison

- Alternative NOx concentrations may be higher or lower than PR 1109.1 Table 1 Proposed NOx limit
- Equivalent Mass Emissions must be less than or equal to Facility BARCT Emission Target

Category	Size (MMBtu/hr)	PR 1109.1 Table 1 Proposed NOx Limit (ppmv)	BARCT Control Efficiency	Facility BARCT Emission Target (tpy)	Alternative NOx BARCT Limit (ppmv)	Alternative BARCT Control Efficiency	Equivalent Mass Emissions (tpy)
Heater	100	5.0	75%	2.2	8	60%	3.6
Heater	200	5.0	92%	4.7	4	93%	3.7
Heater	150	5.0	88%	2.1	3	93%	1.3
Boiler	300	5.0	92%	8.7	5	92%	8.7
Heater	130	5.0	90%	2.5	4	92%	2.0
Heater	100	5.0	80%	1.2	7	72%	1.7
Heater	150	5.0	83%	4.7	2	93%	1.9
				26.1			22.9

Additional Details of Concentration b-Plan

- Approach retains the command-and-control structure, but acknowledges certain units may have greater challenges to achieve the proposed NOx BARCT limits in Table 1
- Operator will be required to achieve the Alternative NOx BARCT Limit in lieu of the NOx concentration limits in PR 1109.1 Table 1
 - The alternative NOx concentration limits will be on permit
- Facilities will need to comply with the NOx limit over the averaging time for that equipment type as prescribed in PR 1109.1
- No throughput limitations
- All other concentration-based requirements (e.g., CEMS, SSM, etc) would be applicable



Implementation Plan (i-Plan)

31


Implementation Plan (i-Plan)

- Establishes a framework to outline which projects will be implemented and within a certain timeframe (phase)
- Each phase of the schedule will be assigned an emission reduction goal
- Facilities can choose which projects will be part of each phase as long as the all projects in that phase meet the emission reduction goal
- The total emission reductions from each phase is the total of the lifetime emission reductions (unit share) for each of the projects
- The unit share is the emission reductions achieved from the unit meeting the BARCT limit compared to their 2017 emissions
 - If a facility elects to comply through a b-Plan, the emission reductions will be calculated based on the alternative NOx limits



i-Plan Original Proposal

- At the last WGM, staff presented a revised implementation plan (i-Plan) to two main phases, with an optional third phase for the most challenging projects or units with an extended turnaround schedule
 - Approach will seek 95 percent of the reductions by 2030, with the remaining 5 percent by 2034
- After discussions with stakeholders on challenges for units with long turnaround schedules, staff proposing an alternative option that:
 - Allows for longer implementation windows to minimize production disruption
 - Frontloads the emissions reductions in the first phase to compensate for longer timeline




Units with Extended Turn Around Schedules

- Some units at the refineries have extended turnaround schedules
 - For example, the crude unit is the first unit that processes petroleum in any refinery, so these units or related units may have an extended turnaround schedule
 - Critical unit for the operation of the refinery that is only shutdown during major turnarounds
 - Major turnaround may only occur once every 8 to 10 years to minimize disruption to the overall refining process
- Staff is seeking to accommodate turnaround schedules to minimize disruptions at the refineries and to achieve emissions reductions as soon as feasible
- Staff is committed to work closely with the refineries during the permit application submittal and issuance to avoid any costly delays that result in missing a turnaround window


i-Plan Revision to 2 Phase/Optional Phase

- Modified targets in the two phase/optional approach to reflect realistic schedules
- Could achieve greater reductions earlier and final compliance date sooner




i-Plan Revision to 2 Phase Only (No Optional Phase)

- Alternatively, simplify the i-Plan by collapsing into 2 phases
 - Maximize flexibility
 - Better accommodate turnaround schedules



i-Plan Implementation

- Facilities that opt to comply with Table 1 NOx limits may submit an i-Plan
- Facilities that opt to comply with a b-Plan will be required to submit an i-Plan
- All units that require retrofit will have to be included in the i-Plan other than units that require emerging technology to be installed at the end of useful life
- The following slides have examples of how the i-Plan will work with units complying with:
 - Table 1 NOx limits
 - b-Plan



Example of a Concentration b-Plan and i-Plan

Facility Selects "Not to Exceed" Alternative NOx BARCT Limit

Category	Size (MMBtu/hr)	PR 1109.1 Table 1 Proposed NOx Limit (ppmv)	Alternative NOx BARCT Limit (ppmv)	Total Emissions (tpy)	b-Plan Emission Reduction (tpy)	i-Plan Remaining Emission (tpy)	
Heater	100	5	8	5.7	2.1	3.6	Phase I 70% Reduction
Heater	200	5	4	10.1	6.4	3.7	
Heater	150	5	3	4.4	3.1	1.3	
Boiler	300	5	5	18.2	9.5	8.7	
Heater	130	5	4	5.1	3.1	2.0	Full Compliance 100%
Heater	100	5	7	2.9	1.2	1.7	
Heater	150	5	2	7.8	5.9	1.9	
Total				54.2	31.3	22.9	

Proposed Rule 429.1: Start-Up and Shutdown Provisions at Petroleum Refineries

Background and Applicability

40

- Staff initially included start-up and shutdown provisions in PR 1109.1
- Staff has since decided it would be more appropriate to incorporate start-up and shutdown provisions for PR 1109.1 facilities into a companion rule – Proposed Rule 429.1 (PR 429.1)
 - Start-up and shutdown requirements for Rule 1109 – Emissions of Oxides of Nitrogen from Boilers and Process Heaters in Petroleum Refineries are addressed in Rule 429 – Start-Up and Shutdown Exemption Provisions for Oxides of Nitrogen
- PR 429.1 will apply to all units at former RECLAIM facilities and new facilities that are subject to PR 1109.1
 - Petroleum refineries
 - Facilities with related operations to petroleum refineries

Need for Start-Up and Shutdown Provisions

41

- During start-up and shutdown events, units cannot achieve proposed NO_x emission limits when:
 - Unit is not at steady-state conditions
 - Temperature is not optimal for pollution control equipment such as SCR
- RECLAIM does not establish limitations on the length of start-up and shutdown events
 - RECLAIM facilities are required to hold RTCs for all emissions, including excess emissions during start-up and shutdown events
- Some units have permit limits for start-up and shutdown events
 - Limitations can include the length of time and best management practices during start-up and shutdown events, provisions are determined on a case-by-case basis

Start-up and Shutdown Duration Limits

- Start-up and shutdown duration limits from PR 1109.1 were incorporated into PR 429.1
- Table 1 provides start-up and shutdown duration limits for units
- Start-up and shutdown are further limited
 - May not last longer than the time necessary to reach the minimum temperature of any post combustion control
 - Shall not last longer than is necessary to reach stable conditions

Requirements

- (1) An owner or operator of a unit shall not exceed the start-up and shutdown time periods specified in Table 1.

TABLE 1: START-UP AND SHUTDOWN DURATION LIMITS

Unit	Not to Exceed per Start-up or Shutdown Event (hours)
Boilers and Process Heaters with a rated heat input capacity < 40 MMBtu/hr, Gas Turbines, Flares, Vapor Incinerators	2
Sulfuric Acid Furnace	24
Boilers and Process Heaters with a rated heat input capacity ≥ 40 MMBtu/hr, Steam Methane Reformer Heaters	48
Steam Methane Reformer with Gas Turbine	60
FCCU, Petroleum Coke Calciner, SRU/TG Incinerators	120

- (A) An owner or operator of a unit shall not allow start-up or shutdown time period to last longer than the time that is necessary to reach minimum operating temperature of the exhaust emission control system, if applicable.
- (B) An owner or operator of a unit shall not allow start-up and shutdown time period to last longer than is necessary to reach stable conditions.

Efforts to Minimize Emissions During Start-up and Shutdown Events

During start-up and shutdown events, operators must take all possible steps to minimize emissions

An owner or operator of a unit shall take all possible steps to minimize emissions during start-up and shutdown events.

- Includes equipment repairs and adjusting temperatures of post-combustion controls

Requirements for Units with Exhaust Emission Control Systems

44

- (4) An owner or operator of a unit shall install and maintain a calibrated temperature gauge on all units with an exhaust emission control system.
- (5) If the temperature of the gas to the inlet of the emission control system is greater than or equal to 450° F, an owner or operator of a unit with an exhaust emission control system shall operate an exhaust emission control system, including the injection of any associated chemical reagent into the exhaust stream to control NO_x.

Units with exhaust emission controls are required to install and maintain a calibrated temperature gauge

Units with exhaust emission controls are required to operate the exhaust emission control when the inlet gas temperature is $\geq 450^{\circ}$ F

Limit to the Number of Scheduled Start-up and Shutdown Events

45

- Staff received comments about provision limiting the number of start-up and shutdown events
 - Comment: The proposed rule would authorize facilities to exceed emission limits an undetermined number of times a year for long periods of time
 - Comment: There should not be any limit to the number of start-ups and shutdowns because they are typically driven by emergencies or maintenance needs
- Staff is considering a provision to limit a unit to 10 scheduled start-up and shutdown events per year
 - Provision based on existing Rule 429 requirements that limits units subject to Rule 1109 to a maximum of 10 scheduled start-up or shutdown events per year
- Staff is considering fewer scheduled start-ups and shutdowns for FCCUs, petroleum coke calciners, and SRU/TG incinerators because of the longer start-up and shutdown duration
- Staff is seeking input from stakeholders

Proposed Rule 429.1 Definitions and Recordkeeping

46

- Staff will include applicable PR 1109.1 definitions in PR 429.1
- PR 429.1 requires records to be maintained on-site for 5 years
 - Operating log
 - List of scheduled start-up(s) and shutdown(s)

Recordkeeping

- (1) An owner or operator of a unit shall maintain the following records on-site for 5 years:
 - (A) An operating log containing the date, time, duration, reason for the start-up(s) and shutdown(s), and signature of a supervisor following each start-up and shutdown; and
 - (B) A list of scheduled start-ups and shutdowns.

Other PR 429.1 Provisions

47

- In response to stakeholder comments, staff included an exemption from start-up and shutdown duration limits and recordkeeping when fuel is burned exclusively in a pilot light

An owner or operator of a unit is exempt from paragraphs (d)(1) and (e)(1) when fuel is burned exclusively in a pilot light.

- Staff is considering additional provisions to address:
 - Maintenance of an exhaust emission control system (e.g. SCR)
 - Refractory dry out
- Staff is seeking input from stakeholders

ClearSign™ Technologies Update

48

ClearSign Update

World Oil Demonstration Project



- Partnership of ClearSign, World Oil, and SCAQMD
- Vertical cylindrical, natural draft Crude Heater
- 5 burners, 39MM BTU/hr (HHV) total fired duty
- Multi-burner factory test completed November 2020
 - Sub 6ppm NOx corrected to 3% oxygen at max rate in multi-burner test
- March 2021 installation
 - Burners installed during turnaround commencing Feb 21st
 - Installation took 3 days
 - March 1st start up
 - Full firing rate achieved with all 5 burners operating
 - Burners currently operating with some modifications resulting in higher than expected NOx performance
 - Replacement components being fabricated for installation in 2022

ClearSign Update

Second Los Angeles Project



- Confidential client within SCAQMD
- Vertical cylindrical, natural draft reboiler heater
- 3 burners, 12.5 MM BTU/hr (HHV) total fired duty
- Co-fires natural gas and process offgas
- March 2021 successful installation
 - March 10, 2021 start up
 - Full firing rate achieved with all 3 burners operating
 - NOx emissions range from 4.5-6.5 ppm NOx (corrected to 3% O2)
 - Meets 7 ppm NOx guarantee
 - Source test scheduled for April

Next Steps

Continue Discussions with Stakeholders



Complete Cost-Effectiveness and BARCT Reassessment



Release Preliminary Draft Staff Report and Rule Language



Public Workshop



Public Hearing September 2021

Proposed Rule 1109.1 Staff Contacts

52

Susan Nakamura

Assistant DEO

snakamura@aqmd.gov

909.396.3105

Michael Krause

Planning & Rules Manager

mkrause@aqmd.gov

909.396.2706

Heather Farr

Program Supervisor

hfarr@aqmd.gov

909.396.3672

Sarady Ka

AQ Specialist

ska@aqmd.gov

909.396.2331

Mojtaba Moghani, Ph.D.

AQ Specialist

mmoghani@aqmd.gov

909.396.2527

Zoya Banan, Ph.D.

AQ Specialist

zbanan@aqmd.gov

909.396.2332



RECLAIM Staff Contacts

53

Susan Nakamura
Assistant DEO

snakamura@aqmd.gov

909.396.3105

Michael Morris
Planning & Rules Manager

mmorris@aqmd.gov

909.396.3282

Uyen-Uyen Vo
Program Supervisor

uvo@aqmd.gov

909.396.2238

Lizabeth Gomez
AQ Specialist

lgomez@aqmd.gov

909.396.3103

Isabelle Shine
AQ Specialist

ishine@aqmd.gov

909.396.3064



Rule 429 Staff Contacts

54

Susan Nakamura

Assistant DEO

snakamura@aqmd.gov

909.396.3105

Michael Morris

Planning & Rules Manager

mmorris@aqmd.gov

909.396.3282

Rudy Chacon

Acting Program Supervisor

rchacon@aqmd.gov

909.396.2206

Isabelle Shine

AQ Specialist

ishine@aqmd.gov

909.396.3064

