



**Proposed Rule 1109.1 – Emissions of Oxides of Nitrogen  
for Petroleum Refineries and Related Operations**  
*Working Group Meeting #24*  
July 28, 2021

**Join Zoom Webinar**

<https://scaqmd.zoom.us/j/95665083938>

**Webinar ID: 956 6508 3938**

**Teleconference Dial-In: +1 669 900 6833**

# Agenda

2



Progress and Status Since Working Group Meeting #23

BARCT Reassessment for Vapor Incinerators: Non-Refinery Flare

Rule Language Updates Released 7/21/21

# Progress and Status Since WGM #23

3

# Status and Progress Since Last WGM

4

- Completed BARCT reassessment for all categories
- Continued meetings with stakeholders, WSPA, and environmental representatives
- Released third version of rule language with updated alternative compliance options

# Stakeholder Meetings in 2021

5



## Chevron

February 19  
February 26  
April 1  
May 20  
June 16  
July 14



## Marathon

January 27  
February 17  
February 24  
March 9  
March 23  
May 13  
July 27



## Phillips 66

February 16  
March 4  
March 31  
July 15  
July 23



## Torrance

January 29  
February 12  
February 26  
March 12  
March 24  
April 9  
April 28  
May 18  
June 1  
June 16  
July 1

July 20  
July 27



## Valero

January 29  
February 24  
April 16  
May 5  
May 19  
June 2  
July 27

# Stakeholder Meetings in 2021 (*cont.*)



<sup>1</sup> Biological Diversity, Coalition for Clean Air, Earth Justice, Communities for a Better Environment, Natural Resources Defense Council and East Yard Communities for Environmental Justice

A photograph of an industrial facility, likely a refinery or chemical plant. The scene is dominated by a complex network of pipes, metal structures, and a central vertical flare stack. The flare stack is a tall, cylindrical structure with a large, U-shaped pipe at the top. The background shows a clear blue sky with scattered white clouds. The overall atmosphere is industrial and functional.

# Non-Refinery Flare Follow-Up

7

# Vapor Incinerators

8

Afterburners, Ground Flares, Vapor Incinerators, and Thermal Oxidizers

```
graph TD; A[Afterburners, Ground Flares, Vapor Incinerators, and Thermal Oxidizers] --> B[Afterburners, Vapor Incinerators, and Thermal Oxidizers 15]; A --> C[Ground Flare 1];
```

✓  
Afterburners, Vapor Incinerators, and Thermal Oxidizers  
15

Ground Flare  
1



# Flares Subject to PR 1109.1 - Background

9


- Refinery flares are subject to Rule 1118 - Control of Emissions From Refinery Flares and are not subject to Rule 1109.1
- One non-refinery flare (not subject to Rule 1118) will be subject to PR 1109.1 that is used for liquid unloading and tank degassing
- Staff further refined the definition of the flare to make it clearer that Rule 1118 refinery flares are not subject to PR 1109.1

FLARE means, for the purpose of this rule, a combustion device that oxidizes combustible gases or vapors from tank farms or liquid unloading, where the combustible gases or vapors being destroyed are routed directly into the burner without energy recovery, and it is not subject to Rule 1118 – Control of Emissions from Refinery Flares.

# Flares Subject to PR 1109.1 – Background (*cont.*)

10

- At WGM #12, staff proposed a BARCT NO<sub>x</sub> limit of 20 ppm at 3% O<sub>2</sub> with burner control with low-use exemption of 20 hours/year
  - Only 1 small open flare in category
  - Used for air pollution control device for truck unloading and tank de-gassing
- Staff received updated cost for flare replacement
  - Flare replacement was already determined not to be cost-effective but low use threshold was set based on original cost estimates



# Flares Subject to PR 1109.1 – Background on Technical Feasibility

- Staff presented the technical feasibility of emission control technology for flares in WGM #12
  - Low-NOx flares can achieve 20 ppm (0.025 pounds per MMBtu)
    - Achieved in practice
    - Consistent with NOx limits in Rule 1118.1 - Control of Emissions From Non-refinery Flares

# Flare – Low-Use Exemption Re-Assessment

12

- Staff originally proposed a low-use limit of 20-hour/year based on original cost assumptions
  - After 20 hours, it was cost effective to replace unit
- Based on updated costs, cost-effectiveness for a flare replacement is ~\$500,000 per ton of NO<sub>x</sub> reduced
- Existing unit is a 20-year-old open flare that cannot be source tested
  - Most open flares have been phased out in our jurisdiction
    - Rule 1150.1 phased out most open flares by January 1, 2018
    - Rule 1118.1 requires flare replacement if an open flare operates at more than 5% capacity
- Considering a low-emitting exemption of no more than one pound NO<sub>x</sub> per day, if unit exceeds threshold for two consecutive years, flare replacement will be required

# Flare – Staff Recommendations

13

PR 1109.1 Flares

BARCT Limit  
20 ppm

## Staff Comment:

- No anticipated emission reductions

## **Recommendation:**

Low-emitting exemption of less than one lb/day, a unit that exceeds one lb/day for two consecutive years will require replacement

Rule Language Updates Released on 7/21/21

# Rule Structure

15

- (a) Purpose
- (b) Applicability
- (c) Definitions
- (d) Emission Limits
- (e) Compliance Schedule
- (f) B-Plan Requirements
- (g) B-Cap Requirements
- (h) Additional Provisions for Compliance Plans
- (i) CEMS Requirements
- (j) Source Test Requirements
- (k) Diagnostics Emission Checks
- (l) Monitoring, Recordkeeping, and Reporting Requirements
- (m) Exemptions

## Rule Attachments

- (A) Supplemental Requirements
- (B) I-Plan Requirements
- (C) B-Plan Requirements
- (D) B-Cap Requirements
- (E) Facilities Emissions – Baseline and Targets

# Subdivisions (a) and (b)

16

## ▪ **Subdivision (a) – Purpose**

The purpose of this rule is to reduce emissions of oxides of nitrogen (NO<sub>x</sub>), while not increasing carbon monoxide (CO) emissions, from units at petroleum refineries and facilities with related operations to petroleum refineries

## ▪ **Subdivision (b) – Applicability**

The provisions of this rule apply to an owner or operator of units at petroleum refineries and facilities with related operations to petroleum refineries

- include asphalt plants, biofuel plants, hydrogen production plants, petroleum coke calcining facilities, sulfuric acid plants, and sulfur recovery plants



## Subdivision (c) – Definitions

17

- Most of the new definitions describe aspects of the compliance plans
- New definitions also include:
  - Former RECLAIM Facility which was added to clarify when certain requirements will take effect
  - Natural gas and refinery fuel gas because gas turbines have different NOx limits depending on fuel
  - Units with combined stacks to clarify the applicable requirements

## Subdivision (d) – Emission Limits

18

- Subdivision (d) contains the emission limits, including:
  - Table 1: NO<sub>x</sub> and CO Emission Limits that represent BARCT
  - Table 2: NO<sub>x</sub> Emission Limits Near Table 1 NO<sub>x</sub> Limits
  - Table 3: Interim NO<sub>x</sub> and CO Emission Limits which are the bridge limits
- Tables were streamlined and compliance dates were moved to subdivision (e)

# PR 1109.1 Table 1

- Table 1 lists NOx and CO limits, averaging times, and oxygen correction

**TABLE 1: NOx AND CO EMISSION LIMITS**

Unit	NOx (ppmv)	CO (ppmv)	Percent O <sub>2</sub>	Rolling Averaging Time
Boilers <40 MMBtu/hour	Pursuant to paragraph (d)(2)	400	3	2-hour
Boilers ≥40 MMBtu/hour	5	400	3	24-hour
Flares	20	400	3	2-hour
FCCU	2	500	3	365-day
	5			7-day
Gas Turbines fueled with Natural Gas	2	130	15	24-hour
Gas Turbines fueled with Refinery Fuel Gas	3	130	15	24-hour
Petroleum Coke Calciner	5	2,000	3	365-day
	10			7-day
Process Heaters <40 MMBtu/hour	Pursuant to paragraph (d)(3)	400	3	2-hour
Process Heaters ≥40 MMBtu/hour	5	400	3	24-hour
SRU/TG Incinerators	30	400	3	24-hour
SMR Heaters	5	400	3	24-hour
SMR Heaters with Gas Turbine	5	130	15	24-hour
Sulfuric Acid Furnaces	30	400	3	365-day
Vapor Incinerators	30	400	3	2-hour

# Subdivision (d) – Emission Limits for Boilers and Process Heaters <40 MMBtu/hr

20

- NOx limits for boilers <40MMBtu/hour
  - Units will be required to meet a 40 ppmv limit as established in a permit to operate issued on or before January 1, 2023
  - Will be required to meet 5 ppmv when 50% or more of the burners or 50% or more of the heat input are replaced
- NOx limits for process heaters <40MMBtu/hour
  - Units will be required to meet a 40 ppmv limit as established in a permit to operate issued on or before January 1, 2023
  - Ten years after rule adoption, units will be required to meet 9 ppmv when 50% or more of the burners or 50% or more of the heat input are replaced
    - Ten-year timeframe because the 9 ppmv limit relies on emerging technology

# PR 1109.1 Table 2

Table 2 lists units with the near limits

**TABLE 2: NO<sub>x</sub> EMISSION LIMITS NEAR TABLE 1 NO<sub>x</sub> LIMITS**

Unit	NO <sub>x</sub> (ppmv)	CO (ppmv)	Percent O <sub>2</sub>	Rolling Averaging Time
FCCU	8	500	3	365-day
	16			7-day
Gas Turbines fueled with Natural Gas	2.5	130	15	24-hour
Process Heaters 40 – 110 MMBtu/hour	18	400	3	24-hour
Process Heaters >110 MMBtu/hour	22	400	3	24-hour
SMR Heaters	7.5	400	3	24-hour
Vapor Incinerators	40	400	3	2-hour

# PR 1109.1 Table 3

Table 3 lists the interim bridge limits

**TABLE 3: INTERIM NO<sub>x</sub> AND CO EMISSION LIMITS**

Unit	NO <sub>x</sub> (ppmv)	CO (ppmv)	Percent O <sub>2</sub>	Rolling Averaging Time <sup>1</sup>
Boilers and Process Heaters <40 MMBtu/hour	40	400	3	365-day
Boilers and Process Heaters ≥40 MMBtu/hour	Pursuant to paragraph (d)(13)	400	3	365-day
FCCU	40	500	3	365-day
Gas Turbines fueled with Natural Gas or Refinery Fuel Gas	20	130	15	365-day
Petroleum Coke Calciner	70	2,000	3	365-day
SRU/TG Incinerators	100	400	3	365-day
SMR Heaters	20 <sup>1</sup>	400	3	365-day
	60 <sup>2</sup>			365-day
SMR Heaters with Gas Turbine	5	130	15	365-day
Sulfuric Acid Furnaces	30	400	3	365-day
Vapor Incinerators	105	400	3	365-day

<sup>1</sup> SMR Heaters with post-combustion air pollution control equipment installed before [DATE OF RULE ADOPTION].

<sup>2</sup> SMR Heaters without post-combustion air pollution control equipment installed before [DATE OF RULE ADOPTION].

## Subdivision (d) – Interim Limit for boilers and process heaters $\geq 40$ MMBtu/hr

23

- Interim Limit for boilers and process heaters  $\geq 40$  MMBtu/hr in paragraph (d)(13)
  - Interim facility-wide NO<sub>x</sub> emission rate of 0.03 pound per million BTU of heat input is applicable for all boilers and process heaters  $\geq 40$  MMBtu/hr based on the maximum rated capacity until other NO<sub>x</sub> Rule 1109.1 Emission Limits are effective
  - For units firing at less than the maximum rated capacity, mass emissions shall be less than or equal to the quantity that would occur at maximum rated capacity

## Subdivision (d) – Other Provisions

24

- Allowing for higher NO<sub>x</sub> limit (5 ppmv) for gas turbines during periods of natural gas curtailment:
  - Natural gas curtailment is a shortage in the supply of natural gas due to supply limitations or restrictions
- If CO limit in permit is higher than Table 1, operators can retain the higher CO limit
- Allowing 365-day averaging times for initial 18 months of complying with limits to help with the transition from annual compliance in RECLAIM program NO<sub>x</sub> concentration limits
- For units with 365-day averaging time, allowing 14 months for the unit to comply with rolling average



# Subdivision (e) – Compliance Schedule

- Subdivision (e) establishes two compliance schedules
- Operators with less than six units must:
  - Submit permit applications by July 1, 2023 and meet the NO<sub>x</sub> and CO emission limits in Table 1 no later than 36 months after a Permit to Construct is issued
- Compliance schedule for operators with six or more units complying with Table 1 /Table 2, a B-Plan, or a B-Cap shall be based on either:
  - Submitting permit applications by July 1, 2023 and meeting the NO<sub>x</sub> and CO limits no later than 36 months after a Permit to Construct is issued; or
  - Submit an I-Plan and meet the NO<sub>x</sub> and CO limits based on the schedule established in this subdivision

# Subdivision (e) – I-Plan Compliance Schedule

- I-Plan is an alternative compliance schedule for facilities with six or more units
- I-Plan can be used for facilities complying with Table 1 limits, an approved B-Plan, or an approved B-Cap
- Compliance schedule and percent reductions listed in Table 4
- I-Plan must be submitted for approval by July 1, 2022:
  - Identify unit(s) to meet at least the Percent Reduction Targets for each Phase
  - Submit turnaround schedule for each unit
  - Specify I-Plan Option 1 or I-Plan Option 2

**TABLE 4: I-PLAN PERCENT REDUCTION TARGETS AND SCHEDULE<sup>(1)</sup>**

		Phase I	Phase II	Phase III
I-Plan Option 1	<b>Percent Reduction Targets</b>	<b>70</b>	<b>100</b>	<b>N/A</b>
	Permit Application Submittal Date	July 1, 2023	January 1, 2027	N/A
	Compliance Date	No later than 36 months after a Permit to Construct is issued	No later than 36 months after a Permit to Construct is issued	NA
I-Plan Option 2	<b>Percent Reduction Targets</b>	<b>60</b>	<b>80</b>	<b>100</b>
	Permit Application Submittal Date	July 1, 2023	January 1, 2025	January 1, 2028
	Compliance Date	No later than 36 months after a Permit to Construct is issued	No later than 36 months after a Permit to Construct is issued	No later than 36 months after a Permit to Construct is issued

<sup>1</sup> Percent reduction targets represent refinery-wide emission reductions including refineries under common ownership pursuant to Attachment E.

# Subdivision (e) – I-Plan Provisions

27

## ■ I-Plan Review

- Rule 1109.1 considers a 30-day period to resubmit a corrected I-Plan if the Executive Officer disapproves the initial I-Plan
- Upon second disapproval of the I-Plan by the Executive Officer, the owner or operator will be required to comply with the implementation schedule in paragraph (e)(1)

## ■ I-Plan Extension

- Under an approved I-Plan, one 12-month extension may be requested for each unit from the Compliance Date in Table 4
  - The request shall be made in writing no later than 90 days prior to the compliance date
- If disapproved, the applicable emission limits must be met within 60 calendar days after notification of disapproval is received

# Subdivision (e) – Other Compliance Schedule Provisions

28

- A unit complying with a near limit will be required to meet Table 1 limits if the NOx control equipment is replaced
- A unit meeting a low-use or low-emitting exemption that exceeds the exemption limits will have 6 months to submit a permit to comply with the Table 1 limits and 36 months to meet the limits after the permit to operate is issued

## Subdivision (f) – B-Plan Provisions

29

- The following are the requirements for a facility complying with a B-Plan:
  - B-Plan must be submitted no later than July 1, 2022
  - B-Plan may include all or part of the units in the corresponding facility
    - Common ownership is acknowledged
  - Alternative BARCT NO<sub>x</sub> limits for each unit to be identified by the owner or operator
  - Included units in the B-Plan cumulatively meet the Facility BARCT Emission Target
  - Equivalent Mass Emissions  $\leq$  Facility BARCT Emission Target
  - Sum of the Alternative Unit Share  $\geq$  I-Plan Percent Reduction Targets for each Phase in Table 4

## Subdivision (f) – B-Plan Provisions (*cont.*)

30

- If the B-Plan is disapproved, the owner or operator must resubmit the corrected B-Plan for approval within 30 days
- Upon the second disapproval of the B-Plan, the owner or operator is subject to comply with the emission limits in Table 1 or Table 2
- If the B-Plan is approved, all included units must acquire an enforceable South Coast AQMD permit condition, limiting:
  - NO<sub>x</sub> to the Alternative BARCT NO<sub>x</sub> limits for each unit in the B-Plan based on the applicable percent O<sub>2</sub> and averaging time in Table 1
  - CO to the Table 1 CO limits for each unit in the B-Plan based on the applicable percent O<sub>2</sub> and averaging time in Table 1

# Subdivision (g) – B-Cap Provisions

- Pre-preliminary draft rule contained some requirements, but provisions are still in development
- B-Cap is a mass cap alternative option
- Staff is proposing Maximum Alternative BARCT NOx to ensure all units will have a minimum level of control

**TABLE 5: Maximum Alternative BARCT NOx Limits**

Unit	Alternative NOx Limit (ppmv)	Percent Oxygen
Boilers and Process Heaters <40 MMBtu/hour	TBD	3
Boilers and Process Heaters ≥40 MMBtu/hour	TBD	3
FCCU	TBD	3
Gas Turbines	TBD	15
Petroleum Coke Calciner	TBD	3
SRU/TG Incinerator	TBD	3
Vapor Incinerator	TBD	3

# Subdivision (h) – Additional Provisions for Compliance Plans

32

- Modification to B-Plan and B-Cap
  - Modifications to B-Plan or B-Cap must be submitted to the Executive Officer no later than 90 days before the Permit Application Submittal Deadline in Table 4 (I-Plan)
  - Percent Reduction Targets in Table 4 and Facility BARCT Emission Targets must be met

- Turnaround Provision:

An owner or operator complying with an approved I-Plan can request a time extension from the Compliance Date in Table 4 if a permit to construct is issued more than 24 months after the date the permit application is deemed complete, provided:

- The permit to construct is issued after the units scheduled turnaround
- The subsequent scheduled turnaround for that unit does not occur until 12 months after the Compliance Date in Table 4; which could be accommodated through “time extension provision”



## Subdivision (i) – CEMS Provisions

33

- CEMS will be required for all units  $\geq 40$  MMBtu/hour
- Once facilities exit RECLAIM, they will have to comply with:
  - Rule 218.2 – Continuous Emission Monitoring System: General Provisions; and
  - Rule 218.3 – Continuous Emission Monitoring System: Performance Specifications
- CO CEMS will not be required on all units but units with an existing CO CEMS will be required to maintain it

# Subdivision (j) – Source Test Provisions

- For a unit with no CEMS requirement, compliance will be demonstrated by conducting a source test according to the schedule in Table 6
- A former RECLAIM Facility with a unit that has not conducted a source test within the schedule in Table 6 shall conduct a source test within:
  - 6 months from receiving a final determination notification for units 20 to <40 MMBtu/hour
  - 12 months from receiving a final determination notification for units <20 MMBtu/hour

**TABLE 6: SOURCE TESTING SCHEDULE**

Combustion Equipment	Source Test Schedule
Vapor Incinerators and Flares <40MMBtu/hr	Within 36 months from previous source test and every 36 months thereafter
All Other Units	Within 12 months from previous source test and every 12 months thereafter

## Subdivision (j) – Source Test Provisions (*cont.*)

35

- For units with air pollution control equipment with ammonia emissions in the exhaust, compliance with the ammonia permit limit shall be demonstrated through:
  - Using an ammonia CEMS
  - Conducting ammonia source testing according to the procedures in District Source Test Method 207.1 – Determination of Ammonia Emissions from Stationary Sources
    - Quarterly during the first 12 months of unit operation and thereafter
    - Annually when 4 consecutive quarterly source tests demonstrate compliance
    - Back to quarterly if an annual test demonstrates emissions exceed permit limit
- Source test must be conducted simultaneously for ammonia, NO<sub>x</sub> and CO for the units with no NO<sub>x</sub> and CO CEMS

## Subdivision (k) – Diagnostic Emission Checks

36

- PR 1109.1 requires diagnostic emission checks to be conducted at least:
  - Every 90 days or every 2,000 operating hours, whichever occurs later, for units that require a source test every 12 months
  - Every 365 days or every 8760 operating hours, whichever occurs later, for units that require a source test every 36 months
- Staff is considering removing the diagnostic emission check for units with 12 months source test requirement

## Subdivision (i) – Monitoring, Recordkeeping and Reporting (MRR) Requirements

37

- New MRR requirements for low-emitting and low-use units exempted from PR 1109.1 NO<sub>x</sub> emissions requirements
- MRR requirements for 0.03 lb/MMBtu interim limit for boilers and process heaters  $\geq 40$  MMBtu/hr still in development

# Subdivision (m) – Exemptions

38

- Most of the strikeout language in the exemption section is from reorganizing the provisions
  - Near limits that were include as exemptions moved to subdivision (d)
- New or amended exemptions include:
  - Amended exemption for small boilers or heaters ( $\leq 2$  MMBtu/hour) used for space or water heating that will be subject to Rule 1146.2 – Emissions of Oxides of Nitrogen from Large Water Heaters and Small Boilers and Process Heaters
  - Added a low-use exemption for process heater fired at less than 15 percent of the rated heat input capacity
  - Added an exemption for a FCCU that must bypass the post-combustion air pollution control equipment to conduct boiler inspections required under California Code of Regulations, Title 8, Section 770(b)

# PR 1109.1 – Attachments

- Attachment A
  - Contains the approach to calculate rolling average concentrations for units with CEMS
- Attachment B
  - Contains the approach and basis for determination of I-Plan elements (I-Plan Percent Reduction Targets for each phase, Unit Shares, and Alternative Unit Shares)
- Attachment C
  - Provides the method to calculate Facility BARCT Emission Target and Equivalent Mass Emissions under a B-Plan
- Attachment D
  - Provides the method to calculate the deterministic values to demonstrate compliance under a B-Cap
- Attachment E
  - Includes facilities baseline and target emissions as determined by the Executive Officer

# Next Steps

Continue Discussions with Stakeholders



Release Preliminary Draft Staff Report and Rule Language



Public Workshop



Public Hearing November 2021



# Proposed Rule 1109.1 Staff Contacts

41

Susan Nakamura

Assistant DEO

[snakamura@aqmd.gov](mailto:snakamura@aqmd.gov)

909.396.3105

Michael Krause

Planning & Rules Manager

[mkrause@aqmd.gov](mailto:mkrause@aqmd.gov)

909.396.2706

Heather Farr

Program Supervisor

[hfarr@aqmd.gov](mailto:hfarr@aqmd.gov)

909.396.3672

Sarady Ka

AQ Specialist

[ska@aqmd.gov](mailto:ska@aqmd.gov)

909.396.2331

Mojtaba Moghani, Ph.D.

AQ Specialist

[mmoghani@aqmd.gov](mailto:mmoghani@aqmd.gov)

909.396.2527

Zoya Banan, Ph.D.

AQ Specialist

[zbanan@aqmd.gov](mailto:zbanan@aqmd.gov)

909.396.2332



# RECLAIM Staff Contacts

42

Susan Nakamura  
Assistant DEO

[snakamura@aqmd.gov](mailto:snakamura@aqmd.gov)  
909.396.3105

Michael Morris  
Planning & Rules Manager

[mmorris@aqmd.gov](mailto:mmorris@aqmd.gov)  
909.396.3282

Uyen-Uyen Vo  
Program Supervisor

[uvo@aqmd.gov](mailto:uvo@aqmd.gov)  
909.396.2238

Lizabeth Gomez  
AQ Specialist

[lgomez@aqmd.gov](mailto:lgomez@aqmd.gov)  
909.396.3103

Isabelle Shine  
AQ Specialist

[ishine@aqmd.gov](mailto:ishine@aqmd.gov)  
909.396.3064



# Rule 429.1 Staff Contacts

43

**Susan Nakamura**

**Assistant DEO**

**[snakamura@aqmd.gov](mailto:snakamura@aqmd.gov)**

**909.396.3105**

**Michael Morris**

**Planning & Rules Manager**

**[mmorris@aqmd.gov](mailto:mmorris@aqmd.gov)**

**909.396.3282**

**Rudy Chacon**

**Acting Program Supervisor**

**[rchacon@aqmd.gov](mailto:rchacon@aqmd.gov)**

**909.396.2206**

**Isabelle Shine**

**AQ Specialist**

**[ishine@aqmd.gov](mailto:ishine@aqmd.gov)**

**909.396.3064**

