

# TAO Advisory Group Retreat

## Stationary – OCSD Biogas Engine Emission Reduction Project

February 2, 2011



**Howard Lange, Air Quality Engineer II**  
**South Coast Air Quality Management District**

# Background

- Most large landfills and water treatment plants in SCAQMD convert the landfill or digester gas (biogas) to electricity
  - Income for municipalities and encouraged by state programs,
  - 54 I.C. engines, 2200 avg. hp, 84 MW total capacity.




# Background (Cont.)

- Biogas engines have been allowed higher NO<sub>x</sub> than natural gas engines because NO<sub>x</sub> reduction catalysts could not be applied
  - contaminants in biogas rapidly fouled catalysts.

# Rule 1110.2 Amendment – 2008

- Biogas engines must reduce NO<sub>x</sub> to 11 ppm by 7/1/2012
- Down from NO<sub>x</sub> levels as high as 50 ppm.
  - *subject to a technology assessment finding that adequate technology exists.*



# Orange County Sanitation District Project

- October 2009 Governing Board approved funding
- Demonstration of retrofit technology on digester gas engine at OCSD's Fountain Valley plant



# Funding

Partners	Funding	Percent
OCSD	\$2,212,000	91
AQMD	\$200,000	9

# Project Overview

- Retrofit a 3,471 hp, 2500 kW digester gas engine with:
  - Digester gas carbon adsorption cleaning system
  - Urea tank & injection system
  - SCR catalyst system
  - Catalytic oxidizer
- Project Team
  - OCSD, Malcolm Pirnie, Inc. and Johnson Matthey



# Biogas Cleaning System





# SCR and Oxidation Catalyst System



# Status and Results to Date

- Construction/Startup March/April 2010
- Biogas Cleaning System Siloxane Removal  
Inlet 3.7-8.7 ppm                      Outlet < 0.1 ppm

- CEMS data (ppm @ 15% O<sub>2</sub>):

	<u>Measured</u>	<u>Proposed Rule Limit</u>
NO <sub>x</sub>	6 – 9	11
CO	6 – 8	250
VOC	< 0.1	30

- Formaldehyde reduction (co-benefit)  
Inlet 21 ppm                      Outlet < 1 ppm
- Final report expected June 2011.

ICE % Load

Natural Gas Flow (dscfm)

Digester Gas Flow (dscfm)

% Digester Gas

NOx @15%O2 (ppmvd), 15-Min Average

NOx @15%O2 (ppmvd), Real-time

CO @15%O2 (ppmvd), 15-Min Average

CO @15%O2 (ppmvd), Real-time

NOx Inlet @15%O2 (ppmvd), Real-time

NH3 Slip @15%O2 (ppmvd), Real-time

Urea Flow (gph)

CEMS Cabinet Temp (Deg F)

UNIT 1

ON-LINE

79.36 V

14.74 V

589.71 V

97.56 V

5.29 V

3.73 V

8.07 V

8.56 V

28.27 V

0.00 V

0.39 V

71.60 V

UNIT 2

ON-LINE

82.28 V

12.88 V

622.80 V

97.97 V

27.88 V

26.05 V

428.13 V

453.01 V

0.00 V

0.00 V

0.00 V

69.01 V

UNIT 3

ON-LINE

101.25 V

213.21 V

404.78 V

65.50 V

41.13 V

35.37 V

358.63 V

446.20 V

0.00 V

0.00 V

0.00 V

73.47 V

Plant Total NOx Lbs/Day, 30Day

75.82 V

Plant Total CO Lbs/Day, 30Day

739.71 V

Status Code: V-Valid, C-Calibration, M-Maintenance, P-Purge  
O-Out of Control, Unavail, D-Process Down

MAIN MENU

start

DELL